



Machine Id
LIEBHERR LH50M 118290-1216
 Component
Fuel Filter Diesel Fuel
 Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)



DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. Resample in 30-45 days to monitor this situation.

Corrosion

(not applicable)

Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible.

Fuel Condition

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			LH0260117	---	---
Sample Date	Client Info			11 Aug 2023	---	---
Machine Age	hrs	Client Info		19400	---	---
Sample Status				SEVERE	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	0.856	---	---
Fuel Color	text	Visual Screen*	Yllow	Red	---	---
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.9	---	---
Pensky-Martens Flash Point	°C	ASTM D7215*	52	64.9	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	10	---	---





DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	176	---	---
5% Distillation Point	°C	ASTM D2887*		205	---	---
10% Distill Point	°C	ASTM D2887*	201	214	---	---
15% Distillation Point	°C	ASTM D2887*		221	---	---
20% Distill Point	°C	ASTM D2887*	216	229	---	---
30% Distill Point	°C	ASTM D2887*	230	241	---	---
40% Distill Point	°C	ASTM D2887*	243	253	---	---
50% Distill Point	°C	ASTM D2887*	255	264	---	---
60% Distill Point	°C	ASTM D2887*	267	276	---	---
70% Distill Point	°C	ASTM D2887*	280	289	---	---
80% Distill Point	°C	ASTM D2887*	295	303	---	---
85% Distillation Point	°C	ASTM D2887*		313	---	---
90% Distill Point	°C	ASTM D2887*	310	323	---	---
95% Distillation Point	°C	ASTM D2887*		341	---	---
Final Boiling Point	°C	ASTM D2887*	341	359	---	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	33	---	---
Cetane Index		ASTM D4737*	<40.0	44	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	0	---	---
Sodium	ppm	ASTM D5185(m)	<0.1	0	---	---
Potassium	ppm	ASTM D5185(m)	<0.1	<1	---	---
Water	%	ASTM D6304*	<0.05	0.003	---	---
ppm Water	ppm	ASTM D6304*	<500	31.8	---	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	▲ 16626	---	---
Particles >6µm		ASTM D7647	>640	● 9274	---	---
Particles >14µm		ASTM D7647	>80	● 2432	---	---
Particles >21µm		ASTM D7647	>20	● 1037	---	---
Particles >38µm		ASTM D7647	>4	● 76	---	---
Particles >71µm		ASTM D7647	>3	5	---	---
Oil Cleanliness		ISO 4406 (c)	>18/16/13	● 21/20/18	---	---




FUEL REPORT



HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	---	---
Nickel	ppm	ASTM D5185(m)	<0.1	0	---	---
Lead	ppm	ASTM D5185(m)	<0.1	0	---	---
Vanadium	ppm	ASTM D5185(m)	<0.1	0	---	---
Iron	ppm	ASTM D5185(m)	<0.1	<1	---	---
Calcium	ppm	ASTM D5185(m)	<0.1	<1	---	---
Magnesium	ppm	ASTM D5185(m)	<0.1	0	---	---
Phosphorus	ppm	ASTM D5185(m)	<0.1	0	---	---
Zinc	ppm	ASTM D5185(m)	<0.1	0	---	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : LH0260117 **Received** : 16 Aug 2023
Lab Number : 02576301 **Diagnosed** : 24 Aug 2023
Unique Number : 5629361 **Diagnostician** : Kevin Marson
Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Weyerhaeuser
 1000 Jones road
 Kenora, ON
 CA P9N 3X8
 Contact: Rene Gagne
 rene.gagne@weyerhaeuser.com
 T: (807)548-7277
 F: (807)548-7201