

FUEL REPORT

Sample Rating Trend

ISO



Machine In LIEBHERR LH50M 118 Component

Tank Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SUL

Particles >71µm

Oil Cleanliness

ASTM D7647 >3

2

ISO 4406 (c) >18/16/13 **22/21/17**

50M 118290-1	1216					X
ALOW SULPHUR) (-	GAL)			Aug2023		
SAMPLE INFORM	1ATION	method	limit/base	current	history1	history
Sample Number		Client Info		LH0260108		
Sample Date		Client Info		11 Aug 2023		
Machine Age	hrs	Client Info		19400		
Sample Status				SEVERE		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history
Specific Gravity		ASTM D1298*	0.839	0.856		
Fuel Color	text	Visual Screen*	Yllow	Red		
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	2.8		
Pensky-Martens Flash Point	°C	ASTM D7215*	52	64.8		
SULFUR CONTER	NT	method	limit/base	current	history1	history
Sulfur	ppm	ASTM D5185(m)	10	10		
DISTILLATION		method	limit/base	current	history1	history
Initial Boiling Point	°C	ASTM D2887*	165	176		
5% Distillation Point	°C	ASTM D2887*		205		
10% Distill Point	°C	ASTM D2887*	201	214		
15% Distillation Point	°C	ASTM D2887*		221		
20% Distill Point	°C	ASTM D2887*	216	229		
30% Distill Point	°C	ASTM D2887*	230	241		
40% Distill Point	°C	ASTM D2887*	243	252		
50% Distill Point	°C	ASTM D2887*	255	264		
60% Distill Point	°C	ASTM D2887*	267	276		
70% Distill Point	°C	ASTM D2887*	280	289		
80% Distill Point	°C	ASTM D2887*	295	302		
85% Distillation Point	°C	ASTM D2887*		313		
90% Distill Point	°C	ASTM D2887*	310	323		
95% Distillation Point	°C	ASTM D2887*	0.44	341		
Final Boiling Point	°C	ASTM D2887*	341	361		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history
API Gravity		ASTM D1298*	37.7	33		
Cetane Index		ASTM D4737*	<40.0	44		
CONTAMINANTS		method	limit/base	current	history1	history
Silicon	ppm	ASTM D5185(m)	<1.0	0		
Sodium	ppm	ASTM D5185(m)	<0.1	0		
Potassium	ppm	ASTM D5185(m)	<0.1	<1		
Water	%	ASTM D6304*	<0.05	0.003		
ppm Water	ppm	ASTM D6304*	<500	29.1		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history
Particles >4µm		ASTM D7647	>2500	936247		
Particles >6µm		ASTM D7647	>640	🛑 13463		
Particles >14µm		ASTM D7647	>80	1278		
Particles >21µm		ASTM D7647	>20	4 31		
Particles >38µm		ASTM D7647	>4	<mark>▲</mark> 30		

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. Resample in 30-45 days to monitor this situation.

Corrosion

{not applicable

Contaminants

There is a high amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible.

Fuel Condition

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

Contact/Location: Rene Gagne - WEY100KEN



FUEL REPORT

