




# PROBLEM SUMMARY

Area  
**SB5**  
 Machine Id  
**ATLAS COPCO 1023898 SB5 compressor (S/N AP1302157)**  
 Component  
**Oil**  
 Fluid  
**ATLAS COPCO ROTO INJECT FLUID (7 LTR)**

Sample Rating Trend




## ADDITIVES



### COMPONENT CONDITION SUMMARY

#### ▲ Additives




### RECOMMENDATION

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. ( Customer Sample Comment: Check for metal fragments, we are waiting on filters and will change based on this test. )

### PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	ABNORMAL	---
Calcium	ppm	ASTM D5185(m)	1000	▲ 33	▲ 123	---
Zinc	ppm	ASTM D5185(m)	590	▲ 135	▲ 355	---
Sulfur	ppm	ASTM D5185(m)		▲ 838	▲ 993	---

PrtFilter



Customer Id: WATGEO  
 Sample No.: WC0776669  
 Lab Number: 02576423  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

## HISTORICAL DIAGNOSIS

### VISUAL METAL



#### 26 Jul 2023 Diag: Kevin Marson

The component was not specified so we have determined that this is a hydraulic system based on the fluid type in use. Please specify the correct component type on your next sample. We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. The fluid was specified as ATLAS COPCO ROTO INJECT FLUID, however, a fluid match indicates that this fluid is ISO 46 AW Hydraulic Oil. Please confirm the oil type and grade on your next sample. Light concentration of visible metal present. All other component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

ADDITIVES

Area  
**SB5**  
 Machine Id  
**ATLAS COPCO 1023898 SB5 compressor (S/N AP1302157)**  
 Component  
**Oil**  
 Fluid  
**ATLAS COPCO ROTO INJECT FLUID (7 LTR)**



## DIAGNOSIS

### Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. ( Customer Sample Comment: Check for metal fragments, we are waiting on filters and will change based on this test. )

### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0776669</b>	LH	---
Sample Date	Client Info	<b>15 Aug 2023</b>	26 Jul 2023	---
Machine Age	wks Client Info	<b>0</b>	0	---
Oil Age	wks Client Info	<b>3</b>	3	---
Oil Changed	Client Info	<b>N/A</b>	N/A	---
Sample Status		<b>ATTENTION</b>	ABNORMAL	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185(m)	<b>2</b>	4	---
Chromium	ppm ASTM D5185(m)	<b>0</b>	0	---
Nickel	ppm ASTM D5185(m)	<b>0</b>	<1	---
Titanium	ppm ASTM D5185(m)	<b>0</b>	0	---
Silver	ppm ASTM D5185(m)	<b>0</b>	0	---
Aluminum	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	---
Lead	ppm ASTM D5185(m)	<b>&lt;1</b>	0	---
Copper	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	---
Tin	ppm ASTM D5185(m)	<b>0</b>	0	---
Antimony	ppm ASTM D5185(m)	<b>0</b>	0	---
Vanadium	ppm ASTM D5185(m)	<b>0</b>	0	---
Beryllium	ppm ASTM D5185(m)	<b>0</b>	0	---
Cadmium	ppm ASTM D5185(m)	<b>0</b>	0	---

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	---
Barium	ppm ASTM D5185(m)	<b>&lt;1</b>	1	---
Molybdenum	ppm ASTM D5185(m)	<b>0</b>	0	---
Manganese	ppm ASTM D5185(m)	<b>0</b>	0	---
Magnesium	ppm ASTM D5185(m)	<b>&lt;1</b>	2	---
Calcium	ppm ASTM D5185(m) 1000	<b>▲ 33</b>	▲ 123	---
Phosphorus	ppm ASTM D5185(m) 510	<b>382</b>	▲ 177	---
Zinc	ppm ASTM D5185(m) 590	<b>▲ 135</b>	▲ 355	---
Sulfur	ppm ASTM D5185(m)	<b>▲ 838</b>	▲ 993	---
Lithium	ppm ASTM D5185(m)	<b>&lt;1</b>	<1	---

## CONTAMINANTS


method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m)	<b>0</b>	<1	---
Sodium	ppm ASTM D5185(m)	<b>6</b>	13	---
Potassium	ppm ASTM D5185(m) >20	<b>&lt;1</b>	1	---

## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>2122</b>	▲ 11190	---
Particles >6µm	ASTM D7647 >1300	<b>427</b>	▲ 2628	---
Particles >14µm	ASTM D7647 >160	<b>41</b>	▲ 212	---
Particles >21µm	ASTM D7647 >40	<b>15</b>	▲ 65	---
Particles >38µm	ASTM D7647 >10	<b>1</b>	4	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	1	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>18/16/13</b>	▲ 21/19/15	---

## FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974* 0.95	<b>0.29</b>	---	---






# OIL ANALYSIS REPORT


## Additives




## Particle Count




## Particle Trend



## Particle Trend




## Acid Number



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	▲ VLITE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	NEG	NEG	NEG
Free Water	scalar	Visual*	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	52.2	49.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




## GRAPHS

### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Filter (Magn: 100 x)



### Acid Number



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **Watch Tower Bible and Tract Society of Canada**  
**Sample No.** : WC0776669 **Received** : 17 Aug 2023 **13893 Highway 7**  
**Lab Number** : 02576423 **Diagnosed** : 24 Aug 2023 **Georgetown, ON**  
**Unique Number** : 5629483 **Diagnostician** : Kevin Marson **CA L7G 4S4**  
**Test Package** : IND 2 ( Additional Tests: BottomAnalysis, FILTERPATCH, PrtCount, PrtFilter, TAN, TBN ) **Contact: Purchasing Department**  
**purchase.ca@jw.org**

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.  
**T: (905)873-4101**  
**F: (905)873-4508**