




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**National Rubber - N00600**  
 Machine Id  
**A2308041**  
 Component  
**Hydraulic System**  
 Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

### Recommendation

This is a baseline read-out on the submitted sample. ( Customer Sample Comment: IND2-ICP KV AN KF )

### Wear

Iron ppm levels are noted.

### Contamination

Silicon ppm levels are notably high.

### Fluid Condition

{not applicable}

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>E3000201</b>	---	---
Sample Date	Client Info		<b>14 Aug 2023</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>Not Chngd</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		<b>0</b>	---	---
Iron	ppm	ASTM D5185(m) >20	<b>26</b>	---	---
Chromium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Nickel	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Silver	ppm	ASTM D5185(m)	<b>1</b>	---	---
Aluminum	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Lead	ppm	ASTM D5185(m) >20	<b>2</b>	---	---
Copper	ppm	ASTM D5185(m) >20	<b>15</b>	---	---
Tin	ppm	ASTM D5185(m) >20	<b>0</b>	---	---
Antimony	ppm	ASTM D5185(m)	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Cadmium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<b>1</b>	---	---
Barium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Molybdenum	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Manganese	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Magnesium	ppm	ASTM D5185(m)	<b>47</b>	---	---
Calcium	ppm	ASTM D5185(m)	<b>53</b>	---	---
Phosphorus	ppm	ASTM D5185(m)	<b>585</b>	---	---
Zinc	ppm	ASTM D5185(m)	<b>463</b>	---	---
Sulfur	ppm	ASTM D5185(m)	<b>2068</b>	---	---
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---






## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	<b>129</b>	---	---
Sodium	ppm	ASTM D5185(m)	<b>2</b>	---	---
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	---	---
Water	%	ASTM D6304* >0.05	<b>0.002</b>	---	---
ppm Water	ppm	ASTM D6304* >500	<b>16.2</b>	---	---

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>111</b>	---	---
Particles >6µm	ASTM D7647	>1300	<b>31</b>	---	---
Particles >14µm	ASTM D7647	>160	<b>4</b>	---	---
Particles >21µm	ASTM D7647	>40	<b>2</b>	---	---
Particles >38µm	ASTM D7647	>10	<b>0</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>14/12/9</b>	---	---

# OIL ANALYSIS REPORT







FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.63</b>	---	---
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	---	---
Silt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Debris	scalar	Visual*	NONE	<b>NONE</b>	---	---
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Appearance	scalar	Visual*	NORML	<b>NORML</b>	---	---
Odor	scalar	Visual*	NORML	<b>NORML</b>	---	---
Emulsified Water	scalar	Visual*	>0.05	<b>NEG</b>	---	---
Free Water	scalar	Visual*		<b>NEG</b>	---	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)		<b>44.2</b>	---	---
Visc @ 100°C	cSt	ASTM D7279(m)		<b>7.1</b>	---	---
Viscosity Index (VI)	Scale	ASTM D2270*		<b>120</b>	---	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : E30000201 **Received** : 17 Aug 2023  
**Lab Number** : **02576555** **Diagnosed** : 23 Aug 2023  
**Unique Number** : 5629615 **Diagnostician** : Tatiana Sorkina  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PQ, VI )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**Environmental 360 Solutions Ltd.**  
 640 Victoria Street  
 Cobourg, ON  
 CA K9A 5H5  
 Contact: Fred Kosseim  
 fkosseim@e360s.ca  
 T: (905)372-2251  
 F: (905)372-1658