




PROBLEM SUMMARY

Area
TV/2000 SAW
 Machine Id
102258 Main

Component
Hydraulic System
 Fluid
ESSO NUTO H ISO 68 (120 LTR)

Sample Rating Trend




WATER



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>5000	▲ 35581	▲ 18774	● 47618
Particles >6µm	ASTM D7647	>1300	▲ 5463	▲ 2533	▲ 5107
Particles >14µm	ASTM D7647	>160	▲ 282	▲ 216	▲ 294
Particles >21µm	ASTM D7647	>40	▲ 66	▲ 69	▲ 60
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 22/20/15	▲ 21/19/15	● 23/20/15
Appearance	scalar Visual*	NORML	▲ WGOIL	NORML	▲ WGOIL
Free Water	scalar Visual*		▲ 1%	NEG	▲ 5%

Customer Id: MITWAT
 Sample No.: WC0799514
 Lab Number: 02576734
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Water Access	---	---	?	We advise that you check for the source of water entry.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.
Filter Fluid	---	---	?	We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil.

HISTORICAL DIAGNOSIS

07 Feb 2023 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >4µm are abnormally high. Particles >6µm are abnormally high. Particles >14µm are notably high. Particles >21µm are notably high. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



03 Aug 2022 Diag: Kevin Marson

WATER



We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. Aluminum ppm levels are abnormal. Oil cooler core leaching or motor piston wear is indicated. Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >4µm are severely high.. Particles >4µm are severely high... Particles >6µm are abnormally high. Particles >14µm are notably high. Particles >21µm are notably high. Free water present. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



09 Feb 2022 Diag: Kevin Marson

WEAR



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. Aluminum ppm levels are abnormal. Oil cooler core leaching or motor piston wear is indicated. Particles >4µm are severely high. Particles >6µm are abnormally high. Particles >14µm are notably high. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
TV/2000 SAW
 Machine Id
102258 Main
 Component
Hydraulic System
 Fluid
ESSO NUTO H ISO 68 (120 LTR)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this oil. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. Free water present.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0799514	WC0763666	WC0688600
Sample Date	Client Info	25 Jul 2023	07 Feb 2023	03 Aug 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m) >30	6	5	8
Chromium	ppm	ASTM D5185(m) >2	<1	0	0
Nickel	ppm	ASTM D5185(m) >2	0	0	0
Titanium	ppm	ASTM D5185(m)	0	0	<1
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >2	2	2	▲ 5
Lead	ppm	ASTM D5185(m) >10	<1	<1	2
Copper	ppm	ASTM D5185(m) >25	1	<1	2
Tin	ppm	ASTM D5185(m) >20	0	0	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	<1

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m) 0	0	<1	<1
Barium	ppm	ASTM D5185(m) 0	0	0	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m) 5	<1	<1	<1
Calcium	ppm	ASTM D5185(m) 50	37	43	34
Phosphorus	ppm	ASTM D5185(m) 330	359	364	332
Zinc	ppm	ASTM D5185(m) 420	435	426	421
Sulfur	ppm	ASTM D5185(m) 3100	6613	6523	5573
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >25	6	6	13
Sodium	ppm	ASTM D5185(m)	1	<1	2
Potassium	ppm	ASTM D5185(m) >20	<1	<1	<1
Water	%	ASTM D6304* >0.05	0.006	0.005	---
ppm Water	ppm	ASTM D6304* >500	60.5	59.1	---


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ 35581	▲ 18774	● 47618
Particles >6µm	ASTM D7647 >1300	▲ 5463	▲ 2533	▲ 5107
Particles >14µm	ASTM D7647 >160	▲ 282	▲ 216	▲ 294
Particles >21µm	ASTM D7647 >40	▲ 66	▲ 69	▲ 60
Particles >38µm	ASTM D7647 >10	4	4	4
Particles >71µm	ASTM D7647 >3	0	1	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 22/20/15	▲ 21/19/15	● 23/20/15




OIL ANALYSIS REPORT


Particle Trend




Water




Acid Number



Water



Viscosity @ 40°C




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	.40	0.34	0.47	0.42

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	VLITE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	▲ WGOIL	NORML	▲ WGOIL
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	.2%	.2%	.5%
Free Water	scalar	Visual*		▲ 1%	NEG	▲ 5%


FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	68.8	64.6	64.3	65.9

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0799514
Lab Number : 02576734
Unique Number : 5629794
Test Package : IND 2 (Additional Tests: KF, TAN Man)

Received : 18 Aug 2023
Diagnosed : 23 Aug 2023
Diagnostician : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

MICHELIN TIRE
 866 RANDOLPH RD
 WATERVILLE, NS
 CA B0P 1V0
 Contact: Alan Davies
 alan.davies@michelin.com
 T: (902)534-3590
 F: x: