



# PROBLEM SUMMARY

Sample Rating Trend

ISO




Area  
**OPF1/BATCH OFF**

Machine Id  
**204522 Plastifier**


Component  
**Gearbox**

Fluid  
**MOBIL MOBILGEAR 600 XP 460 (375 LTR)**



## COMPONENT CONDITION SUMMARY

### Particle Trend



## RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 139084	19516	● 276626
Particles >6µm	ASTM D7647	>5000	● 92686	4365	● 51898
Particles >14µm	ASTM D7647	>640	● 6970	378	328
Particles >21µm	ASTM D7647	>160	▲ 739	108	37
Oil Cleanliness	ISO 4406 (c)	>21/19/16	● 24/24/20	21/19/16	● 25/23/16

Customer Id: MITWAT  
Sample No.: WC0799507  
Lab Number: 02576919  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access	---	---	?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 28 Mar 2023 Diag: Kevin Marson

#### VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 31 Jan 2023 Diag: Wes Davis

#### ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 27 Jul 2022 Diag: Wes Davis

#### ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**OPF1/BATCH OFF**

Machine Id  
**204522 Plastifier**

Component  
**Gearbox**

Fluid  
**MOBIL MOBILGEAR 600 XP 460 (375 LTR)**

## DIAGNOSIS

### Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0799507</b>	WC0763695	WC0763661
Sample Date	Client Info	<b>18 Jul 2023</b>	28 Mar 2023	31 Jan 2023
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>SEVERE</b>	ABNORMAL	SEVERE

## WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184*	<b>128</b>	---	105	
Iron	ppm	ASTM D5185(m) >200	<b>163</b>	1	128
Chromium	ppm	ASTM D5185(m) >15	<b>1</b>	0	<1
Nickel	ppm	ASTM D5185(m) >15	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m) >25	<b>0</b>	0	0
Lead	ppm	ASTM D5185(m) >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185(m) >200	<b>2</b>	0	1
Tin	ppm	ASTM D5185(m) >25	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m) >5	<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES






method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	<b>12</b>	34	15
Barium	ppm	ASTM D5185(m)	<b>0</b>	2	0
Molybdenum	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185(m)	<b>2</b>	0	1
Magnesium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Calcium	ppm	ASTM D5185(m)	<b>3</b>	0	<1
Phosphorus	ppm	ASTM D5185(m)	<b>327</b>	363	331
Zinc	ppm	ASTM D5185(m)	<b>5</b>	3	4
Sulfur	ppm	ASTM D5185(m)	<b>17339</b>	8400	17454
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >50	<b>3</b>	2	3
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	1
Potassium	ppm	ASTM D5185(m) >20	<b>&lt;1</b>	0	0

## FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>20000	<b>▲ 139084</b>	19516	● 276626
Particles >6µm	ASTM D7647	>5000	<b>● 92686</b>	4365	● 51898
Particles >14µm	ASTM D7647	>640	<b>● 6970</b>	378	328
Particles >21µm	ASTM D7647	>160	<b>▲ 739</b>	108	37
Particles >38µm	ASTM D7647	>40	<b>3</b>	6	0
Particles >71µm	ASTM D7647	>10	<b>1</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>● 24/24/20</b>	21/19/16	● 25/23/16




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.81</b>	0.76	0.70






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>VLITE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	460	<b>437</b>	▲ 338	440

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0799507 **Received** : 18 Aug 2023  
**Lab Number** : **02576919** **Diagnosed** : 21 Aug 2023  
**Unique Number** : 5629979 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: PQ, TAN Man )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**MICHELIN TIRE**  
 866 RANDOLPH RD  
 WATERVILLE, NS  
 CA B0P 1V0  
 Contact: Alan Davies  
 alan.davies@michelin.com  
 T: (902)534-3590  
 F: x: