




# PROBLEM SUMMARY

Sample Rating Trend




## ADDITIVES



Area  
**Kingsbridge SP-13584**  
Machine Id  
**T24 (S/N 21748)**  
Component  
**Wind Turbine Gearbox**  
Fluid  
**CHEVRON PINNACLE WM 320 (320 LTR)**

### COMPONENT CONDITION SUMMARY

#### ▲ Additives



### RECOMMENDATION

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.

### PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	SEVERE	SEVERE
Calcium	ppm	ASTM D5185(m)	0	0	1
			▲ 11		

Customer Id: VESTAS  
Sample No.: WC0783096  
Lab Number: 02576924  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1  
(289)291-4641 x4641  
[Bill.Quesnel@wearcheck.com](mailto:Bill.Quesnel@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

## HISTORICAL DIAGNOSIS

### 04 Apr 2023 Diag: Kevin Marson

#### WEAR



We recommend an early resample to monitor this condition. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 29 Sep 2022 Diag: Bill Quesnel

#### WEAR



We recommend an early resample to monitor this condition. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 03 Apr 2022 Diag: Kevin Marson

#### WEAR



Resample at the next service interval to monitor. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). Iron ppm levels are severe. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



## ADDITIVES



Area  
**Kingsbridge SP-13584**  
 Machine Id  
**T24 (S/N 21748)**  
 Component  
**Wind Turbine Gearbox**  
 Fluid  
**CHEVRON PINNACLE WM 320 (320 LTR)**

### DIAGNOSIS

#### Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

#### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0783096</b>	WC0783086	WC0632653
Sample Date	Client Info		<b>11 Aug 2023</b>	04 Apr 2023	29 Sep 2022
Machine Age	mths	Client Info	<b>0</b>	0	0
Oil Age	mths	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	SEVERE	SEVERE

### WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*	>50	<b>0</b>	0	0
Iron	ppm	ASTM D5185(m)	>75	<b>19</b>	111
Chromium	ppm	ASTM D5185(m)	>5	<b>&lt;1</b>	1
Nickel	ppm	ASTM D5185(m)	>10	<b>&lt;1</b>	<1
Titanium	ppm	ASTM D5185(m)	>10	<b>0</b>	0
Silver	ppm	ASTM D5185(m)		<b>&lt;1</b>	0
Aluminum	ppm	ASTM D5185(m)	>10	<b>0</b>	<1
Lead	ppm	ASTM D5185(m)	>3	<b>0</b>	<1
Copper	ppm	ASTM D5185(m)	>10	<b>&lt;1</b>	<1
Tin	ppm	ASTM D5185(m)	>3	<b>0</b>	0
Antimony	ppm	ASTM D5185(m)	>3	<b>0</b>	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	<1
Barium	ppm	ASTM D5185(m)	0	<b>0</b>	0
Molybdenum	ppm	ASTM D5185(m)	0	<b>0</b>	0
Manganese	ppm	ASTM D5185(m)		<b>&lt;1</b>	1
Magnesium	ppm	ASTM D5185(m)	0	<b>&lt;1</b>	<1
Calcium	ppm	ASTM D5185(m)	0	<b>11</b>	0
Phosphorus	ppm	ASTM D5185(m)	300	<b>300</b>	263
Zinc	ppm	ASTM D5185(m)	0	<b>6</b>	7
Sulfur	ppm	ASTM D5185(m)	8000	<b>7360</b>	6574
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1


### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>10	<b>0</b>	<1
Sodium	ppm	ASTM D5185(m)	>10	<b>&lt;1</b>	6
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	2
Water	%	ASTM D6304*	>0.02	<b>0.007</b>	0.007
ppm Water	ppm	ASTM D6304*	>200	<b>76.7</b>	72.3


### INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		<b>0</b>	0
Nitration	Abs/cm	ASTM D7624*		<b>2.1</b>	1.9
Sulfation	Abs./1mm	ASTM D7415*		<b>28.2</b>	27.8


### Additives




### Particle Count




### Acid Number



### Water



### Viscosity @ 100°C




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>270</b>	1455	341
Particles >6µm	ASTM D7647	>10000	<b>66</b>	448	66
Particles >14µm	ASTM D7647	>1300	<b>8</b>	49	6
Particles >21µm	ASTM D7647	>320	<b>3</b>	19	1
Particles >38µm	ASTM D7647	>80	<b>1</b>	1	0
Particles >71µm	ASTM D7647	>20	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/20/17	<b>15/13/10</b>	18/16/13	16/13/10

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	<b>27.3</b>	28.1	29.0
Acid Number (AN)	mg KOH/g	ASTM D974*	<b>0.71</b>	0.94	0.98

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*	<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	<b>324</b>	331	330
Visc @ 100°C	cSt	ASTM D7279(m)	<b>36.4</b>	36.0	36.4
Viscosity Index (VI)	Scale	ASTM D2270*	<b>159</b>	155	157

### SAMPLE IMAGES



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Vestas American Wind Technology Inc.  
**Sample No.** : WC0783096  
**Lab Number** : **02576924**  
**Unique Number** : 5629984  
**Test Package** : IND 2 ( Additional Tests: FT-IR, KF, KV100, PQ, TAN Man, VI )

**Received** : 18 Aug 2023  
**Diagnosed** : 23 Aug 2023  
**Diagnostician** : Bill Quesnel

1417 NW Everett Street  
Portland, OR  
US 97209  
Contact: Nicole Philippi  
NiPhi@vestas.com  
T: (503)327-7683  
F: (503)327-0247

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
Validity of results and interpretation are based on the sample and information as supplied.