




PROBLEM SUMMARY

Sample Rating Trend

ISO




Area
Capital Power PDN - SC011776
 Machine Id
T513 (S/N 00021147ZD)
 Component
Wind Turbine Gearbox
 Fluid
MOBIL MOBILGEAR SHC XMP 320 (395 LTR)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	NORMAL	NORMAL
Particles >6µm	ASTM D7647 >10000	▲ 23237	548	6098
Oil Cleanliness	ISO 4406 (c) >--/20/17	▲ 24/22/11	19/16/13	21/20/15

Customer Id: VESTAS
 Sample No.: WC0824661
 Lab Number: 02576943
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

09 Jan 2023 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



15 Jul 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. NOTE: An increase in the particle count is noted. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



21 Jan 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

ISO



Area
Capital Power PDN - SC011776
 Machine Id
T513 (S/N 00021147ZD)
 Component
Wind Turbine Gearbox
 Fluid
MOBIL MOBILGEAR SHC XMP 320 (395 LTR)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0824661	WC0768687	WC0720393
Sample Date	Client Info		09 Aug 2023	09 Jan 2023	15 Jul 2022
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*	>50	0	0	0
Iron	ppm	ASTM D5185(m)	>75	27	30
Chromium	ppm	ASTM D5185(m)	>5	<1	<1
Nickel	ppm	ASTM D5185(m)	>10	0	<1
Titanium	ppm	ASTM D5185(m)	>10	0	0
Silver	ppm	ASTM D5185(m)		0	0
Aluminum	ppm	ASTM D5185(m)	>10	0	<1
Lead	ppm	ASTM D5185(m)	>3	0	<1
Copper	ppm	ASTM D5185(m)	>5	2	4
Tin	ppm	ASTM D5185(m)	>3	0	0
Antimony	ppm	ASTM D5185(m)	>3	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0
Beryllium	ppm	ASTM D5185(m)		0	0
Cadmium	ppm	ASTM D5185(m)		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	<1
Barium	ppm	ASTM D5185(m)		0	0
Molybdenum	ppm	ASTM D5185(m)	0	<1	0
Manganese	ppm	ASTM D5185(m)		<1	<1
Magnesium	ppm	ASTM D5185(m)		0	0
Calcium	ppm	ASTM D5185(m)	0	<1	0
Phosphorus	ppm	ASTM D5185(m)	485	333	343
Zinc	ppm	ASTM D5185(m)	0	13	22
Sulfur	ppm	ASTM D5185(m)		3627	3806
Lithium	ppm	ASTM D5185(m)		<1	<1

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>40	3	3
Sodium	ppm	ASTM D5185(m)	>10	<1	1
Potassium	ppm	ASTM D5185(m)	>20	<1	<1
Water	%	ASTM D6304*	>0.02	0.011	0.004
ppm Water	ppm	ASTM D6304*	>200	111.0	42.1

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*		0	0
Nitration	Abs/cm	ASTM D7624*		2.3	2.4
Sulfation	Abs/.1mm	ASTM D7415*		50.0	29.5



OIL ANALYSIS REPORT









FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		112199	2743	10659
Particles >6µm	ASTM D7647	>10000	23237	548	6098
Particles >14µm	ASTM D7647	>1300	13	41	245
Particles >21µm	ASTM D7647	>320	3	10	36
Particles >38µm	ASTM D7647	>80	0	2	1
Particles >71µm	ASTM D7647	>20	0	2	0
Oil Cleanliness	ISO 4406 (c)	>--/20/17	24/22/11	19/16/13	21/20/15

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	56.5	27.2	25.2
Acid Number (AN)	mg KOH/g	ASTM D974*	1.02	1.02	1.02

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	NEG	NEG	NEG
Free Water	scalar	Visual*	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	324	324	323
Visc @ 100°C	cSt	ASTM D7279(m)	37.1	37.0	36.6
Viscosity Index (VI)	Scale	ASTM D2270*	163	162	161

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Vestas American Wind Technology Inc.
Sample No. : WC0824661 **Received** : 18 Aug 2023
Lab Number : **02576943** **Diagnosed** : 21 Aug 2023
Unique Number : 5630003 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: FT-IR, KF, KV100, PQ, TAN Man, VI)

1417 NW Everett Street
 Portland, OR
 US 97209
 Contact: Adam Meyer
 admey@vestas.com
 T: (519)983-0374
 F: (503)327-2001

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.