




PROBLEM SUMMARY




Sample Rating Trend

DEGRADATION

Area
Kingsbridge SP-13584
 Machine ID
T3 (S/N 21749)
 Component
Wind Turbine Gearbox
 Fluid
CHEVRON PINNACLE WM 320 (320 LTR)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend that you drain the oil from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	SEVERE
Iron	ppm	ASTM D5185(m)	>75	▲ 88	▲ 88	▲ 79
Zinc	ppm	ASTM D5185(m)	0	▲ 24	▲ 26	23
Acid Number (AN)	mg KOH/g	ASTM D974*	0.7	▲ 1.39	▲ 1.37	◆ 1.52

Customer Id: VESTAS
 Sample No.: WC0783142
 Lab Number: 02576946
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Bill Quesnel CLS, OMA II, MLA-III, LLA-I +1
 (289)291-4641 x4641
Bill.Quesnel@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	We recommend that you drain the oil from the component if this has not already been done.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

HISTORICAL DIAGNOSIS

27 Apr 2023 Diag: Kevin Marson

DEGRADATION



We recommend that you drain the oil from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. The AN level is above the recommended limit. Additive levels indicate the addition of a different brand, or type of oil. The oil is no longer serviceable.

view report



04 Oct 2022 Diag: Kevin Marson

DEGRADATION



We recommend that you drain the oil from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Additive levels indicate the addition of a different brand, or type of oil. The high AN level of the oil indicates the presence of oxi-polymerized products. The AN level is much higher than the recommended limit. The oil is no longer serviceable.

view report



30 Sep 2021 Diag: Bill Quesnel

DEGRADATION



We recommend that you drain the oil from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Additive levels indicate the addition of a different brand, or type of oil. The high AN level of the oil indicates the presence of oxi-polymerized products. The AN level is much higher than the recommended limit. The oil is no longer serviceable.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Area
Kingsbridge SP-13584
 Machine Id
T3 (S/N 21749)
 Component
Wind Turbine Gearbox
 Fluid
CHEVRON PINNACLE WM 320 (320 LTR)

DIAGNOSIS

Recommendation

We recommend that you drain the oil from the component if this has not already been done. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition.

Wear

Iron ppm levels are abnormal. The low ferrous density (PQ) index indicates the wear metal levels are due to corrosion.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is above the recommended limit. Additive levels indicate the addition of a different brand, or type of oil. The oil is no longer serviceable.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0783142	WC0783116	WC0305849
Sample Date	Client Info		26 Jul 2023	27 Apr 2023	04 Oct 2022
Machine Age	yrs	Client Info	0	0	0
Oil Age	yrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184*	>50	0	0	0	
Iron	ppm	ASTM D5185(m)	>75	▲ 88	▲ 88	▲ 79
Chromium	ppm	ASTM D5185(m)	>5	1	<1	<1
Nickel	ppm	ASTM D5185(m)	>10	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	>10	0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>10	0	<1	0
Lead	ppm	ASTM D5185(m)	>3	1	1	1
Copper	ppm	ASTM D5185(m)	>10	2	2	2
Tin	ppm	ASTM D5185(m)	>3	0	0	<1
Antimony	ppm	ASTM D5185(m)	>3	0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0	2	1	2
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		<1	1	1
Magnesium	ppm	ASTM D5185(m)	0	<1	0	0
Calcium	ppm	ASTM D5185(m)	0	<1	0	0
Phosphorus	ppm	ASTM D5185(m)	300	210	228	219
Zinc	ppm	ASTM D5185(m)	0	▲ 24	▲ 26	23
Sulfur	ppm	ASTM D5185(m)	8000	6881	7099	6901
Lithium	ppm	ASTM D5185(m)		<1	<1	<1






CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>10	1	<1	1
Sodium	ppm	ASTM D5185(m)	>10	6	7	6
Potassium	ppm	ASTM D5185(m)	>20	1	3	<1
Water	%	ASTM D6304*	>0.02	0.011	0.008	0.007
ppm Water	ppm	ASTM D6304*	>200	115.2	84.4	77.2

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		0	0	0
Nitration	Abs/cm	ASTM D7624*		2.2	2.0	2.3
Sulfation	Abs/.1mm	ASTM D7415*		28.2	27.6	18.4

OIL ANALYSIS REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		589	7059	515
Particles >6µm	ASTM D7647	>10000	162	434	129
Particles >14µm	ASTM D7647	>1300	16	18	11
Particles >21µm	ASTM D7647	>320	6	5	2
Particles >38µm	ASTM D7647	>80	1	0	0
Particles >71µm	ASTM D7647	>20	1	0	0
Oil Cleanliness	ISO 4406 (c)	>--/20/17	16/15/11	20/16/11	16/14/11

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm ASTM D7414*		29.3	29.1	13.6
Acid Number (AN)	mg KOH/g ASTM D974*	0.7	1.39	1.37	1.52

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar Visual*	NONE	NONE	NONE	NONE
Silt	scalar Visual*	NONE	NONE	NONE	NONE
Debris	scalar Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar Visual*	NONE	NONE	NONE	NONE
Appearance	scalar Visual*	NORML	NORML	NORML	NORML
Odor	scalar Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar Visual*	>0.02	NEG	NEG	NEG
Free Water	scalar Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D7279(m)	319	328	330	331
Visc @ 100°C	cSt ASTM D7279(m)	35.4	35.6	35.8	36.0
Viscosity Index (VI)	Scale ASTM D2270*	156	154	154	155

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Vestas American Wind Technology Inc.
Sample No. : WC0783142 **Received** : 18 Aug 2023
Lab Number : 02576946 **Diagnosed** : 23 Aug 2023
Unique Number : 5630006 **Diagnostician** : Bill Quesnel
Test Package : IND 2 (Additional Tests: FT-IR, KF, KV100, PQ, TAN Man, VI)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

1417 NW Everett Street
 Portland, OR
 US 97209
 Contact: Nicole Philippi
 NiPhi@vestas.com
 T: (503)327-7683
 F: (503)327-0247