




PROBLEM SUMMARY

Sample Rating Trend



ADDITIVES



Area
Kingsbridge SP-13584


Machine Id
T5

Component
Wind Turbine Gearbox

Fluid
CHEVRON PINNACLE WM 320 (--- LTR)

COMPONENT CONDITION SUMMARY

▲ Additives



RECOMMENDATION

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL	
Phosphorus	ppm	ASTM D5185(m)	300	▲ 436	▲ 454	▲ 428
Sulfur	ppm	ASTM D5185(m)	8000	▲ 3995	▲ 4084	▲ 3984

Customer Id: VESTAS
Sample No.: WC0783144
Lab Number: 02576948
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1
(289)291-4641 x4641
Bill.Quesnel@wearcheck.com

To change component or sample information:
Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

HISTORICAL DIAGNOSIS

12 Apr 2023 Diag: Bill Quesnel

DIRT



We advise that you check all areas where dirt can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate concentration of dirt present in the oil. The water content is negligible. Phosphorus and sulfur ppm levels are abnormally high. The AN level is acceptable for this fluid.

view report



12 Apr 2022 Diag: Kevin Marson

ADDITIVES



The oil is near the end of its useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Phosphorus and sulfur ppm levels are abnormally high. The AN level is acceptable for this fluid.

view report



14 Oct 2021 Diag: Bill Quesnel

ADDITIVES



The oil is near the end of its useful service life, recommend schedule an oil change. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable. Phosphorus and sulfur ppm levels are abnormally high. The AN level is acceptable for this fluid.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ADDITIVES



Area
Kingsbridge SP-13584
 Machine Id
T5
 Component
Wind Turbine Gearbox
 Fluid
CHEVRON PINNACLE WM 320 (--- LTR)

DIAGNOSIS

Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0783144	WC0783066	WC0632600
Sample Date	Client Info		09 Aug 2023	12 Apr 2023	12 Apr 2022
Machine Age	yrs	Client Info	0	0	0
Oil Age	yrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184*	>50	0	0	0	
Iron	ppm	ASTM D5185(m)	>75	8	7	6
Chromium	ppm	ASTM D5185(m)	>5	0	0	0
Nickel	ppm	ASTM D5185(m)	>10	<1	0	<1
Titanium	ppm	ASTM D5185(m)	>10	0	<1	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>10	0	<1	0
Lead	ppm	ASTM D5185(m)	>15	<1	<1	0
Copper	ppm	ASTM D5185(m)	>10	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>10	0	0	0
Antimony	ppm	ASTM D5185(m)	>5	0	0	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	0	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)		0	<1	0
Magnesium	ppm	ASTM D5185(m)	0	<1	<1	0
Calcium	ppm	ASTM D5185(m)	0	1	0	2
Phosphorus	ppm	ASTM D5185(m)	300	▲ 436	▲ 454	▲ 428
Zinc	ppm	ASTM D5185(m)	0	6	4	4
Sulfur	ppm	ASTM D5185(m)	8000	▲ 3995	▲ 4084	▲ 3984
Lithium	ppm	ASTM D5185(m)		<1	<1	<1


CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>10	10	▲ 11	10
Sodium	ppm	ASTM D5185(m)	>10	1	1	<1
Potassium	ppm	ASTM D5185(m)	>20	0	0	<1
Water	%	ASTM D6304*	>0.02	0.007	0.006	0.005
ppm Water	ppm	ASTM D6304*	>200	73.6	61.0	50.7


INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		0	0	0
Nitration	Abs/cm	ASTM D7624*		2.1	1.9	2.3
Sulfation	Abs/1mm	ASTM D7415*		47.7	46.8	27.6


Additives




Particle Count




Acid Number



Water



Viscosity @ 100°C




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		456	4086	1008
Particles >6µm	ASTM D7647	>10000	113	1471	193
Particles >14µm	ASTM D7647	>1300	15	31	17
Particles >21µm	ASTM D7647	>320	7	7	4
Particles >38µm	ASTM D7647	>80	2	0	0
Particles >71µm	ASTM D7647	>20	1	0	0
Oil Cleanliness	ISO 4406 (c)	>--/20/17	16/14/11	19/18/12	17/15/11

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm	ASTM D7414*	53.4	52.9	24.1
Acid Number (AN)	mg KOH/g	ASTM D974*	0.93	0.93	0.96

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	NEG	NEG	NEG
Free Water	scalar	Visual*	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	342	342	346
Visc @ 100°C	cSt	ASTM D7279(m)	38.6	38.5	39.1
Viscosity Index (VI)	Scale	ASTM D2270*	163	162	163

SAMPLE IMAGES



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Vestas American Wind Technology Inc.
Sample No. : WC0783144 **Received** : 18 Aug 2023 1417 NW Everett Street
Lab Number : **02576948** **Diagnosed** : 23 Aug 2023 Portland, OR
Unique Number : 5630008 **Diagnostician** : Bill Quesnel US 97209
Test Package : IND 2 (Additional Tests: FT-IR, KF, KV100, PQ, PrtCount, TAN Man, VI) Contact: Nicole Philippi
 To discuss this sample report, contact Customer Service at 1-800-268-2131. NiPhi@vestas.com
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: (503)327-7683
 Validity of results and interpretation are based on the sample and information as supplied. F: (503)327-0247