







# FUEL REPORT


Fuel Distillation Curve




Particle Count




Water



Viscosity @ 40°C




Particle Trend



MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml ASTM D6469*	>=100000	0	0	---
Yeast	CFU/ml ASTM D6469*	>=100000	0	0	---
Mold	Colonies ASTM D6469*	MODER	NONE	NONE	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185(m)	<0.1	0	0	0
Nickel	ppm ASTM D5185(m)	<0.1	0	0	0
Lead	ppm ASTM D5185(m)	<0.1	0	0	0
Vanadium	ppm ASTM D5185(m)	<0.1	0	0	0
Iron	ppm ASTM D5185(m)	<0.1	<1	<1	<1
Calcium	ppm ASTM D5185(m)	<0.1	<1	<1	<1
Magnesium	ppm ASTM D5185(m)	<0.1	0	0	0
Phosphorus	ppm ASTM D5185(m)	<0.1	0	<1	<1
Zinc	ppm ASTM D5185(m)	<0.1	0	0	<1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PP13899605 **Received** : 21 Aug 2023  
**Lab Number** : 02577279 **Diagnosed** : 25 Aug 2023  
**Unique Number** : 5630339 **Diagnostician** : Kevin Marson  
**Test Package** : FUEL ( Additional Tests: Bacteria, CC Flash, GC-PercFuel, PRtCount )

**ExxonMobil Canada East Ltd.**  
 Hebron-Materials and Repair Coordin, Suite 1000, 100 New Gow  
 St. John's, NL  
 CA A1C 6K3  
 Contact: Liam Maher  
 liam.m.maher@exxonmobil.com  
 T: (709)273-3729  
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.