FUEL REPORT

Sample Rating Trend

ISO

Area
[145095]
Machine Id
60845311
Component
Diesel Fuel
Fluid
No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you filter this fluid before use. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Corrosion

{not applicable}

Contaminants

There is a moderate amount of silt (particulates < 14 microns in size) present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample. The water content is negligible.

Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B). The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**CU0021468**	---	---
Sample Date		Client Info		**20 Aug 2023**	---	---
Machine Age	hrs	Client Info		**0**	---	---
Sample Status				**ABNORMAL**	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	**0.861**	---	---
Fuel Color	text	Visual Screen*	Yllow	**Yllow**	---	---
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	**2.6**	---	---
Pensky-Martens Flash Point	°C	ASTM D7215*	52	**66.4**	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	**12**	---	---

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	**177**	---	---
5% Distillation Point	°C	ASTM D2887*		**207**	---	---
10% Distill Point	°C	ASTM D2887*	201	**218**	---	---
15% Distillation Point	°C	ASTM D2887*		**226**	---	---
20% Distill Point	°C	ASTM D2887*	216	**234**	---	---
30% Distill Point	°C	ASTM D2887*	230	**247**	---	---
40% Distill Point	°C	ASTM D2887*	243	**256**	---	---
50% Distill Point	°C	ASTM D2887*	255	**266**	---	---
60% Distill Point	°C	ASTM D2887*	267	**276**	---	---
70% Distill Point	°C	ASTM D2887*	280	**286**	---	---
80% Distill Point	°C	ASTM D2887*	295	**297**	---	---
85% Distillation Point	°C	ASTM D2887*		**307**	---	---
90% Distill Point	°C	ASTM D2887*	310	**317**	---	---
95% Distillation Point	°C	ASTM D2887*		**335**	---	---
Final Boiling Point	°C	ASTM D2887*	341	**355**	---	---

IGNITION QUALITY	method	limit/base	current	history1	history2
API Gravity	ASTM D1298*	37.7	**32**	---	---
Cetane Index	ASTM D4737*	<40.0	**42**	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	**0**	---	---
Sodium	ppm	ASTM D5185(m)	<0.1	**<1**	---	---
Potassium	ppm	ASTM D5185(m)	<0.1	**<1**	---	---
Water	%	ASTM D6304*	<0.05	**0.003**	---	---
ppm Water	ppm	ASTM D6304*	<500	**36.9**	---	---

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ **9916**	---	---
Particles >6µm	ASTM D7647	>640	▲ **1851**	---	---
Particles >14µm	ASTM D7647	>80	▲ **117**	---	---
Particles >21µm	ASTM D7647	>20	▲ **29**	---	---
Particles >38µm	ASTM D7647	>4	**1**	---	---
Particles >71µm	ASTM D7647	>3	**0**	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ **20/18/14**	---	---

FUEL REPORT

Particle Count



Particle Trend



Water



Viscosity @ 40°C

Gas Chromatography (GCD)



MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	ASTM D6469*	>=100000	**0**	---	---
Yeast	CFU/ml	ASTM D6469*	>=100000	**0**	---	---
Mold	Colonies	ASTM D6469*	MODER	**NONE**	---	---

HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	**0**	---	---
Nickel	ppm	ASTM D5185(m)	<0.1	**0**	---	---
Lead	ppm	ASTM D5185(m)	<0.1	**0**	---	---
Vanadium	ppm	ASTM D5185(m)	<0.1	**0**	---	---
Iron	ppm	ASTM D5185(m)	<0.1	**<1**	---	---
Calcium	ppm	ASTM D5185(m)	<0.1	**<1**	---	---
Magnesium	ppm	ASTM D5185(m)	<0.1	**<1**	---	---
Phosphorus	ppm	ASTM D5185(m)	<0.1	**<1**	---	---
Zinc	ppm	ASTM D5185(m)	<0.1	**<1**	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				*no image*	*no image*
Bottom				*no image*	*no image*

GRAPHS

Fuel Distillation Curve



Pensky-Martens Flash Point (°C)



GCD Spectrum



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : CU0021468
Lab Number : 02577295
Unique Number : 5630355
Test Package : FUEL (Additional Tests: Bacteria, CC Flash, GC-PercFuel, PrtCount)
Received : 21 Aug 2023
Diagnosed : 25 Aug 2023
Diagnostician : Kevin Marson

CUMMINS EASTERN CANADA LP
6950 EDWARDS BLVD
MISSISSAUGA, ON
CA L5T 2W2
Contact: Jason Doxsee
jason.doxsee@cummins.com
T: (613)847-5020
F: (905)795-0035

ISO 17025:2017 Accredited Laboratory

To discuss this sample report, contact Customer Service at 1-800-268-2131.
Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
Validity of results and interpretation are based on the sample and information as supplied.