




# FUEL REPORT

Sample Rating Trend

ISO



Area  
**CN GU 1874 G2 [147277]**  
 Machine Id  
**74959518**

Component  
**Diesel Fuel**  
 Fluid  
**No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)**

## DIAGNOSIS

### Recommendation

Laboratory test indicate that this fuel is suitable for use and meets all test requirements. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We advise that you filter this fluid before use. We recommend an early resample to monitor this condition.

### Corrosion

(not applicable)

### Contaminants

There is a moderate amount of particulates (2 to 100 microns in size) present in the fuel. The water content is negligible.

### Fuel Condition

The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B).

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>CU0021484</b>	CU0021402	---
Sample Date	Client Info			<b>18 Aug 2023</b>	25 Jul 2023	---
Machine Age	hrs	Client Info		<b>938</b>	937	---
Sample Status				<b>ABNORMAL</b>	SEVERE	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*	0.839	<b>0.851</b>	0.851	---
Fuel Color	text	Visual Screen*	Yllow	<b>Red</b>	Red	---
Visc @ 40°C	cSt	ASTM D7279(m)	3.0	<b>2.5</b>	2.6	---
Pensky-Martens Flash Point	°C	ASTM D7215*	52	<b>64.7</b>	66.6	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185(m)	10	<b>11</b>	10	---

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D2887*	165	<b>176</b>	179	---
5% Distillation Point	°C	ASTM D2887*		<b>203</b>	207	---
10% Distill Point	°C	ASTM D2887*	201	<b>213</b>	217	---
15% Distillation Point	°C	ASTM D2887*		<b>221</b>	225	---
20% Distill Point	°C	ASTM D2887*	216	<b>229</b>	232	---
30% Distill Point	°C	ASTM D2887*	230	<b>241</b>	244	---
40% Distill Point	°C	ASTM D2887*	243	<b>251</b>	253	---
50% Distill Point	°C	ASTM D2887*	255	<b>261</b>	263	---
60% Distill Point	°C	ASTM D2887*	267	<b>273</b>	275	---
70% Distill Point	°C	ASTM D2887*	280	<b>284</b>	286	---
80% Distill Point	°C	ASTM D2887*	295	<b>298</b>	300	---
85% Distillation Point	°C	ASTM D2887*		<b>307</b>	310	---
90% Distill Point	°C	ASTM D2887*	310	<b>317</b>	320	---
95% Distillation Point	°C	ASTM D2887*		<b>332</b>	335	---
Final Boiling Point	°C	ASTM D2887*	341	<b>350</b>	350	---






IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D1298*	37.7	<b>34</b>	34	---
Cetane Index		ASTM D4737*	<40.0	<b>45</b>	45	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<1.0	<b>0</b>	0	---
Sodium	ppm	ASTM D5185(m)	<0.1	<b>0</b>	0	---
Potassium	ppm	ASTM D5185(m)	<0.1	<b>&lt;1</b>	<1	---
Water	%	ASTM D6304*	<0.05	<b>0.008</b>	0.003	---
ppm Water	ppm	ASTM D6304*	<500	<b>80.5</b>	26.6	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	<b>▲ 6931</b>	◆ 43695	---
Particles >6µm		ASTM D7647	>640	<b>▲ 1880</b>	◆ 10429	---
Particles >14µm		ASTM D7647	>80	<b>▲ 171</b>	▲ 440	---
Particles >21µm		ASTM D7647	>20	<b>▲ 48</b>	▲ 60	---
Particles >38µm		ASTM D7647	>4	<b>2</b>	0	---
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>18/16/13	<b>▲ 20/18/15</b>	◆ 23/21/16	---






# FUEL REPORT



HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	---
Nickel	ppm	ASTM D5185(m)	<0.1	0	---
Lead	ppm	ASTM D5185(m)	<0.1	0	---
Vanadium	ppm	ASTM D5185(m)	<0.1	0	---
Iron	ppm	ASTM D5185(m)	<0.1	<1	---
Calcium	ppm	ASTM D5185(m)	<0.1	0	---
Magnesium	ppm	ASTM D5185(m)	<0.1	0	---
Phosphorus	ppm	ASTM D5185(m)	<0.1	0	---
Zinc	ppm	ASTM D5185(m)	<0.1	0	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					no image
Bottom					no image

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 CUMMINS CANADA ULC - GENERATOR DIVISION  
**Sample No.** : CU0021484 **Received** : 21 Aug 2023 7175 PACIFIC CIRCLE  
**Lab Number** : 02577297 **Diagnosed** : 23 Aug 2023 MISSISSAUGA, ON  
**Unique Number** : 5630357 **Diagnostician** : Kevin Marson CA L5T 2A5  
**Test Package** : FUEL ( Additional Tests: CC Flash, GC-PercFuel, PrtCount ) Contact: Zaneef Abboobakar  
 zaneef.abboobakar@cummins.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

F: (905)795-0035