




# PROBLEM SUMMARY

Sample Rating Trend




WEAR




Machine Id  
**L2-L4 NDT ENTRY CONV HPU**  
Component  
**Hydraulic System**  
Fluid  
**FORSYTHE TURBO HYDRAULIC AW 32 (500 LTR)**

## COMPONENT CONDITION SUMMARY

### ▲ Non-ferrous Metals



### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	ABNORMAL
Copper	ppm	ASTM D5185(m) >20	▲ 65	▲ 64
Particles >4µm		ASTM D7647 >5000	▲ 5598	2820
Oil Cleanliness		ISO 4406 (c) >19/17/14	▲ 20/17/11	19/16/11

Customer Id: WEL191WEL  
Sample No.: WC0851646  
Lab Number: 02577470  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

### 25 May 2023 Diag: Kevin Marson

#### WEAR



We recommend an early resample to monitor this condition. Copper ppm levels are abnormal. Oil cooler core leaching or motor piston wear is indicated. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 08 Jan 2023 Diag: Kevin Marson

#### WEAR



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Copper ppm levels are abnormal. Oil cooler core leaching or motor piston wear is indicated. Particles >4µm and oil cleanliness are abnormally high. Particles >6µm are notably high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 19 Sep 2022 Diag: Kevin Marson

#### WEAR



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Copper ppm levels are abnormal. Oil cooler core leaching or motor piston wear is indicated. Particles >4µm and oil cleanliness are abnormally high. Particles >6µm are notably high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Machine Id  
**L2-L4 NDT ENTRY CONV HPU**  
 Component  
**Hydraulic System**  
 Fluid  
**FORSYTHE TURBO HYDRAULIC AW 32 (500 LTR)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

### Wear

Copper ppm levels are abnormal. Oil cooler core leaching or motor piston wear is indicated.

### Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0851646</b>	WC0822504	WC0777246
Sample Date	Client Info		<b>21 Aug 2023</b>	25 May 2023	08 Jan 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	<b>4</b>	5	4
Chromium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	0
Lead	ppm	ASTM D5185(m)	>20	<b>2</b>	2	2
Copper	ppm	ASTM D5185(m)	>20	<b>▲ 65</b>	▲ 64	▲ 58
Tin	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<b>2</b>	4	2
Barium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>4</b>	4	4
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)		<b>8</b>	9	9
Calcium	ppm	ASTM D5185(m)		<b>63</b>	68	68
Phosphorus	ppm	ASTM D5185(m)		<b>403</b>	455	418
Zinc	ppm	ASTM D5185(m)		<b>415</b>	427	426
Sulfur	ppm	ASTM D5185(m)		<b>1556</b>	1729	1683
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	<1	<1
Sodium	ppm	ASTM D5185(m)		<b>1</b>	2	2
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	<1	0


## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>▲ 5598</b>	2820	▲ 10945
Particles >6µm	ASTM D7647	>1300	<b>663</b>	528	▲ 2324
Particles >14µm	ASTM D7647	>160	<b>16</b>	17	76
Particles >21µm	ASTM D7647	>40	<b>3</b>	2	18
Particles >38µm	ASTM D7647	>10	<b>0</b>	0	2
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>▲ 20/17/11</b>	19/16/11	▲ 21/18/13


## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	<b>0.54</b>	0.60	0.59


### Particle Trend




### Particle Count




### Particle Trend



### Acid Number




### Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	32	31.9	32.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### Particle Count



#### Acid Number



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0851646  
**Lab Number** : 02577470  
**Unique Number** : 5630530  
**Test Package** : IND 2

**Received** : 22 Aug 2023  
**Diagnosed** : 23 Aug 2023  
**Diagnostician** : Kevin Marson

**Welded Tube of Canada**  
 191 Ridge Road  
 Welland, ON  
 CA L3B 5N7  
 Contact: Steve Holjak  
 sholjak@weldedtube.com  
 T: (905)669-1111  
 F: (905)695-1504

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.