




PROBLEM SUMMARY

Sample Rating Trend


WEAR




Machine Id
C3-C8 HPU HYD. TESTER CONV. HPU
 Component
Hydraulic System
 Fluid
FORSYTHE TURBO HYDRAULIC AW 32 (400 LTR)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Non-ferrous Metals



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ATTENTION	ABNORMAL	
Lead	ppm	ASTM D5185(m)	>20	▲ 13	1	1
Copper	ppm	ASTM D5185(m)	>20	▲ 42	▲ 48	38
Particles >4µm		ASTM D7647	>5000	▲ 18883	▲ 7540	▲ 13740
Particles >6µm		ASTM D7647	>1300	▲ 1763	1059	▲ 2470
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ 21/18/13	▲ 20/17/13	▲ 21/18/13

Customer Id: WEL191WEL
 Sample No.: WC0851657
 Lab Number: 02577489
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using IND 3 test kits,

HISTORICAL DIAGNOSIS

25 May 2023 Diag: Kevin Marson

WEAR



We recommend you service the filters on this component. Resample at the next service interval to monitor. Copper ppm levels are noted. All other component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



08 Jan 2023 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm and oil cleanliness are abnormally high. Particles >6µm are notably high. The oil viscosity is higher than typical. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



19 Sep 2022 Diag: Kevin Marson

WEAR



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Copper ppm levels are noted. All other component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 46 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
C3-C8 HPU HYD. TESTER CONV. HPU
 Component
Hydraulic System
 Fluid
FORSYTHE TURBO HYDRAULIC AW 32 (400 LTR)

DIAGNOSIS

▲ Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

▲ Wear

Copper ppm levels are noted. Lead ppm levels are marginal. All other component wear rates are normal.

▲ Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0851657	WC0822499	WC0777250
Sample Date	Client Info		21 Aug 2023	25 May 2023	08 Jan 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ATTENTION	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	6	6	3
Chromium	ppm	ASTM D5185(m)	>20	2	2	2
Nickel	ppm	ASTM D5185(m)	>20	<1	<1	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	<1	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	0	0
Lead	ppm	ASTM D5185(m)	>20	▲ 13	1	1
Copper	ppm	ASTM D5185(m)	>20	▲ 42	▲ 48	38
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Antimony	ppm	ASTM D5185(m)		0	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<1	1	<1
Barium	ppm	ASTM D5185(m)		<1	0	0
Molybdenum	ppm	ASTM D5185(m)		<1	<1	<1
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)		2	2	3
Calcium	ppm	ASTM D5185(m)		23	25	28
Phosphorus	ppm	ASTM D5185(m)		394	419	402
Zinc	ppm	ASTM D5185(m)		406	411	416
Sulfur	ppm	ASTM D5185(m)		945	1015	1014
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<1	<1	0
Sodium	ppm	ASTM D5185(m)		0	0	0
Potassium	ppm	ASTM D5185(m)	>20	<1	<1	0


FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 18883	▲ 7540	▲ 13740
Particles >6µm	ASTM D7647	>1300	▲ 1763	1059	▲ 2470
Particles >14µm	ASTM D7647	>160	80	50	69
Particles >21µm	ASTM D7647	>40	23	11	14
Particles >38µm	ASTM D7647	>10	1	1	1
Particles >71µm	ASTM D7647	>3	0	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 21/18/13	▲ 20/17/13	▲ 21/18/13


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.59	0.63	0.60


▲ Particle Trend




▲ Particle Trend




▲ Non-ferrous Metals



Acid Number




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	32	34.9	33.2 38.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0851657
Lab Number : 02577489
Unique Number : 5630549
Test Package : IND 2 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Welded Tube of Canada
 191 Ridge Road
 Welland, ON
 CA L3B 5N7
 Contact: Steve Holjak
 sholjak@weldedtube.com
 T: (905)669-1111
 F: (905)695-1504