




# PROBLEM SUMMARY


Area  
**System 56 - Hazardous Drains [13884889]**  
 Machine Id  
**Z-5601B Centrifuge Gearbox Lube Oil**  
 Component  
**Gearbox**  
 Fluid  
**GEAR OIL ISO 320 (13 LTR)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please specify the brand, type, and viscosity of the oil on your next sample.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	SEVERE	ABNORMAL
Particles >4µm	ASTM D7647	>20000	▲ <b>147853</b>	● 217830	▲ 107804
Particles >6µm	ASTM D7647	>5000	▲ <b>30616</b>	● 71961	▲ 26167
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ <b>24/22/15</b>	● 25/23/19	▲ 24/22/14

**Customer Id:** HIBSTJ  
**Sample No.:** PP  
**Lab Number:** 02577584  
**Test Package:** MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Information Required	---	---	?	Please specify the brand, type, and viscosity of the oil on your next sample.

HISTORICAL DIAGNOSIS



**11 Mar 2023 Diag: Kevin Marson**

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend that you drain the oil from the component if this has not already been done. Resample in 30-45 days to monitor this situation. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are severely high. Particles >4µm are severely high. ppm Water and water and water and water contamination levels are abnormal. Particles >14µm are abnormally high. Particles >21µm are abnormally high. There is a moderate concentration of water present in the oil. Free water present. The white residue present in the sample is oil additive precipitate. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

view report



**29 Dec 2022 Diag: Kevin Marson**

We recommend you service the filters on this component. Confirm the source of the lubricant being utilized for top-up/fill. We recommend an early resample to monitor this condition. The fluid was specified as IRVING HDH SAE 80W90, however, a fluid match indicates that this fluid is ISO 320 Gear Oil. Please confirm the oil type and grade on your next sample. Copper ppm levels are abnormal. Particles >4µm are abnormally high. Particles >6µm and oil cleanliness are abnormally high. The water content is negligible. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



**24 Apr 2022 Diag: Kevin Marson**

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are abnormally high. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**System 56 - Hazardous Drains [13884889]**  
 Machine Id  
**Z-5601B Centrifuge Gearbox Lube Oil**

Component  
**Gearbox**  
 Fluid  
**GEAR OIL ISO 320 (13 LTR)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please specify the brand, type, and viscosity of the oil on your next sample.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PP</b>	PP	PP
Sample Date	Client Info	<b>08 Aug 2023</b>	11 Mar 2023	29 Dec 2022
Machine Age	hrs Client Info	<b>0</b>	0	0
Oil Age	hrs Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	SEVERE	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm ASTM D5185(m)	>150	<b>14</b>	9	54
Chromium ppm ASTM D5185(m)	>10	<b>&lt;1</b>	0	<1
Nickel ppm ASTM D5185(m)	>10	<b>&lt;1</b>	0	<1
Titanium ppm ASTM D5185(m)		<b>0</b>	0	<1
Silver ppm ASTM D5185(m)		<b>0</b>	0	0
Aluminum ppm ASTM D5185(m)	>5	<b>&lt;1</b>	0	<1
Lead ppm ASTM D5185(m)	>65	<b>2</b>	<1	3
Copper ppm ASTM D5185(m)	>80	<b>48</b>	4	<b>▲ 97</b>
Tin ppm ASTM D5185(m)	>8	<b>&lt;1</b>	<1	5
Antimony ppm ASTM D5185(m)	>5	<b>0</b>	<1	<1
Vanadium ppm ASTM D5185(m)		<b>0</b>	0	0
Beryllium ppm ASTM D5185(m)		<b>0</b>	0	0
Cadmium ppm ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm ASTM D5185(m)	50	<b>3</b>	10	5
Barium ppm ASTM D5185(m)	15	<b>&lt;1</b>	0	0
Molybdenum ppm ASTM D5185(m)	15	<b>0</b>	0	0
Manganese ppm ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Magnesium ppm ASTM D5185(m)	50	<b>2</b>	7	4
Calcium ppm ASTM D5185(m)	50	<b>7</b>	12	10
Phosphorus ppm ASTM D5185(m)	350	<b>239</b>	222	200
Zinc ppm ASTM D5185(m)	100	<b>10</b>	4	33
Sulfur ppm ASTM D5185(m)	12500	<b>6478</b>	9402	7915
Lithium ppm ASTM D5185(m)		<b>&lt;1</b>	<1	<1

## CONTAMINANTS






method	limit/base	current	history1	history2
Silicon ppm ASTM D5185(m)	>20	<b>6</b>	<1	3
Sodium ppm ASTM D5185(m)		<b>4</b>	42	26
Potassium ppm ASTM D5185(m)	>20	<b>&lt;1</b>	2	<1
Water % ASTM D6304*	>0.2	<b>0.032</b>	<b>▲ 0.583</b>	0.001
ppm Water ppm ASTM D6304*	>2000	<b>327.5</b>	<b>▲ 5835.4</b>	14.2

## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm ASTM D7647	>20000	<b>▲ 147853</b>	<b>■ 217830</b>	<b>▲ 107804</b>
Particles >6µm ASTM D7647	>5000	<b>▲ 30616</b>	<b>■ 71961</b>	<b>▲ 26167</b>
Particles >14µm ASTM D7647	>640	<b>191</b>	<b>▲ 4476</b>	83
Particles >21µm ASTM D7647	>160	<b>46</b>	<b>▲ 976</b>	17
Particles >38µm ASTM D7647	>40	<b>4</b>	19	3
Particles >71µm ASTM D7647	>10	<b>2</b>	1	2
Oil Cleanliness ISO 4406 (c)	>21/19/16	<b>▲ 24/22/15</b>	<b>■ 25/23/19</b>	<b>▲ 24/22/14</b>



# OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.85	<b>0.47</b>	0.50	0.58



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>VLITE</b>	▲ LIGHT	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	▲ MILKY	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	<b>.2%</b>	▲ .2%	NEG
Free Water	scalar	Visual*		<b>NEG</b>	▲ 1%	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	320	<b>316</b>	▲ 314	▲ 331

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



ISO 17025:2017 Accredited Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **HIBERNIA MGMT & DEVELOPMENT CO. LTD**  
**Sample No.** : PP **Received** : 22 Aug 2023 **SUITE 1000,, 100 NEW GOWER STREET**  
**Lab Number** : 02577584 **Diagnosed** : 24 Aug 2023 **ST.JOHNS, NL**  
**Unique Number** : 5630644 **Diagnostician** : Wes Davis **CA A1C 6K3**  
**Test Package** : MAR 2 ( Additional Tests: KF, PrtCount ) **Contact: Christopher Michelau**  
**christopher.j.michelau@exxonmobil.com**  
**T:**  
**F: (709)722-3766**