


PROBLEM SUMMARY

Area [7642388] Machine Id TINKER OMEGA PH82503 TRAY STAKER (S/N MIP-1224)

Hydraulic System

CASTROL HYSPIN DHV 46 (225 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

PROBLEMATIC TEST RESULTS Sample Status SEVERE SEVERE **ATTENTION** Particles >4µm ASTM D7647 >5000 34096 114662 ▲ 5466 Particles >6µm ASTM D7647 >1300 13426 50426 288 Particles >14µm ASTM D7647 >160 907 6195 18 Particles >21um ASTM D7647 >40 **196** 1809 9 **Oil Cleanliness** ISO 4406 (c) >19/17/14 22/21/17 24/23/20 20/15/11 Debris scalar Visual* NONE LIGHT NONE NONE PrtFilter no image no image


Customer Id: ESCPOR Sample No.: WC0741329 Lab Number: 02577730 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 <u>gloria.gonzalez@wearcheck.com</u>



RECOMMENDED /	ACTIONS			
Action	Status	Date	Done By	Description
Change Filter			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample			?	Resample in 30-45 days to monitor this situation.
Alert			?	We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Dirt Access			?	We advise that you check all areas where contaminants can enter the system.
Filter Fluid			?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

HISTORICAL DIAGNOSIS

17 Feb 2023 Diag: Wes Davis



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



view report



05 Jan 2023 Diag: Wes Davis

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

08 Jul 2022 Diag: Kevin Marson

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.All component wear rates are normal. Oil Cleanliness are abnormally high. Particles >14 μ m are abnormally high. Particles >21 μ m are abnormally high. Particles >6 μ m are abnormally high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.





OIL ANALYSIS REPORT

[7642388] TINKER OMEGA PH82503 TRAY STAKER (S/N MIP-1224)

Component **Hydraulic System**

CASTROL HYSPIN DHV 46 (225 LTR)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. We suspect that the abnormal contaminant(s) is the result of incorrect sampling technique. DISCLAIMER: Interpretation of results is based on the sample as received from the customer. The condition of the sample and the method of sampling cannot be verified.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. Light concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.





SAMPLE INFORMATION method WC0741329 Client Info WC0741325 Sample Number Client Info 15 May 2023 17 Feb 2023 05 Jan 2023 Sample Date Machine Age hrs **Client Info** 0 0 Oil Age hrs Client Info 0 0 Oil Changed **Client Info** N/A N/A SEVERE Sample Status SEVERE

Sample Rating Trend

ISO

WC0741335

ATTENTION

0

0

N/A

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	<1	<1	<1
Chromium	ppm	ASTM D5185(m)	>20	0	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		0	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	<1	0
Lead	ppm	ASTM D5185(m)	>20	0	0	0
Copper	ppm	ASTM D5185(m)	>20	<1	<1	<1
Tin	ppm	ASTM D5185(m)	>20	0	0	0
Antimony	ppm	ASTM D5185(m)		0	<1	0
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		7	8	8
Barium	ppm	ASTM D5185(m)		0	0	0
Molybdenum	ppm	ASTM D5185(m)		3	3	3
Manganese	ppm	ASTM D5185(m)		0	0	0
Magnesium	ppm	ASTM D5185(m)		23	23	23
Calcium	ppm	ASTM D5185(m)		109	118	114
Phosphorus	ppm	ASTM D5185(m)		409	432	418
Zinc	ppm	ASTM D5185(m)		483	488	467
Sulfur	ppm	ASTM D5185(m)		1355	1427	1371
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

CONTAMINANTS			method	limit/base	current	history1	history2	
	Silicon	ppm	ASTM D5185(m)	>15	3	3	3	
	Sodium	ppm	ASTM D5185(m)		0	0	0	
	Potassium	ppm	ASTM D5185(m)	>20	<1	<1	0	

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	34096	114662	▲ 5466
Particles >6µm	ASTM D7647	>1300	13426	• 50426	288
Particles >14µm	ASTM D7647	>160	6 907	6195	18
Particles >21µm	ASTM D7647	>40	196	1809	9
Particles >38µm	ASTM D7647	>10	5	92	1
Particles >71µm	ASTM D7647	>3	0	<u> </u>	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	22/21/17	• 24/23/20	▲ 20/15/11
FLUID DEGRADATION	method	limit/base	current	history1	history2

Acid Number (AN) Report Id: ESCPOR [WCAMIS] 02577730 (Generated: 08/24/2023 10:18:04) Rev: 1

mg KOH/g ASTM D974* 0.15

0.44 0.42

Contact/Location: Paul Dundas - ESCPOR


0.55



Î

number of particles (per 1


OIL ANALYSIS REPORT



00 50

र्छ १५

40 Abnorma



an 5/72

NONE

NONE

NONE

NONE

NONE

VLITE

NORML

NONE

NONE

NONE

NONE

NONE

NONE

NORML

VLITE

NONE

NONE

NONE

LIGHT

NONE

NORML

NONE

NONE

NONE

NONE

NONE

NONE

NORML

-B 0.00

May15/23

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 ESCO LTD. CALA Sample No. Received P.O.BOX 270, 185 HOPE STREET SOUTH : WC0741329 : 23 Aug 2023 Lab Number : 24 Aug 2023 PORT HOPE, ON : 02577730 Diagnosed ISO 17025:2017 Diagnostician : Kevin Marson Accredited Unique Number : 5630790 CA L1A 3W4 Laboratory **Test Package** : IND 2 (Additional Tests: Bottom, BottomAnalysis, FilterPatch, PrtFilter) Contact: Paul Dundas To discuss this sample report, contact Customer Service at 1-800-268-2131. paul.dundas@mail.weir T: (647)725-8153 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied. F: (905)885-7600

an 5/2/3

Feb17/23

Contact/Location: Paul Dundas - ESCPOR

Feb17/23