




FUEL REPORT

Sample Rating Trend

ISO



Area
[99830]
 Machine Id
C917102120
 Component
Diesel Fuel
 Fluid
DIESSEL FUEL No. 2 (--- GAL)



DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. Laboratory test indicate that this fuel is suitable for use and meets all test requirements. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you filter this fluid before use. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

Corrosion

(not applicable)

Contaminants

There is a high amount of silt (particulates < 14 microns in size) present in the fuel. The water content is negligible.

Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel, low sulfur (US EPA/CGSB-3.517-3 type B). The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	CU0019852	---	---
Sample Date	Client Info	19 Aug 2023	---	---
Machine Age	hrs Client Info	0	---	---
Sample Status		SEVERE	---	---

PHYSICAL PROPERTIES

method	limit/base	current	history1	history2	
Specific Gravity	ASTM D1298*	0.850	0.824	---	---
Fuel Color	text Visual Screen*	YELLOW	Red	---	---
Visc @ 40°C	cSt ASTM D7279(m)	4.1	2	---	---
Pensky-Martens Flash Point	°C ASTM D7215*	40	55.5	---	---

SULFUR CONTENT

method	limit/base	current	history1	history2	
Sulfur	ppm ASTM D5185(m)		8	---	---

DISTILLATION

method	limit/base	current	history1	history2	
Initial Boiling Point	°C ASTM D2887*	174	165	---	---
5% Distillation Point	°C ASTM D2887*		184	---	---
10% Distill Point	°C ASTM D2887*	186	192	---	---
15% Distillation Point	°C ASTM D2887*		198	---	---
20% Distill Point	°C ASTM D2887*	206	204	---	---
30% Distill Point	°C ASTM D2887*	226	215	---	---
40% Distill Point	°C ASTM D2887*	245	227	---	---
50% Distill Point	°C ASTM D2887*	260	238	---	---
60% Distill Point	°C ASTM D2887*	272	253	---	---
70% Distill Point	°C ASTM D2887*	285	268	---	---
80% Distill Point	°C ASTM D2887*	315	285	---	---
85% Distillation Point	°C ASTM D2887*		297	---	---
90% Distill Point	°C ASTM D2887*	360	309	---	---
95% Distillation Point	°C ASTM D2887*		328	---	---
Final Boiling Point	°C ASTM D2887*	>360	347	---	---

IGNITION QUALITY

method	limit/base	current	history1	history2	
API Gravity	ASTM D1298*	35.0	40	---	---
Cetane Index	ASTM D4737*	<40.0	49	---	---

CONTAMINANTS






method	limit/base	current	history1	history2	
Silicon	ppm ASTM D5185(m)	<1.0	0	---	---
Sodium	ppm ASTM D5185(m)	<0.1	<1	---	---
Potassium	ppm ASTM D5185(m)	<0.1	<1	---	---
Water	% ASTM D6304*	<0.05	0.003	---	---
ppm Water	ppm ASTM D6304*	<500	28.6	---	---

FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>2500	57637	---	---
Particles >6µm	ASTM D7647	>640	13702	---	---
Particles >14µm	ASTM D7647	>80	23	---	---
Particles >21µm	ASTM D7647	>20	2	---	---
Particles >38µm	ASTM D7647	>4	0	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	23/21/12	---	---






FUEL REPORT



HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185(m)	<0.1	0	---	---
Nickel	ppm	ASTM D5185(m)	<0.1	0	---	---
Lead	ppm	ASTM D5185(m)	<0.1	<1	---	---
Vanadium	ppm	ASTM D5185(m)	<0.1	0	---	---
Iron	ppm	ASTM D5185(m)	<0.1	<1	---	---
Calcium	ppm	ASTM D5185(m)	<0.1	0	---	---
Magnesium	ppm	ASTM D5185(m)	<0.1	0	---	---
Phosphorus	ppm	ASTM D5185(m)	<0.1	0	---	---
Zinc	ppm	ASTM D5185(m)	<0.1	0	---	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : CU0019852 **Received** : 24 Aug 2023
Lab Number : **02578272** **Diagnosed** : 28 Aug 2023
Unique Number : 5631332 **Diagnostician** : Kevin Marson
Test Package : FUEL (Additional Tests: CC Flash, GC-PercFuel, PrtCount)

CUMMINS EASTERN CANADA LP
 3189 SWANSEA CRESCENT
 OTTAWA, ON
 CA K1G 3W5
 Contact: Max Lauzon
 max.lauzon@cummins.com
 T:
 F: (613)736-1202

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.