




# OIL ANALYSIS REPORT

## Sample Rating Trend

**NORMAL**



## TURBLEX C1 COMPRESSOR LUBE OIL

Machine Id  
 Component  
**Centrifugal Compressor**  
 Fluid  
**SHELL TELLUS 46 (1025 LTR)**

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor. ( Customer Sample Comment: Annual oil sampling test )

#### Wear

All component wear rates are normal.

#### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The water content is negligible. The system and fluid cleanliness is acceptable.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0701216</b>	WC0701226	WC0361077
Sample Date	Client Info		<b>23 Aug 2023</b>	11 May 2022	12 May 2021
Machine Age	yrs	Client Info	<b>20</b>	7	0
Oil Age	yrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>50	<b>&lt;1</b>	0	<1
Chromium	ppm	ASTM D5185(m)	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)		<b>2</b>	2	2
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185(m)	>25	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185(m)	>25	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185(m)	>50	<b>2</b>	2	2
Tin	ppm	ASTM D5185(m)	>15	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0.0	<b>0</b>	0	1
Barium	ppm	ASTM D5185(m)	0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)	11	<b>&lt;1</b>	0	<1
Calcium	ppm	ASTM D5185(m)	35	<b>51</b>	52	52
Phosphorus	ppm	ASTM D5185(m)	266	<b>347</b>	335	314
Zinc	ppm	ASTM D5185(m)	276	<b>417</b>	420	414
Sulfur	ppm	ASTM D5185(m)	1847	<b>2472</b>	2486	2511
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

### CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>25	<b>2</b>	2	2
Sodium	ppm	ASTM D5185(m)		<b>1</b>	<1	2
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	<1
Water	%	ASTM D6304*	>0.1	<b>0.001</b>	0.001	---
ppm Water	ppm	ASTM D6304*	>1000	<b>10.5</b>	7.4	---

### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>181</b>	138	261
Particles >6µm	ASTM D7647	>2500	<b>58</b>	48	70
Particles >14µm	ASTM D7647	>320	<b>5</b>	5	5
Particles >21µm	ASTM D7647	>80	<b>3</b>	2	2
Particles >38µm	ASTM D7647	>20	<b>0</b>	0	0
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>15/13/10</b>	14/13/10	15/13/10



# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.36	<b>0.54</b>	0.45	0.52






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.99	<b>51.6</b>	47.2	46.7

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0701216  
**Lab Number** : 02578492  
**Unique Number** : 5631552  
**Test Package** : IND 2 ( Additional Tests: KF )  
**Received** : 25 Aug 2023  
**Diagnosed** : 29 Aug 2023  
**Diagnostician** : Kevin Marson

**NATIONAL RESEARCH COUNCIL**  
 1200 MONTREAL ROAD, BUILDING M-10  
 OTTAWA, ON  
 CA K1A 0R6  
 Contact: David Stevenson  
 david.s.stevenson@nrc-cnrc.gc.ca  
 T: (613)998-3483  
 F: (613)952-7677

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.