

PROBLEM SUMMARY

TEL23144 (S/N Propellor & Sterntube) Component

Sterntube Fluid

PETRO CANADA DURON MARINE SAE 30 (600 LTR)

COMPONENT CONDITION SUMMARY











RECOMMENDATION

Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit.

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE		ABNORMAL	ABNORMAL	
PQ		ASTM D8184*		<u> </u>				
Iron	ppm	ASTM D5185(m)	>15	e 89		7	6	
Aluminum	ppm	ASTM D5185(m)	>4	<u> </u>		1	1	
Calcium	ppm	ASTM D5185(m)	2540	<u> </u>		2124	2054	
Phosphorus	ppm	ASTM D5185(m)	1000	<u> </u>		1044	1037	
Zinc	ppm	ASTM D5185(m)	1110	<u> </u>		1036	1017	
Sulfur	ppm	ASTM D5185(m)	3700	<u> </u>		3403	3221	
Particles >6µm		ASTM D7647	>5000	0258	39	🔺 14182	🔺 14040	
Oil Cleanliness		ISO 4406 (c)	>/19/16	e 25/24/	/16	<u> </u>	<u> </u>	
Visc @ 40°C	cSt	ASTM D7279(m)	83.2	112		91.8	93.1	

Customer Id: CCGSTEL Sample No.: WC0836396 Lab Number: 02578549 Test Package: MAR 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com



RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Resample			?	We advise an early resample to confirm this situation.			
Alert			?	NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit.			

HISTORICAL DIAGNOSIS



08 May 2023 Diag: Kevin Marson

We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you follow the water drain-off procedure for this component. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.Lead ppm levels are abnormal. Bearing wear is indicated. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate concentration of water present in the oil. Free water present. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid.



08 Jan 2023 Diag: Bill Quesnel



We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We advise that you use off-line filtration with water adsorbent filters to attempt to remove the water from this oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.Lead ppm levels are noted. All other component wear rates are normal. Water and ppm water contamination levels are abnormal. Particles >6µm and oil cleanliness are abnormally high. There is a moderate concentration of water present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



28 Sep 2022 Diag: Kevin Marson

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report





OIL ANALYSIS REPORT

TEL23144 (S/N Propellor & Sterntube)

Sterntube

PETRO CANADA DURON MARINE SAE 30 (600 LTR)

DIAGNOSIS

Recommendation

Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit.

🛑 Wear

Iron ppm levels are severe. PQ levels are abnormal. Aluminum ppm levels are abnormal. Bearing wear is indicated. The high ferrous density (PQ) index indicates that abnormal wear is occurring.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The viscosity of the oil is higher than normal, possibly indicating the addition of a heavier grade of oil. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



SAMPLE INFOR	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		WC0836396	WC0740097	WC0723535	
Sample Date		Client Info		13 Aug 2023	08 May 2023	08 Jan 2023	
Machine Age	mths	Client Info		0	0	0	
Oil Age	mths	Client Info		0	0	8	
Oil Changed		Client Info		N/A	N/A	Not Changd	
Sample Status				SEVERE	ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
PQ		ASTM D8184*		4 8			
Iron	ppm	ASTM D5185(m)	>15	e 89	7	6	
Chromium	ppm	ASTM D5185(m)	>2	<1	<1	<1	
Nickel	ppm	ASTM D5185(m)	>2	0	<1	<1	
Titanium	ppm	ASTM D5185(m)	>8	<1	<1	<1	
Silver	ppm	ASTM D5185(m)		0	<1	0	
Aluminum	ppm	ASTM D5185(m)	>4	<u> </u>	1	1	
Lead	ppm	ASTM D5185(m)	>15	0	A 21	1 6	
Copper	ppm	ASTM D5185(m)	>25	4	11	8	
Tin	ppm	ASTM D5185(m)	>10	4	2	2	
Antimony	ppm	ASTM D5185(m)		0	0	<1	
Vanadium	ppm	ASTM D5185(m)		0	0	0	
Beryllium	ppm	ASTM D5185(m)		0	0	0	
Cadmium	ppm	ASTM D5185(m)		0	<1	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	mag	ASTM D5185(m)	1.0	د1	4	3	
Barium	ppm	ASTM D5185(m)	1.0	0	0	0	
Molvbdenum	maa	ASTM D5185(m)	1.0	0	<1	<1	
Manganese	maa	ASTM D5185(m)	1	<1	<1	<1	
Magnesium	maa	ASTM D5185(m)	15	<1	335	318	
Calcium	ppm	ASTM D5185(m)	2540	<u>^</u> 2	2124	2054	
Phosphorus	ppm	ASTM D5185(m)	1000	A 399	1044	1037	
Zinc	ppm	ASTM D5185(m)	1110	<u> </u>	1036	1017	
Sulfur	ppm	ASTM D5185(m)	3700	152	3403	3221	
Lithium	ppm	ASTM D5185(m)		<1	<1	<1	
CONTAMINANTS	S	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>25	4	8	6	
Sodium	ppm	ASTM D5185(m)	220	1	41	36	
Potassium	ppm	ASTM D5185(m)	>20	<1	1	2	
		mothod	limit/bass	ourropt	historyd	-	
FLOID GLEANLI	VESS		mm/base	current			
Particles >4µm		ASTM D7647	5000	196913	/8920	83240	
Particles >6µm		ASTM D7647	>5000	1 02589	A 14182	14040	
Particles >14µm		ASTM D/647	>640	411	384	445	
Particles >21µm		ASTM D7647	>160	38	87	127	
Particles >38µm		ASTM D/647	>40	1	3	6	
Particles >/1µm		ASTM D/64/	>10			0	
OII Cleanliness		ISO 4406 (c)	>/19/16	= 25/24/16	A 23/21/16	<u> </u>	



1.200

0k

👗 PQ

Severe 200

Abnor 100 50

250

150

0

1

maa

2

OIL ANALYSIS REPORT

Particle Trend	FLUID DEGRADA	TION	method	limit/ba
4μm 6μm 14μm	Acid Number (AN)	mg KOH/g	ASTM D974*	2.9
• • • • • • • • • • • • • • • •	VISUAL		method	limit/ba
	White Metal	scalar	Visual*	NONE
	Yellow Metal	scalar	Visual*	NONE
anthing	Precipitate	scalar	Visual*	NONE
6/11 //16 //16 //16 //16 //16 //18 //18	Silt	scalar	Visual*	NONE
May2) Jun23 Jun20eci4 Deci8 Jul5	Debris	scalar	Visual*	NONE
	Sand/Dirt	scalar	Visual*	NONE
PQ	Appearance	scalar	Visual*	NORML
Severe	Odor	scalar	Visual*	NORML
	Emulsified Water	scalar	Visual*	>0.1
	Free Water	scalar	Visual*	
Abnormal O	FLUID PROPERT	IES	method	limit/ba
	Visc @ 40°C	cSt	ASTM D7279(m)	83.2
Jun7/16 - Dec9/21 -	SAMPLE IMAGES	3	method	limit/ba
Aluminum (ppm)	Color			

Bottom



1.68

NONE

NONE

NONE

NONE

NONE

NONE

NORML

A WGOIL

.2%

1%

91.8

1.24

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

.2%

NEG

93.1

0.09

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

NEG

NEG

112

imit/base



Contact/Location: Chief Engineer - CCGSTEL