




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
KDAC
 Machine Id
200206
 Component
Diesel Engine
 Fluid
PETRO CANADA DURON SHP 10W30 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0852032	WC0814941	---
Sample Date	Client Info		16 Aug 2023	16 Aug 2023	---
Machine Age	kms	Client Info	183905	183904	---
Oil Age	kms	Client Info	0	64216	---
Oil Changed	Client Info		Not Chngd	Changed	---
Sample Status			NORMAL	NORMAL	---

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>3.0	<1.0	<1.0	---
Glycol	WC Method		NEG	NEG	---

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>90	2	19	---
Chromium	ppm	ASTM D5185(m)	>20	0	1	---
Nickel	ppm	ASTM D5185(m)	>2	0	<1	---
Titanium	ppm	ASTM D5185(m)	>2	0	<1	---
Silver	ppm	ASTM D5185(m)	>2	0	<1	---
Aluminum	ppm	ASTM D5185(m)	>20	1	10	---
Lead	ppm	ASTM D5185(m)	>40	0	2	---
Copper	ppm	ASTM D5185(m)	>330	<1	3	---
Tin	ppm	ASTM D5185(m)	>15	0	1	---
Antimony	ppm	ASTM D5185(m)		0	0	---
Vanadium	ppm	ASTM D5185(m)		0	0	---
Beryllium	ppm	ASTM D5185(m)		0	0	---
Cadmium	ppm	ASTM D5185(m)		0	0	---

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	2	6	4	---
Barium	ppm	ASTM D5185(m)	0	0	0	---
Molybdenum	ppm	ASTM D5185(m)	50	57	61	---
Manganese	ppm	ASTM D5185(m)	0	0	<1	---
Magnesium	ppm	ASTM D5185(m)	950	944	987	---
Calcium	ppm	ASTM D5185(m)	1050	1013	1085	---
Phosphorus	ppm	ASTM D5185(m)	995	1033	1038	---
Zinc	ppm	ASTM D5185(m)	1180	1149	1222	---
Sulfur	ppm	ASTM D5185(m)	2600	2587	2431	---
Lithium	ppm	ASTM D5185(m)		<1	<1	---

CONTAMINANTS



	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>25	4	7	---
Sodium	ppm	ASTM D5185(m)		1	2	---
Potassium	ppm	ASTM D5185(m)	>20	2	26	---

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*	>6	0	0.2	---
Nitration	Abs/cm	ASTM D7624*	>20	4.7	8.6	---
Sulfation	Abs./1mm	ASTM D7415*	>30	18.7	21.6	---



OIL ANALYSIS REPORT











FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	12.9	16.7	---
Base Number (BN)	mg KOH/g	ASTM D2896*		9.32	7.98	---

VISUAL		method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	---
Free Water	scalar	Visual*		NEG	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	12.00	11.7	11.2	---

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0852032 **Received** : 28 Aug 2023
Lab Number : **02578585** **Diagnosed** : 29 Aug 2023
Unique Number : 5631645 **Diagnostician** : Wes Davis
Test Package : MOB 2

WFR Technical Services
 5389 Riverside Drive
 Burlington, ON
 CA L7L 3Y1
 Contact: William Ridley
 wfr.technical.services@gmail.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
F: