


PROBLEM SUMMARY

Area
TCP Ch#1 [2304251382]
 Machine Id
MCQUAY STNU060300231
 Component
Chiller
 Fluid
MOBIL EAL ARTIC ISO 46 (--- GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				MARGINAL	MARGINAL	NORMAL
Copper	ppm	ASTM D5185(m)	>100	▲ 21	▲ 26.0	12.0

Customer Id: GTT0000352
 Sample No.: GTT0000030
 Lab Number: 02578771
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Bill Quesnel CLS,OMA II,MLA-III,LLA-I +1
 (289)291-4641 x4641
Bill.Quesnel@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

06 Sep 2022 Diag: Wes Davis

WEAR



The elevated copper reading indicates the effects of oil migration through the evaporator (oil loss from the compressor) possibly occurring during intervals of operation at low cooling load conditions. All other readings are in normal ranges.

[view report](#)



23 Sep 2020 Diag: Wes Davis

NORMAL



The test results indicate normal wear patterns for this type of unit with moisture and acidity in the acceptable range. The elevated moisture is associated with synthetic oils.

[view report](#)



22 Oct 2019 Diag: Wes Davis

NORMAL




The test results indicate normal wear patterns for this type of unit with the moisture and acidity also in the acceptable range.

[view report](#)



Area
TCP Ch#1 [2304251382]
 Machine Id
MCQUAY STNU060300231
 Component
Chiller
 Fluid
MOBIL EAL ARTIC ISO 46 (--- GAL)



DIAGNOSIS

Recommendation
 Resample at the next service interval to monitor.

Wear
 Copper ppm levels are marginal. The elevated copper reading indicates the effects of oil migration through the evaporator (oil loss from the compressor) possibly occurring during intervals of operation at low cooling load conditions. All other readings are in normal ranges.

Contamination
 There is no indication of any contamination in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		GTT0000030	GTT72757	GTT72758
Sample Date	Client Info		28 Jul 2023	06 Sep 2022	23 Sep 2020
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			MARGINAL	MARGINAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	---	---
Iron	ppm	ASTM D5185(m) >100	7.1	4.6	3.0
Chromium	ppm	ASTM D5185(m) >2	0.0	0.1	0.1
Nickel	ppm	ASTM D5185(m)	0.9	---	---
Titanium	ppm	ASTM D5185(m)	0.0	---	---
Silver	ppm	ASTM D5185(m) >2	0.0	---	---
Aluminum	ppm	ASTM D5185(m) >50	1.4	0.1	0.1
Lead	ppm	ASTM D5185(m) >2	1.0	0.1	0.1
Copper	ppm	ASTM D5185(m) >100	▲ 21	▲ 26.0	12.0
Tin	ppm	ASTM D5185(m) >4	1.2	0.1	0.1
Antimony	ppm	ASTM D5185(m)	0.0	---	---
Vanadium	ppm	ASTM D5185(m)	0.0	---	---
Beryllium	ppm	ASTM D5185(m)	0.0	---	---
Cadmium	ppm	ASTM D5185(m)	0.0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0.8	---	---
Barium	ppm	ASTM D5185(m)	0.0	---	---
Molybdenum	ppm	ASTM D5185(m)	0.0	---	---
Manganese	ppm	ASTM D5185(m)	0.5	---	---
Magnesium	ppm	ASTM D5185(m)	0.0	---	---
Calcium	ppm	ASTM D5185(m)	0.4	---	---
Phosphorus	ppm	ASTM D5185(m)	8.9	---	---
Zinc	ppm	ASTM D5185(m)	27	13.1	12.9
Sulfur	ppm	ASTM D5185(m)	51	---	---
Lithium	ppm	ASTM D5185(m)	0.3	---	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	5.6	---	---
Sodium	ppm	ASTM D5185(m)	1.5	---	---
Potassium	ppm	ASTM D5185(m) >20	1.0	---	---
Water	%	ASTM D6304* >0.01	0.061	---	---
ppm Water	ppm	ASTM D6304* >100	613.1	69	124

FLUID DEGRADATION



	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.1	0.08	0.071	0.060

OIL ANALYSIS REPORT

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	---
Odor	scalar	Visual*	NORML	FREON	---
Emulsified Water	scalar	Visual*	>0.01	NEG	---
Free Water	scalar	Visual*		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	49.2	38.2	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color					no image	no image
Bottom					no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : GTT0000030 **Received** : 28 Aug 2023
Lab Number : **02578771** **Diagnosed** : 01 Sep 2023
Unique Number : 5631831 **Diagnostician** : Bill Quesnel
Test Package : IND 2 (Additional Tests: KF, TAN Man)

Daikin Applied Canada Inc.
 8-641 Chrislea Road
 Vaughan, ON
 CA L4L 8A3
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
F: