



OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
Borden Ch#2
 Machine Id
YORK 2GYM017121(2)
 Component
Chiller
 Fluid
YORK TYPE L (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		GTT0000029	---	---
Sample Date	Client Info		02 Jun 2023	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			NORMAL	---	---

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	---	---
Iron	ppm	ASTM D5185(m) >8	0.0	---	---
Chromium	ppm	ASTM D5185(m) >2	0.0	---	---
Nickel	ppm	ASTM D5185(m)	0.2	---	---
Titanium	ppm	ASTM D5185(m)	0.0	---	---
Silver	ppm	ASTM D5185(m) >2	0.0	---	---
Aluminum	ppm	ASTM D5185(m) >3	0.0	---	---
Lead	ppm	ASTM D5185(m) >2	0.0	---	---
Copper	ppm	ASTM D5185(m) >8	0.5	---	---
Tin	ppm	ASTM D5185(m) >4	0.0	---	---
Antimony	ppm	ASTM D5185(m)	0.0	---	---
Vanadium	ppm	ASTM D5185(m)	0.0	---	---
Beryllium	ppm	ASTM D5185(m)	0.0	---	---
Cadmium	ppm	ASTM D5185(m)	0.0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0.4	---	---
Barium	ppm	ASTM D5185(m)	0.0	---	---
Molybdenum	ppm	ASTM D5185(m)	0.0	---	---
Manganese	ppm	ASTM D5185(m)	0.0	---	---
Magnesium	ppm	ASTM D5185(m)	0.0	---	---
Calcium	ppm	ASTM D5185(m)	0.1	---	---
Phosphorus	ppm	ASTM D5185(m)	0.2	---	---
Zinc	ppm	ASTM D5185(m)	1.4	---	---
Sulfur	ppm	ASTM D5185(m)	12	---	---
Lithium	ppm	ASTM D5185(m)	0.4	---	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	11	---	---
Sodium	ppm	ASTM D5185(m)	0.2	---	---
Potassium	ppm	ASTM D5185(m) >20	0.5	---	---
Water	%	ASTM D6304* >0.01	0.054	---	---
ppm Water	ppm	ASTM D6304* >100	545.9	---	---

FLUID DEGRADATION



	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.05	---	---

OIL ANALYSIS REPORT

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Precipitate	scalar	Visual*	NONE	NONE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	FREON	---	---
Emulsified Water	scalar	Visual*	>0.01	NEG	---	---
Free Water	scalar	Visual*		NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	100	73.7	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color					no image	no image
Bottom					no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : GTT0000029 **Received** : 28 Aug 2023
Lab Number : 02578772 **Diagnosed** : 01 Sep 2023
Unique Number : 5631832 **Diagnostician** : Bill Quesnel
Test Package : IND 2 (Additional Tests: KF, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

Dexterra
 425-5915 Airport Rd
 Mississauga, ON
 CA L4V 1T1
 Contact: Service Manager
 accountspayable@dexterra.com
 T:
 F: