




# PROBLEM SUMMARY

Area  
**SAB1**  
 Machine Id  
**SAB1 G5**  
 Component  
**Thrust Bearing**  
 Fluid  
**PETRO CANADA TURBOFLO XL46 (1182 LTR)**

Sample Rating Trend




**VISUAL METAL**



## COMPONENT CONDITION SUMMARY

▲ Particle Trend




## RECOMMENDATION

We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>1300		▲ <b>1529</b>	689	412
Oil Cleanliness	ISO 4406 (c)	>17/15/12		▲ <b>18/15/10</b>	17/15/11	16/14/11
White Metal	scalar	Visual*	NONE	▲ <b>LIGHT</b>	NONE	NONE

PrtFilter



Customer Id: ONTQUE  
 Sample No.: WC0828620  
 Lab Number: 02578778  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.

## HISTORICAL DIAGNOSIS

### 27 Mar 2023 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Component wear rates appear to be normal (unconfirmed). The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 21 Nov 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 27 Sep 2022 Diag: Kevin Marson

VISUAL METAL



We advise that you check for visible metal particles in the oil. We recommend an early resample to monitor this condition. Light concentration of visible metal present. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

VISUAL METAL

Area  
**SAB1**  
 Machine Id  
**SAB1 G5**  
 Component  
**Thrust Bearing**  
 Fluid  
**PETRO CANADA TURBOFLO XL46 (1182 LTR)**



## DIAGNOSIS

### Recommendation

We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

### Wear

Light concentration of visible metal present.

### Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>WC0828620</b>	WC0642872	WC0587299
Sample Date	Client Info	<b>27 Aug 2023</b>	27 Mar 2023	21 Nov 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >85	<1	<1
Chromium	ppm	ASTM D5185(m) >20	0	0
Nickel	ppm	ASTM D5185(m) >20	<1	0
Titanium	ppm	ASTM D5185(m)	0	0
Silver	ppm	ASTM D5185(m)	0	0
Aluminum	ppm	ASTM D5185(m) >40	<1	0
Lead	ppm	ASTM D5185(m) >60	<1	<1
Copper	ppm	ASTM D5185(m) >7	<1	<1
Tin	ppm	ASTM D5185(m) >40	0	0
Antimony	ppm	ASTM D5185(m)	0	<1
Vanadium	ppm	ASTM D5185(m)	0	0
Beryllium	ppm	ASTM D5185(m)	0	0
Cadmium	ppm	ASTM D5185(m)	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1
Barium	ppm	ASTM D5185(m)	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0
Manganese	ppm	ASTM D5185(m)	0	0
Magnesium	ppm	ASTM D5185(m)	0	0
Calcium	ppm	ASTM D5185(m)	<1	0
Phosphorus	ppm	ASTM D5185(m)	2	1
Zinc	ppm	ASTM D5185(m) 0	2	1
Sulfur	ppm	ASTM D5185(m)	657	651
Lithium	ppm	ASTM D5185(m)	<1	<1

## CONTAMINANTS


method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >20	5	5
Sodium	ppm	ASTM D5185(m)	0	<1
Potassium	ppm	ASTM D5185(m) >20	<1	0

## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >1300	▲ <b>1529</b>	689	412
Particles >6µm	ASTM D7647 >320	<b>270</b>	168	111
Particles >14µm	ASTM D7647 >40	<b>8</b>	13	11
Particles >21µm	ASTM D7647 >10	<b>2</b>	3	4
Particles >38µm	ASTM D7647 >3	<b>0</b>	0	1
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >17/15/12	▲ <b>18/15/10</b>	17/15/11	16/14/11





## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974* 0.04	<b>0.08</b>	0.05





# OIL ANALYSIS REPORT



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0828620 **Received** : 28 Aug 2023  
**Lab Number** : 02578778 **Diagnosed** : 30 Aug 2023  
**Unique Number** : 5631838 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: BottomAnalysis, FilterPatch, PrtFilter, TAN Man )


**Ontario Power Generation**  
 NIAGARA PLANT GROUP, 14000 NIAGARA PKWY  
 NIAGARA ON THE LAKE, ON  
 CA L0S 1J0  
 Contact: Michael Brochu  
 mike.brochu@opg.com  
 T: (905)357-0322  
 F: (905)374-5466

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	▲ LIGHT	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46.39	45.4	45.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS

