




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**NOVA BUS 1633**

Component  
**Natural Gas Engine**

Fluid  
**VALVOLINE PREMIUM BLUE 9200 15W40 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

Elevated aluminum (Al) and/or lead (Pb) and potassium (K) levels in your metals analysis are likely a result of solder flux release into the lubricant and is common on new equipment/components. There is no indication of any contamination in the oil.

### Fluid Condition

The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0849881</b>	WC0811481	WC0748319
Sample Date	Client Info		<b>25 Aug 2023</b>	29 May 2023	17 Feb 2023
Machine Age	kms	Client Info	<b>0</b>	425146	405368
Oil Age	kms	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Glycol	WC Method		---	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >50	<b>15</b>	12	9
Chromium	ppm	ASTM D5185(m) >4	<b>1</b>	1	<1
Nickel	ppm	ASTM D5185(m) >2	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185(m)	<b>&lt;1</b>	1	3
Silver	ppm	ASTM D5185(m) >3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185(m) >9	<b>2</b>	2	2
Lead	ppm	ASTM D5185(m) >30	<b>9</b>	7	2
Copper	ppm	ASTM D5185(m) >35	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185(m) >4	<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185(m)	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<b>5</b>	8	15
Barium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185(m)	<b>53</b>	55	51
Manganese	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)	<b>884</b>	880	813
Calcium	ppm	ASTM D5185(m)	<b>1294</b>	1364	1316
Phosphorus	ppm	ASTM D5185(m)	<b>748</b>	756	739
Zinc	ppm	ASTM D5185(m)	<b>913</b>	905	856
Sulfur	ppm	ASTM D5185(m)	<b>1953</b>	1978	1967
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >+100	<b>6</b>	5	5
Sodium	ppm	ASTM D5185(m)	<b>5</b>	4	5
Potassium	ppm	ASTM D5185(m) >20	<b>6</b>	6	6

## INFRA-RED



	method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624* >20	<b>13.9</b>	13.4	6.0
Sulfation	Abs/.1mm	ASTM D7415* >30	<b>26.9</b>	25.5	17.2

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414* >25	<b>23.5</b>	23.1	9.8











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	Visual*	>0.1	<b>NEG</b>	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	114	<b>117</b>	---
Visc @ 100°C	cSt	ASTM D7279(m)	14.8	<b>14.8</b>	14.7
Viscosity Index (VI)	Scale	ASTM D2270*	133	<b>129</b>	---

## GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0849881 **Received** : 30 Aug 2023  
**Lab Number** : 02579288 **Diagnosed** : 30 Aug 2023  
**Unique Number** : 5632348 **Diagnostician** : Kevin Marson  
**Test Package** : MOB 1 ( Additional Tests: KV40, VI, Visual )

**CITY OF HAMILTON**  
 2200 UPPER JAMES., MOUNTAIN TRANSIT STOREROOM  
 MOUNT HOPE, ON  
 CA L0R 1W0  
 Contact: Jeff Parr  
 jeff.parr@hamilton.ca  
 T: (905)546-2424  
 F: (905)679-4502

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.