

## **OIL ANALYSIS REPORT**

Sample Rating Trend





## Component Blower

Fluid

## PETRO CANADA SYNDURO SHB ISO 220 (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0744977		
Sample Date		Client Info		24 Aug 2023		
Machine Age	hrs	Client Info		1861		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>20	3		
Chromium	ppm	ASTM D5185(m)	>20	0		
Nickel	ppm	ASTM D5185(m)	>20	<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>20	<1		
Lead	ppm	ASTM D5185(m)	>20	0		
Copper	ppm	ASTM D5185(m)	>20	<1		
Tin	ppm	ASTM D5185(m)	>20	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1		
Barium	ppm	ASTM D5185(m)	50	0		
Molybdenum	ppm	ASTM D5185(m)	0.0	0		
Manganese	ppm	ASTM D5185(m)		<1		
Magnesium	ppm	ASTM D5185(m)	5.0	<1		
Calcium	ppm	ASTM D5185(m)	5.0	<1		
Phosphorus	ppm	ASTM D5185(m)	100	126		
Zinc	ppm	ASTM D5185(m)	5.0	3		
Sulfur		ASTM D5185(m)	1900	1910		
Lithium	ppm	ASTM D5185(m)	1900	<1		
	ppm	ASTIVI D3103(III)		<1 <1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	2		
Sodium	ppm	ASTM D5185(m)		<1		
Potassium	ppm	ASTM D5185(m)	>20	<1		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	VLITE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		
Emulsified Water	scalar	Visual*		NEG		
Free Water	scalar	Visual*		NEG		
3:36:16) Rev: 1					cation: Jon Burg	



# **OIL ANALYSIS REPORT**



с	FLUID PROPER	RTIES me	thod limit/bas	se current	history1	history2
	Visc @ 40°C	cSt ASTM	D7279(m) 219	215		
	SAMPLE IMAG	ES me	thod limit/bas	se current	history1	history2
23+	Color				no image	no image
Aug24/23	Bottom				no image	no image
	GRAPHS					
E	Iron (ppm) <sup>60</sup> <sup>50</sup> <sup>40</sup> <sup>30</sup>			Lead (ppm)		
	20 Abnormal		Aug24/23	20 - Abnormal		Aug24/23
	Aluminum (ppm	)	Aut	Chromium (pp	m)	Auc
E	30 20 <b>Abnormal</b>			E 30 20 Abnormal		
	Copper (ppm)		Aug24/23	Silicon (ppm)		Aug24/23
Ē	50 - Severe 40 30 - Abnormal			50 - Severe 40 - E 30 - 20 - Abnormal		
	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		Aug24/23	200 Abnormal		Aug24/23
2	Viscosity @ 40°C	C		Additives		
	220 Base 210 Abnomal			50 0		
	Aug24/23		Aug24/23	Aug24/23		Aug24/23
	: WearCheck - C8-1 : WC0744977 : 02579413 : 5632473 : MOB 1	Received Diagnosed Diagnostician	: 30 Aug 2023 : 30 Aug 2023 : Wes Davis		466	FLEET CARE HIGHWAY 52 DUNDAS, ON CA L9H 5E2 ot: Jon Burgess
Test denoted (*) outside scope of Validity of results and interpretat	of accreditation, (m)	method modified	l, (e) tested at ex	ternal lab.	າ.ວບາ <del>ງເ</del> ວວ(ຫປ <sup>ູ</sup> X-1	T: F: