



PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY

Area

5

Machine Id


5-3-230-D Pump Station for Atox Roller Lube

Component

Reservoir Bearing Lube


Fluid

MOBIL SHC 639 (1000 LTR)



COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Visc @ 40°C	cSt	ASTM D7279(m)	923 ▲ 529	541 ▲	560 ▲

Customer Id: STMBOW
 Sample No.: WC0851475
 Lab Number: 02579506
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

21 Aug 2023 Diag: Kevin Marson

VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. Viscosity of sample indicates oil is within ISO 460 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



14 Aug 2023 Diag: Kevin Marson

VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



08 Aug 2023 Diag: Kevin Marson

VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The oil viscosity is lower than typical, possibly indicating the addition of lighter grade oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





OIL ANALYSIS REPORT

Sample Rating Trend

VISCOSITY

Area

5

Machine Id


5-3-230-D Pump Station for Atox Roller Lube

Component

Reservoir Bearing Lube

Fluid

MOBIL SHC 639 (1000 LTR)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

Viscosity of sample indicates oil is within ISO 460 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0851475	WC0842790	WC0842788
Sample Date	Client Info		28 Aug 2023	21 Aug 2023	14 Aug 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>120	1	1
Chromium	ppm	ASTM D5185(m)	>5	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	0
Titanium	ppm	ASTM D5185(m)		0	0
Silver	ppm	ASTM D5185(m)		0	0
Aluminum	ppm	ASTM D5185(m)	>4	<1	<1
Lead	ppm	ASTM D5185(m)	>30	0	0
Copper	ppm	ASTM D5185(m)	>17	<1	<1
Tin	ppm	ASTM D5185(m)	>10	0	0
Antimony	ppm	ASTM D5185(m)		0	0
Vanadium	ppm	ASTM D5185(m)		0	0
Beryllium	ppm	ASTM D5185(m)		0	0
Cadmium	ppm	ASTM D5185(m)		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0.2	<1	<1
Barium	ppm	ASTM D5185(m)	0.0	0	0
Molybdenum	ppm	ASTM D5185(m)	0.0	0	0
Manganese	ppm	ASTM D5185(m)	0.0	0	0
Magnesium	ppm	ASTM D5185(m)	0.6	<1	0
Calcium	ppm	ASTM D5185(m)	0.0	<1	2
Phosphorus	ppm	ASTM D5185(m)	691	375	387
Zinc	ppm	ASTM D5185(m)	2.0	2	2
Sulfur	ppm	ASTM D5185(m)	18	294	165
Lithium	ppm	ASTM D5185(m)		<1	<1

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	12	12
Sodium	ppm	ASTM D5185(m)		<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<1	<1

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		103695	103486	89389
Particles >6µm	ASTM D7647	>320000	29177	24716	24670
Particles >14µm	ASTM D7647	>160000	435	367	376
Particles >21µm	ASTM D7647	>40000	45	43	43
Particles >38µm	ASTM D7647	>10000	1	1	2
Particles >71µm	ASTM D7647	>2500	0	0	0
Oil Cleanliness	ISO 4406 (c)	>25/24	22/16	22/16	22/16

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.32	0.35	0.37







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	923 ▲ 529	▲ 541	▲ 560

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0851475 **Received** : 30 Aug 2023
Lab Number : 02579506 **Diagnosed** : 31 Aug 2023
Unique Number : 5632566 **Diagnostician** : Kevin Marson
Test Package : IND 2

ST. MARYS CEMENT CO.
 400 BOWMANVILLE AVENUE
 BOWMANVILLE, ON
 CA L1C 7B5
 Contact: Aleksandrs Cascins
 Alex.Cascins@vcimentos.com
 T: (905)623-3341
 F: (905)623-4695

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.