




PROBLEM SUMMARY

Sample Rating Trend





VISCOSITY



Area
SAB2
 Machine Id
South Crane Trolley
 Component
Gearbox
 Fluid
ESSO SPARTAN EP 320 (--- LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	SEVERE
Particles >4µm	ASTM D7647	>20000	▲ 48654	▲ 82123	● 199632
Particles >6µm	ASTM D7647	>5000	▲ 6268	▲ 9658	● 68734
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 23/20/15	▲ 24/20/14	● 25/23/17
Visc @ 40°C	cSt	ASTM D7279(m) 320	▲ 222	▲ 222	304

Customer Id: ONTQUE
 Sample No.: WC0565995
 Lab Number: 02579811
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

HISTORICAL DIAGNOSIS

01 Aug 2018 Diag: Bill Quesnel

VISCOSITY



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. Particles >4µm are abnormally high. Particles >6µm are notably high. Viscosity of sample indicates oil is within ISO 220 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



04 Jan 2016 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Lead ppm levels are noted. All other component wear rates are normal. Particles >6µm are severely high. Particles >4µm are severely high. Particles >14µm are notably high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



05 Jan 2010 Diag:

WEAR



Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Cleanliness target codes are in part dependent on the system filter micron ratings. Please provide the micron rating of the filters in this system for future samples. All component wear rates are normal. A decrease in the lead level is noted. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The condition of the oil is acceptable for the time in service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Area
SAB2
 Machine Id
South Crane Trolley
 Component
Gearbox
 Fluid
ESSO SPARTAN EP 320 (--- LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

Viscosity of sample indicates oil is within ISO 220 range, advise investigate. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0565995	WC02238638	WC
Sample Date	Client Info		30 Aug 2023	01 Aug 2018	04 Jan 2016
Machine Age	yrs	Client Info	0	0	0
Oil Age	yrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	---	---
Iron	ppm	ASTM D5185(m) >200	6	5	26
Chromium	ppm	ASTM D5185(m) >15	0	0	0
Nickel	ppm	ASTM D5185(m) >15	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	0	0	0
Aluminum	ppm	ASTM D5185(m) >25	0	0	<1
Lead	ppm	ASTM D5185(m) >100	30	40	▲ 401
Copper	ppm	ASTM D5185(m) >200	<1	0	<1
Tin	ppm	ASTM D5185(m) >25	0	0	0
Antimony	ppm	ASTM D5185(m) >5	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) .4	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	0	<1
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	<1	<1
Magnesium	ppm	ASTM D5185(m) 0	<1	<1	<1
Calcium	ppm	ASTM D5185(m) 0	<1	<1	<1
Phosphorus	ppm	ASTM D5185(m) 250	389	402	305
Zinc	ppm	ASTM D5185(m) 0	3	2	4
Sulfur	ppm	ASTM D5185(m)	2058	2155	6343
Lithium	ppm	ASTM D5185(m)	<1	0	<1

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	19	21	6
Sodium	ppm	ASTM D5185(m)	<1	0	2
Potassium	ppm	ASTM D5185(m) >20	0	0	<1

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 48654	▲ 82123	● 199632
Particles >6µm	ASTM D7647	>5000	▲ 6268	▲ 9658	● 68734
Particles >14µm	ASTM D7647	>640	187	151	▲ 1275
Particles >21µm	ASTM D7647	>160	31	22	224
Particles >38µm	ASTM D7647	>40	7	0	10
Particles >71µm	ASTM D7647	>10	6	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 23/20/15	▲ 24/20/14	● 25/23/17



OIL ANALYSIS REPORT



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0565995 **Received** : 31 Aug 2023
Lab Number : 02579811 **Diagnosed** : 05 Sep 2023
Unique Number : 5632871 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: PQ, PrtCount)

Ontario Power Generation
 NIAGARA PLANT GROUP., 14000 NIAGARA PKWY
 NIAGARA ON THE LAKE, ON
 CA L0S 1J0
 Contact: Michael Brochu
 mike.brochu@opg.com
 T: (905)357-0322
 F: (905)374-5466

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.75	0.90	0.915	1.36

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	NONE	VLITE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	VLITE
Debris	scalar	Visual*	NONE	VLITE	VLITE	LIGHT
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	320	▲ 222	▲ 222	304

SAMPLE IMAGES	method	limit/base	current	history1	history2	
Color						
Bottom						
PrtFilter				no image	no image	no image