

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

HOFFMAN ABL #1 DE (S/N 1277047)

Blower Fluid

PETRO CANADA TURBOFLO R&O 46 (1 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The oil viscosity is higher than typical. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0802929		
Sample Date		Client Info		15 Aug 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*		0		
Iron	ppm	ASTM D5185(m)	>20	1		
Chromium	ppm	ASTM D5185(m)	>20	0		
Nickel	ppm	ASTM D5185(m)	>20	<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)		0		
Aluminum	ppm	ASTM D5185(m)	>20	<1		
Lead	ppm	ASTM D5185(m)	>20	0		
Copper	ppm	ASTM D5185(m)	>20	<1		
Tin	ppm	ASTM D5185(m)	>20	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		0		
Barium	ppm	ASTM D5185(m)		0		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		<1		
Calcium	ppm	ASTM D5185(m)	0	<1		
Phosphorus	ppm	ASTM D5185(m)	3	19		
Zinc	ppm	ASTM D5185(m)	0	3		
Sulfur	ppm	ASTM D5185(m)		116		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	0		
Sodium	ppm	ASTM D5185(m)		<1		
Potassium	ppm	ASTM D5185(m)	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.12	0.07		



OIL ANALYSIS REPORT



VISUAL		method				history2	
White Metal	scalar \	/isual*	NONE	NONE			
Yellow Metal	scalar \	/isual*	NONE	NONE			
Precipitate	scalar \	/isual*	NONE	NONE			
Silt	scalar \	/isual*	NONE	NONE			
Debris	scalar \	/isual*	NONE	VLITE			
Sand/Dirt	scalar \	/isual*	NONE	NONE			
Appearance	scalar \	/isual*	NORML	NORML			
Odor	scalar \	/isual*	NORML	NORML			
Emulsified Water	scalar \	/isual*		NEG			
Free Water	scalar \	/isual*		NEG			
FLUID PROPERT	IES	method	limit/base	curren	t history1	history2	
Visc @ 40°C	cSt A	STM D7279(m)	44.4	54.4			
SAMPLE IMAGES	3	method	limit/base	curren	t history1	history2	
Color					no image	no image	
Bottom				Ø	no image	no image	
GRAPHS							
Ferrous Alloys				PQ			
iron			220	Sama			
G- nickel			200	- 0			
1			180	•			
2-			160	+			
		**************	140 \$3	•			
Aug 15/23			Aug15/23	+			
√ Non-ferrous Metals	_		PR 24	Abnormal			
Non-rerrous Metais	5						
copper			60				
6 tin							
1			40				
2			20	•			
			53				
Aug15/23			Aug15/23	Aug 15/23		C L V	
⊲ Viscosity @ 40°C			4		bor		
60 T					Acid Number		
5-			KOH/g	Base		*****	
- Abnormal 5 - Base			B0.10	1			
Abnormal			ی 50.0 ا				
Abnormal			0.10 HOX Numper 0.00 Voruge				
51 22			0.00	5/23		ç	
Aug15/23			Aug 15/23	Aug15/			
02580017	Received Diagnosed Diagnostic	:01 \$ I :05 \$ ian :Kev 0-268-2131	Sep 2023 Sep 2023 rin Marson		Conta		

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

CALA

ISO 17025:2017 Accredited Laboratory

£

Laboratory

Sample No.

Lab Number

Unique Number Test Package

Contact/Location: Allison Neal - PNESTO

F: (905)662-1766