



OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

1B

Component

Unknown Component

Fluid

PETRO CANADA TURBOFLO XL46 (--- GAL)

DIAGNOSIS

Recommendation

This is a baseline read-out on the submitted sample.

Wear

{not applicable}

Contamination

{not applicable}

Fluid Condition

{not applicable}

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PP	---	---
Sample Date	Client Info		31 Aug 2023	---	---
Machine Age	hrs	Client Info	0	---	---
Oil Age	hrs	Client Info	0	---	---
Oil Changed	Client Info		N/A	---	---
Sample Status			NORMAL	---	---

FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	737	---	---
Particles >6µm	ASTM D7647	>1300	205	---	---
Particles >14µm	ASTM D7647	>160	14	---	---
Particles >21µm	ASTM D7647	>40	4	---	---
Particles >38µm	ASTM D7647	>10	0	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	17/15/11	---	---

SAMPLE IMAGES




	method	limit/base	current	history1	history2
Color				<i>no image</i>	<i>no image</i>
Bottom				<i>no image</i>	<i>no image</i>



OIL ANALYSIS REPORT



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : PP **Received** : 01 Sep 2023
Lab Number : 02580145 **Diagnosed** : 01 Sep 2023
Unique Number : 5633205 **Diagnostician** : Bill Quesnel
Test Package : TEST (Additional Tests: PrtCount)

ANDRITZ HYDRO
 6100 AUT TRANSCANADIENNE
 POINT CLAIRE, QC
 CA H9R 1B9
 Contact: Guy Cauchon
 guy.cauchon@andritz.com

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

T:
F: