




PROBLEM SUMMARY

Area
STARBOARD CRANE
 Machine Id
58-T-7645 STARBOARD CRANE HYDRAULIC TANK (S/N Maint Plan 28275)
 Component
Hydraulic System
 Fluid
ESSO UNIVIS N 46 (800 LTR)

Sample Rating Trend




VISUAL METAL



COMPONENT CONDITION SUMMARY


▲ Particle Trend



RECOMMENDATION

We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	ATTENTION
Particles >6µm	ASTM D7647	>2500	▲ 8406	1979	▲ 3144	
Particles >14µm	ASTM D7647	>320	▲ 506	145	246	
Particles >21µm	ASTM D7647	>80	▲ 113	34	59	
Oil Cleanliness	ISO 4406 (c)	>--/18/15	▲ 22/20/16	20/18/14	▲ 21/19/15	
White Metal	scalar	Visual*	● LIGHT	NONE	NONE	
PrtFilter				no image	no image	

Customer Id: SPESTJ
 Sample No.: WC0711696
 Lab Number: 02580361
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF).
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using IND 3 test kits,
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.

HISTORICAL DIAGNOSIS

15 May 2022 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



18 Jan 2022 Diag: Wes Davis

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



19 Oct 2021 Diag: Wes Davis

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

VISUAL METAL

Area
STARBOARD CRANE
 Machine Id
58-T-7645 STARBOARD CRANE HYDRAULIC TANK (S/N Maint Plan 28275)
 Component
Hydraulic System
 Fluid
ESSO UNIVIS N 46 (800 LTR)



DIAGNOSIS

Recommendation

We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. Re-sampling is suggested to confirm test results prior to significant maintenance activities being performed. Please indicate that this is a resample on your Sample Information Form (SIF). We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using IND 3 test kits, this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid.

Wear

Light concentration of visible metal present. Cutting wear particles are caused by either hard protuberances (mis-aligned components, etc.), or abrasives entering the system and embedding themselves in softer materials (sand, etc.), and gouging out mating surfaces.


Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

Particle Filter (Magn: 200 x)



SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0711696	WC0590078	WC0590079
Sample Date	Client Info	03 Aug 2023	15 May 2022	18 Jan 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	NORMAL	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m) >20	<1	<1
Chromium	ppm	ASTM D5185(m) >10	0	0
Nickel	ppm	ASTM D5185(m) >10	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0
Silver	ppm	ASTM D5185(m)	0	0
Aluminum	ppm	ASTM D5185(m) >10	0	<1
Lead	ppm	ASTM D5185(m) >20	<1	<1
Copper	ppm	ASTM D5185(m) >20	3	4
Tin	ppm	ASTM D5185(m) >10	0	0
Antimony	ppm	ASTM D5185(m)	0	<1
Vanadium	ppm	ASTM D5185(m)	0	0
Beryllium	ppm	ASTM D5185(m)	0	0
Cadmium	ppm	ASTM D5185(m)	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1
Barium	ppm	ASTM D5185(m)	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0
Manganese	ppm	ASTM D5185(m)	0	0
Magnesium	ppm	ASTM D5185(m)	<1	0
Calcium	ppm	ASTM D5185(m)	29	28
Phosphorus	ppm	ASTM D5185(m)	348	341
Zinc	ppm	ASTM D5185(m)	417	432
Sulfur	ppm	ASTM D5185(m)	1066	1075
Lithium	ppm	ASTM D5185(m)	<1	<1

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	<1	1
Sodium	ppm	ASTM D5185(m)	<1	<1
Potassium	ppm	ASTM D5185(m) >20	<1	<1





FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	26456	7241	13194
Particles >6µm	ASTM D7647 >2500	8406	1979	3144
Particles >14µm	ASTM D7647 >320	506	145	246
Particles >21µm	ASTM D7647 >80	113	34	59
Particles >38µm	ASTM D7647 >20	3	0	3
Particles >71µm	ASTM D7647 >4	0	0	0
Oil Cleanliness	ISO 4406 (c) >--/18/15	22/20/16	20/18/14	21/19/15

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.46	0.37
				0.48

OIL ANALYSIS REPORT




Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 HUSKY SEA ROSE /AKER SOLUTIONS
Sample No. : WC0711696 **Received** : 05 Sep 2023 PO BOX 20
Lab Number : 02580361 **Diagnosed** : 08 Sep 2023 ST. JOHN'S, NL
Unique Number : 5633421 **Diagnostician** : Kevin Marson CA A1C 6C9
Test Package : IND 2 (Additional Tests: Bottom, BottomAnalysis, FilterPatch, PrtFilter) Contact: Maintenance Supervisor
 To discuss this sample report, contact Customer Service at 1-800-268-2131. maintsuper.searose@huskyenergy.ca
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. T: x:
 Validity of results and interpretation are based on the sample and information as supplied. F: x:

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	🔴 LIGHT	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	46	43.7	44.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS

