

# **OIL ANALYSIS REPORT**

Area [4229]
Machine Id 09-033-CD

New (Unused) Oil

PETRO CANADA LUMINOL TRI (--- GAL)

# Sample Rating Trend



### DIAGNOSIS

### Recommendation

This is a baseline read-out on the submitted sample.

### Wear

{not applicable}

### Contamination

{not applicable}


## **Fluid Condition**

Pour Point = -60°C.

				Sep2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PP0000777		
Sample Date		Client Info		27 Sep 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>5	0		
Chromium	ppm	ASTM D5185(m)	>5	0		
Nickel	ppm	ASTM D5185(m)	>5	<1		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>5	0		
Aluminum	ppm	ASTM D5185(m)	>5	0		
Lead	ppm	ASTM D5185(m)	>5	0		
Copper	ppm	ASTM D5185(m)	>5	0		
Tin	ppm	ASTM D5185(m)	>5	0		
Antimony	ppm	ASTM D5185(m)		0		
Vanadium	ppm	ASTM D5185(m)		0		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1		
Barium	ppm	ASTM D5185(m)	0	<1		
Molybdenum	ppm	ASTM D5185(m)	0	0		
Manganese	ppm	ASTM D5185(m)	0	0		
Magnesium	ppm	ASTM D5185(m)	0	0		
Calcium	ppm	ASTM D5185(m)	0	0		
Phosphorus	ppm	ASTM D5185(m)	0	0		
Zinc	ppm	ASTM D5185(m)	0	0		
Sulfur	ppm	ASTM D5185(m)	10	0		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	0		
Sodium	ppm	ASTM D5185(m)	>5	0		
Potassium	ppm	ASTM D5185(m)	>20	<1		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		



# **OIL ANALYSIS REPORT**





**CALA** ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5655060

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9

: PP0000777 : 02585994

Received Diagnosed : 28 Sep 2023

: 28 Sep 2023 Diagnostician : Kevin Marson

Test Package : TEST ( Additional Tests: ICP, PourPt, Visual )

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

**Oleo Energies** 5800 Thorold Stone Road Niagara Falls, ON

CA L2J 1A2 Contact: Mark Michalkoff mmichalkoff@oleoenergies.com T: (905)358-5133