



# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**A2309172**  
 Component  
**Quench Oil**  
 Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

**Recommendation**  
 This is a baseline read-out on the submitted sample.

**Wear**  
 Copper ppm levels are noted.

**Contamination**  
 {not applicable}

**Fluid Condition**  
 {not applicable}

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Batch #	Client Info		<b>2023 09 0340</b>	---	---
Machine ID	Client Info		<b>A2309172</b>	---	---
Department	Client Info		<b>Production</b>	---	---
Sample From	Client Info		<b>Machine</b>	---	---
Production Stage	Client Info		<b>Final</b>	---	---
Sent to WC	Client Info		<b>09/27/2023</b>	---	---
Sample Number	Client Info		<b>E30000416</b>	---	---
Sample Date	Client Info		<b>26 Sep 2023</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>N/A</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	<b>8</b>	---	---
Chromium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Nickel	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Silver	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Aluminum	ppm	ASTM D5185(m)	<b>0</b>	---	---
Lead	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Copper	ppm	ASTM D5185(m)	<b>11</b>	---	---
Tin	ppm	ASTM D5185(m)	<b>0</b>	---	---
Antimony	ppm	ASTM D5185(m)	<b>0</b>	---	---
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	---	---
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	---	---






## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Barium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Molybdenum	ppm	ASTM D5185(m)	<b>0</b>	---	---
Manganese	ppm	ASTM D5185(m)	<b>0</b>	---	---
Magnesium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Calcium	ppm	ASTM D5185(m)	<b>22</b>	---	---
Phosphorus	ppm	ASTM D5185(m)	<b>22</b>	---	---
Zinc	ppm	ASTM D5185(m)	<b>6</b>	---	---
Sulfur	ppm	ASTM D5185(m)	<b>287</b>	---	---
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	<b>2</b>	---	---
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	---	---
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	---	---
Water	%	ASTM D6304*	<b>0.00</b>	---	---
ppm Water	ppm	ASTM D6304*	<b>0.00</b>	---	---

# OIL ANALYSIS REPORT





FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>135</b>	---	---	
Particles >6µm	ASTM D7647	>1300	<b>46</b>	---	---	
Particles >14µm	ASTM D7647	>160	<b>12</b>	---	---	
Particles >21µm	ASTM D7647	>40	<b>4</b>	---	---	
Particles >38µm	ASTM D7647	>10	<b>0</b>	---	---	
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	---	
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>14/13/11</b>	---	---	

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.14</b>	---	---

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	---	---
Silt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Debris	scalar	Visual*	NONE	<b>NONE</b>	---	---
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Appearance	scalar	Visual*	NORML	<b>NORML</b>	---	---
Odor	scalar	Visual*	NORML	<b>NORML</b>	---	---
Emulsified Water	scalar	Visual*		<b>NEG</b>	---	---
Free Water	scalar	Visual*		<b>NEG</b>	---	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)		<b>66.5</b>	---	---
Visc @ 100°C	cSt	ASTM D7279(m)		<b>9.5</b>	---	---
Viscosity Index (VI)	Scale	ASTM D2270*		<b>122</b>	---	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : E30000416 **Received** : 02 Oct 2023  
**Lab Number** : **02586184** **Diagnosed** : 05 Oct 2023  
**Unique Number** : 5655250 **Diagnostician** : Tatiana Sorkina  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, TAN Man, VI )

**Environmental 360 Solutions Ltd.**  
 640 Victoria Street  
 Cobourg, ON  
 CA K9A 5H5  
 Contact: Aylwin Lee  
 aylwinlee@e360s.ca  
 T: (905)372-2251  
 F: (905)373-4950

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.