


# **OIL ANALYSIS REPORT**

Area [4231] Machine Id 09-028-CD

New (Unused) Oil

PETRO CANADA LUMINOL LS B-4 (--- GAL)





### DIAGNOSIS

## Recommendation

This is a baseline read-out on the submitted sample.

## Wear

{not applicable}

# Contamination

{not applicable}

# **Fluid Condition**

Pour Point = -60°C.


<b>-</b> )				Sep 2023		
SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PP0000778		
Sample Date		Client Info		28 Sep 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>5	0		
Chromium	ppm	ASTM D5185(m)	>5	0		
Nickel	ppm	ASTM D5185(m)	>5	0		
Titanium	ppm	ASTM D5185(m)		0		
Silver	ppm	ASTM D5185(m)	>5	<1		
Aluminum	ppm	ASTM D5185(m)	>5	0		
Lead	ppm	ASTM D5185(m)	>5	<1		
Copper	ppm	ASTM D5185(m)	>5	<1		
Tin	ppm	ASTM D5185(m)	>5	0		
Antimony	ppm	ASTM D5185(m)	70	0		
Vanadium	• •	ASTM D5185(m)		0		
	ppm	. ,		-		
Beryllium	ppm	ASTM D5185(m)		0		
Cadmium	ppm	ASTM D5185(m)		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)		<1		
Barium	ppm	ASTM D5185(m)		<1		
Molybdenum	ppm	ASTM D5185(m)		0		
Manganese	ppm	ASTM D5185(m)		0		
Magnesium	ppm	ASTM D5185(m)		0		
Calcium	ppm	ASTM D5185(m)		0		
Phosphorus	ppm	ASTM D5185(m)		0		
Zinc	ppm	ASTM D5185(m)		<1		
Sulfur	ppm	ASTM D5185(m)		1		
Lithium	ppm	ASTM D5185(m)		<1		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>15	0		
Sodium	ppm	ASTM D5185(m)		0		
Potassium	ppm	ASTM D5185(m)	>20	<1		
	ррпп					
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE		
Yellow Metal	scalar	Visual*	NONE	NONE		
Precipitate	scalar	Visual*	NONE	NONE		
Silt	scalar	Visual*	NONE	NONE		
Debris	scalar	Visual*	NONE	NONE		
Sand/Dirt	scalar	Visual*	NONE	NONE		
Appearance	scalar	Visual*	NORML	NORML		
Odor	scalar	Visual*	NORML	NORML		




# **OIL ANALYSIS REPORT**

FLUID PROPERTIES		method	limit/base	current	history1	history2
Pour Point	°C	ASTM D97*		-60		
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color				no image	no image	no image
Bottom				no image	no image	no image
GRAPHS						

# Ferrous Alloys







CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number Unique Number : 5655291

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : PP0000778 : 02586225

Received Diagnosed

: 02 Oct 2023 : 02 Oct 2023 Diagnostician : Kevin Marson

Test Package : TEST ( Additional Tests: ICP, PourPt, Visual ) To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

**Oleo Energies** 5800 Thorold Stone Road Niagara Falls, ON

CA L2J 1A2 Contact: Rahzia Neufeld rneufeld@oleoenergies.com

T: (905)358-5133