



OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
REFRESCO
 Machine Id
MYCOM COMPRESSOR #1 (S/N 1575)
 Component
Reciprocating Compressor
 Fluid
CIMCO TYPE A (--- GAL)

DIAGNOSIS

Recommendation
 Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0848637	---	---
Sample Date	Client Info		22 Sep 2023	---	---
Machine Age	hrs Client Info		2095	---	---
Oil Age	hrs Client Info		9	---	---
Oil Changed	Client Info		Not Chngd	---	---
Sample Status			NORMAL	---	---

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	---	---
Iron	ppm ASTM D5185(m)	>50	<1	---	---
Chromium	ppm ASTM D5185(m)	>10	0	---	---
Nickel	ppm ASTM D5185(m)		<1	---	---
Titanium	ppm ASTM D5185(m)		0	---	---
Silver	ppm ASTM D5185(m)		<1	---	---
Aluminum	ppm ASTM D5185(m)	>25	0	---	---
Lead	ppm ASTM D5185(m)	>25	0	---	---
Copper	ppm ASTM D5185(m)	>50	<1	---	---
Tin	ppm ASTM D5185(m)	>15	0	---	---
Antimony	ppm ASTM D5185(m)		0	---	---
Vanadium	ppm ASTM D5185(m)		0	---	---
Beryllium	ppm ASTM D5185(m)		0	---	---
Cadmium	ppm ASTM D5185(m)		0	---	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm ASTM D5185(m)		<1	---	---
Barium	ppm ASTM D5185(m)		0	---	---
Molybdenum	ppm ASTM D5185(m)		0	---	---
Manganese	ppm ASTM D5185(m)		0	---	---
Magnesium	ppm ASTM D5185(m)		0	---	---
Calcium	ppm ASTM D5185(m)		<1	---	---
Phosphorus	ppm ASTM D5185(m)		<1	---	---
Zinc	ppm ASTM D5185(m)		<1	---	---
Sulfur	ppm ASTM D5185(m)		5	---	---
Lithium	ppm ASTM D5185(m)		<1	---	---

CONTAMINANTS





	method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185(m)	>25	0	---	---
Sodium	ppm ASTM D5185(m)		<1	---	---
Potassium	ppm ASTM D5185(m)	>20	0	---	---
Water	% ASTM D6304*	>0.1	0.001	---	---
ppm Water	ppm ASTM D6304*	>1000	14.6	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974*	0.05	0.01	---	---



OIL ANALYSIS REPORT






VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	---	---
Yellow Metal	scalar	Visual*	NONE	NONE	---	---
Precipitate	scalar	Visual*	NONE	NONE	---	---
Silt	scalar	Visual*	NONE	NONE	---	---
Debris	scalar	Visual*	NONE	NONE	---	---
Sand/Dirt	scalar	Visual*	NONE	NONE	---	---
Appearance	scalar	Visual*	NORML	NORML	---	---
Odor	scalar	Visual*	NORML	AMMON	---	---
Emulsified Water	scalar	Visual*	>0.1	NEG	---	---
Free Water	scalar	Visual*		NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	58	55.9	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0848637 **Received** : 03 Oct 2023
Lab Number : 02586459 **Diagnosed** : 04 Oct 2023
Unique Number : 5655525 **Diagnostician** : Bill Quesnel
Test Package : IND 2 (Additional Tests: KF, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

CIMCO Refrigeration
 1551 Corporate Drive
 Burlington, ON
 CA L7L 6M3
 Contact: Roberto Stillisano
 rstillisano@toromont.com
 T: (416)886-9921
 F: (416)465-8815