




# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Machine Id  
**NOVA 1716**

Component  
**Natural Gas Engine**

Fluid  
**VALVOLINE PREMIUM BLUE 9200 15W40 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We recommend an early resample to monitor this condition.

### ▲ Wear

Copper ppm levels are noted. In the absence of other significant wear metals, suspect copper due to sources other than wear (i.e. cooling core). All other component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0849963</b>	WC0811611	WC0791290
Sample Date	Client Info		<b>30 Sep 2023</b>	30 Jun 2023	04 Apr 2023
Machine Age	kms	Client Info	<b>0</b>	0	305663
Oil Age	kms	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ATTENTION</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Glycol	WC Method		---	0.0	---

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>50	<b>11</b>	12	13
Chromium	ppm	ASTM D5185(m)	>4	<b>1</b>	2	2
Nickel	ppm	ASTM D5185(m)	>2	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	<1	2
Silver	ppm	ASTM D5185(m)	>3	<b>&lt;1</b>	<1	1
Aluminum	ppm	ASTM D5185(m)	>9	<b>2</b>	2	2
Lead	ppm	ASTM D5185(m)	>30	<b>3</b>	5	3
Copper	ppm	ASTM D5185(m)	>35	<b>▲ 67</b>	32	14
Tin	ppm	ASTM D5185(m)	>4	<b>&lt;1</b>	<1	<1
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<b>6</b>	6	7
Barium	ppm	ASTM D5185(m)		<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>54</b>	53	52
Manganese	ppm	ASTM D5185(m)		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m)		<b>841</b>	846	825
Calcium	ppm	ASTM D5185(m)		<b>1260</b>	1287	1325
Phosphorus	ppm	ASTM D5185(m)		<b>679</b>	733	781
Zinc	ppm	ASTM D5185(m)		<b>889</b>	873	873
Sulfur	ppm	ASTM D5185(m)		<b>1790</b>	1804	1912
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>+100	<b>6</b>	6	6
Sodium	ppm	ASTM D5185(m)		<b>3</b>	9	4
Potassium	ppm	ASTM D5185(m)	>20	<b>&lt;1</b>	12	2

## INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	ASTM D7844*		<b>0</b>	0	0
Nitration	Abs/cm	ASTM D7624*	>20	<b>12.6</b>	13.4	14.1
Sulfation	Abs/.1mm	ASTM D7415*	>30	<b>23.0</b>	24.3	26.2


## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	ASTM D7414*	>25	<b>21.5</b>	23.3	22.1




# OIL ANALYSIS REPORT

### ▲ Non-ferrous Metals



### Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.1	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	14.8	13.5	13.2

### GRAPHS


#### Iron (ppm)




#### Lead (ppm)




#### Aluminum (ppm)




#### Chromium (ppm)




### ▲ Copper (ppm)




### Silicon (ppm)



### Viscosity @ 100°C



### Additives



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0849963  
**Lab Number** : 02586626  
**Unique Number** : 5655692  
**Test Package** : MOB 1

**Received** : 04 Oct 2023  
**Diagnosed** : 04 Oct 2023  
**Diagnostician** : Kevin Marson  
**CITY OF HAMILTON**  
 2200 UPPER JAMES., MOUNTAIN TRANSIT STOREROOM  
 MOUNT HOPE, ON  
 CA L0R 1W0  
 Contact: Jeff Parr  
 jeff.parr@hamilton.ca  
 T: (905)546-2424  
 F: (905)679-4502

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.