




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
PUMPHOUSE/AIR COMPRESSORS
 Machine Id
C - 3 Air Compressor TURBINE Compressor Oil Sump
 Component
Lube System
 Fluid
SULLAIR SULLUBE (45 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0866325	WC	WC0785649
Sample Date	Client Info		04 Oct 2023	30 May 2023	27 Jan 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	SEVERE	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184*	>DFLT	0	---	0	
Iron	ppm	ASTM D5185(m)	>20	6	---	5
Chromium	ppm	ASTM D5185(m)	>20	0	---	0
Nickel	ppm	ASTM D5185(m)	>20	0	---	0
Titanium	ppm	ASTM D5185(m)		0	---	0
Silver	ppm	ASTM D5185(m)		<1	---	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	---	0
Lead	ppm	ASTM D5185(m)	>20	<1	---	<1
Copper	ppm	ASTM D5185(m)	>20	<1	---	4
Tin	ppm	ASTM D5185(m)	>20	0	---	0
Antimony	ppm	ASTM D5185(m)		0	---	0
Vanadium	ppm	ASTM D5185(m)		0	---	0
Beryllium	ppm	ASTM D5185(m)		0	---	0
Cadmium	ppm	ASTM D5185(m)		0	---	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	12	2	---	2
Barium	ppm	ASTM D5185(m)	500	259	---	359
Molybdenum	ppm	ASTM D5185(m)	0.0	0	---	0
Manganese	ppm	ASTM D5185(m)		0	---	<1
Magnesium	ppm	ASTM D5185(m)	0.0	<1	---	<1
Calcium	ppm	ASTM D5185(m)	8.2	2	---	1
Phosphorus	ppm	ASTM D5185(m)	4.0	2	---	<1
Zinc	ppm	ASTM D5185(m)	0.1	5	---	28
Sulfur	ppm	ASTM D5185(m)	240	154	---	138
Lithium	ppm	ASTM D5185(m)		<1	---	<1

CONTAMINANTS






	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	0	---	0
Sodium	ppm	ASTM D5185(m)		6	---	14
Potassium	ppm	ASTM D5185(m)	>20	2	---	2

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		74886	---	15797
Particles >6µm	ASTM D7647	>10240000	9075	---	3923
Particles >14µm	ASTM D7647	>10240000	131	---	228
Particles >21µm	ASTM D7647	>2560000	19	---	55
Particles >38µm	ASTM D7647	>640000	1	---	2
Particles >71µm	ASTM D7647	>160000	0	---	0
Oil Cleanliness	ISO 4406 (c)	>--/30/30	23/20/14	---	21/19/15



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	0.06	0.12	---	0.25






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NOOIL	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>1	NEG	---	NEG
Free Water	scalar	Visual*		NEG	---	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	38.1	37.3	---	37.1

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



ISO 17025:2017
Accredited
Laboratory

Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**
Sample No. : WC0866325 **Received** : 04 Oct 2023 2330 Regional Road #3, Door: BOSC8
Lab Number : 02586759 **Diagnosed** : 05 Oct 2023 NANTICOKE, ON
Unique Number : 5655825 **Diagnostician** : Wes Davis CA N0A 1L0
Test Package : IND 2 (Additional Tests: PQ, TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.
 Contact: Tom Walden
 Thomas.Walden@stelco.com
 T: (519)587-4541
 F: (519)587-7702