


PROBLEM SUMMARY

PUMPHOUSE/LANCE & FCE PUMPS C - Lance and Furnace Turbine OB


Lube System


PETRO CANADA HYDREX AW 100 (1 GAL)





COMPONENT CONDITION SUMMARY





RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC T	EST RE	SULTS				
Sample Status				SEVERE	SEVERE	NORMAL
Tin	ppm	ASTM D5185(m)	>20	• 55	0	4
Antimony	ppm	ASTM D5185(m)		<u> </u>	0	<1
Particles >6µm		ASTM D7647	>10000	△ 30256	103495	6707
Oil Cleanliness		ISO 4406 (c)	>/20/18	25/22/16	2 5/24/18	23/20/14
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE	NONE
PrtFilter				8	no image	no image

Customer Id: LEWBOSC Sample No.: WC0866297 Lab Number: 02586768 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Kevin Marson +1 (289)291-4644 x4644 Kevin.Marson@wearcheck.com

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Resample			?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

31 May 2023 Diag: Bill Quesnel

WATER



We advise that you check for the source of water entry. Check seals and/or filters for points of contaminant entry. We advise that you follow the water drain-off procedure for this component. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a high concentration of water present in the oil. Free water present. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



27 Jan 2023 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

13 Dec 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

PUMPHOUSE/LANCE & FCE PUMPS C - Lance and Furnace Turbine OB

Lube System

PETRO CANADA HYDREX AW 100 (1 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Tin ppm levels are severe. Antimony ppm levels are abnormal. Pump thrust plate, or bushing wear is indicated. Light concentration of visible metal present.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.


•)		p 1999 Mar 2001	Apr2004 Mar2012 Mar2	013 Aug2014 Jul2018 Nov2019 A	ug2022 Oct20	
SAMPLE INFORM	NOITAN	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0866297	WC0824426	WC0785689
Sample Date		Client Info		04 Oct 2023	31 May 2023	27 Jan 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	SEVERE	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184*	>DFLT	0	7	0
Iron	ppm	ASTM D5185(m)	>20	4	48	4
Chromium	ppm	ASTM D5185(m)	>20	0	<1	0
Nickel	ppm	ASTM D5185(m)	>20	0	0	<1
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)		<1	<1	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	<1	<1
Lead	ppm	ASTM D5185(m)	>20	12	3	11
Copper	ppm	ASTM D5185(m)	>20	6	4	32
Tin	ppm	ASTM D5185(m)	>20	5 5	0	4
Antimony	ppm	ASTM D5185(m)		<u> </u>	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	0
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	<1	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	0	<1	<1	<1
Barium	ppm	ASTM D5185(m)	0	<1	14	4
Molybdenum	ppm	ASTM D5185(m)	0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	<1	0
Magnesium	ppm	ASTM D5185(m)	0	0	<1	<1
Calcium	ppm	ASTM D5185(m)	50	47	29	49
Phosphorus	ppm	ASTM D5185(m)	330	319	331	367
Zinc	ppm	ASTM D5185(m)	430	408	379	403
Sulfur	ppm	ASTM D5185(m)	760	2431	3364	2657
Lithium	ppm	ASTM D5185(m)		<1	<1	<1
CONTAMINANTS		method	limit/base	current	history1	history2

CONTAMINAN	ITS	method	limit/base	current	history1	histor	y2
Silicon	ppm	ASTM D5185(m)	>15	2	8	1	
Sodium	ppm	ASTM D5185(m)		<1	2	2	
Potassium	ppm	ASTM D5185(m)	>20	24	<1	<1	

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4μm	ASTM D7647		166702	312222	60049
Particles >6µm	ASTM D7647	>10000	4 30256	103495	6707
Particles >14μm	ASTM D7647	>2500	425	2237	94
Particles >21µm	ASTM D7647	>640	72	488	17
Particles >38μm	ASTM D7647	>160	3	3	0
Particles >71µm	ASTM D7647	>40	0	0	0
Oil Cleanliness	ISO 4406 (c)	>/20/18	<u>^ 25/22/16</u>	25/24/18	23/20/14





OIL ANALYSIS REPORT

mg KOH/g ASTM D974*

scalar

scalar

scalar

scalar

scalar

scalar

scalar

scalar

scalar

cSt

scalar Visual*

ASTM D7279(m)

0.60

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

>5

101

0.44

VLITE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

NEG

NEG

94.9

FLUID DEGRADATION

FLUID PROPERTIES

SAMPLE IMAGES

PrtFilter

Acid Number (AN)


VISUAL

White Metal


Yellow Metal


Precipitate

Silt



Sep1 Mar26 Apr25 Apr25 Aug20 Jull5 Oct4	Debris
Daubiela Carreb	Sand/Dirt
Particle Count 491,520 T T26	Appearance
122,880	Odor
₹ 30,720 22 88 20 12 12 12 12 12 12 12 12 12 12 12 12 12	Emulsified Water
7,680	Free Water
30,720	FLUID PROPE
12 ss 30	Visc @ 40°C
2	SAMPLE IMAG
0 4μ 6μ 14μ 21μ 38μ 71μ	
Particle Trend	Color
= 500k − − − − − − − − − − − − − − − − − −	
\$ 400k	
(a) 500k + (b) 4μm (b) 4μm (b) 4μm (b) 4μm (b) 6μm (b	Bottom
g zook	
= 100k	







CALA ISO 17025:2017 Accredited

Laboratory Sample No. Lab Number **Unique Number** Test Package : IND 2 (Additional Tests: Bottom, BottomAnalysis, FilterPatch, PQ, PrtFilter)

: WC0866297 : 02586768 : 5655834

Received

: 04 Oct 2023 Diagnosed

: 06 Oct 2023 Diagnostician : Kevin Marson

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 STELCO - BOSC - Basic Oxygen Slab Caster 2330 Regional Road #3, Door: BOSC8 NANTICOKE, ON

0.48

NONE

NONE

NONE

NONE

NONE

NONE

LAYRD

NORML

1%

>10%

97.5

no image

0.48

NONE

NONE

NONE

NONE

NONE

NONE

NEG

NEG

99.7

no image

NORML

NORML

CA NOA 1L0 Contact: Tom Walden

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.

T: (519)587-4541 F: (519)587-7702

Report Id: LEWBOSC [WCAMIS] 02586768 (Generated: 10/06/2023 13:29:58) Rev: 1

Submitted By: Bob Melanson

Thomas.Walden@stelco.com