




# PROBLEM SUMMARY

Sample Rating Trend




## VISCOSITY



Area  
**Caster/Segment Drives**  
 Machine Id  
**B - Strand 2 - 2 Gear Box Roll # 60 Bottom**  
 Component  
**Gearbox**  
 Fluid  
**SHELL OMALA 220 (45 GAL)**

### COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



### RECOMMENDATION

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. The fluid was specified as SHELL OMALA 220, however, a fluid match indicates that this fluid is ISO 320 Gear Oil. Please confirm the oil type and grade on your next sample.

### PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	NORMAL	NORMAL
Sulfur	ppm	ASTM D5185(m)	7039	▲ 14231	7996 8032
Visc @ 40°C	cSt	ASTM D7279(m)	220	▲ 304	234 234

Customer Id: LEWBOSC  
 Sample No.: WC0866324  
 Lab Number: 02586908  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

**RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Alert	---	---	?	The fluid was specified as SHELL OMALA 220, however, a fluid match indicates that this fluid is ISO 320 Gear Oil. Please confirm the oil type and grade on your next sample.
Check Fluid Source	---	---	?	Confirm the source of the lubricant being utilized for top-up/fill.

**HISTORICAL DIAGNOSIS**

**28 Feb 2023 Diag: Kevin Marson**

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



**13 Sep 2022 Diag: Kevin Marson**

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



**01 Mar 2022 Diag: Kevin Marson**

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

VISCOSITY

Area  
**Caster/Segment Drives**  
 Machine Id  
**B - Strand 2 - 2 Gear Box Roll # 60 Bottom**  
 Component  
**Gearbox**  
 Fluid  
**SHELL OMALA 220 (45 GAL)**



## DIAGNOSIS

### Recommendation

Confirm the source of the lubricant being utilized for top-up/fill. Resample at the next service interval to monitor. The fluid was specified as SHELL OMALA 220, however, a fluid match indicates that this fluid is ISO 320 Gear Oil. Please confirm the oil type and grade on your next sample.

### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

### Fluid Condition

Viscosity of sample indicates oil is within ISO 320 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0866324</b>	WC0796850	WC0743642
Sample Date	Client Info		<b>04 Oct 2023</b>	28 Feb 2023	13 Sep 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*	>DFLT	<b>6</b>	5	2
Iron	ppm	ASTM D5185(m) >200	<b>15</b>	54	49
Chromium	ppm	ASTM D5185(m) >15	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185(m) >15	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)	<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185(m) >25	<b>&lt;1</b>	<1	<1
Lead	ppm	ASTM D5185(m) >100	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185(m) >200	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185(m) >25	<b>0</b>	<1	0
Antimony	ppm	ASTM D5185(m) >5	<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 4.4	<b>16</b>	5	5
Barium	ppm	ASTM D5185(m) 0.0	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185(m) 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185(m) 0	<b>&lt;1</b>	1	1
Calcium	ppm	ASTM D5185(m) 0	<b>3</b>	3	4
Phosphorus	ppm	ASTM D5185(m) 215	<b>294</b>	255	242
Zinc	ppm	ASTM D5185(m) 0	<b>2</b>	2	2
Sulfur	ppm	ASTM D5185(m) 7039	<b>▲ 14231</b>	7996	8032
Lithium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1






## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >50	<b>&lt;1</b>	5	4
Sodium	ppm	ASTM D5185(m)	<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185(m) >20	<b>0</b>	<1	0

## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>170961</b>	208955	101295
Particles >6µm	ASTM D7647	>10240000	<b>52492</b>	55181	27639
Particles >14µm	ASTM D7647	>10240000	<b>1225</b>	2610	667
Particles >21µm	ASTM D7647	>2560000	<b>235</b>	746	163
Particles >38µm	ASTM D7647	>640000	<b>13</b>	17	3
Particles >71µm	ASTM D7647	>160000	<b>1</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>--/30/30	<b>25/23/17</b>	25/23/19	24/22/17

# OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*		<b>0.72</b>	0.53	0.46






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	Visual*	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	<b>VLITE</b>	VLITE	NONE
Appearance	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	Visual*	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	Visual*	>5	<b>NEG</b>	NEG	NEG
Free Water	scalar	Visual*		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	220	<b>▲ 304</b>	234	234

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 **STELCO - BOSC - Basic Oxygen Slab Caster**  
**Sample No.** : WC0866324 **Received** : 04 Oct 2023 2330 Regional Road #3, Door: BOSC8  
**Lab Number** : 02586908 **Diagnosed** : 05 Oct 2023 NANTICOKE, ON  
**Unique Number** : 5655974 **Diagnostician** : Kevin Marson CA N0A 1L0  
**Test Package** : IND 2 ( Additional Tests: PQ, PrtCount, TAN Man )  
 Contact: Tom Walden  
 Thomas.Walden@stelco.com  
 T: (519)587-4541  
 F: (519)587-7702

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.