

COOLANT REPORT

BRIDGEPOINT [192081] 332621-1-2-0621

Component

Coolant

CONVENTIONAL COOLANT (--- GAL)

Sample Rating Trend **NORMAL**

Recommendation

The fluid is suitable for further service. Resample at the next service interval to monitor.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits.

				Sep 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WA0020037		
Sample Date		Client Info		26 Sep 2023		
Machine Age	hrs	Client Info		209		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*		1.065		
рН	Scale 0-14	ASTM D1287*	9.5	8.38		
Nitrites	ppm	Alcan Test Kit*	1500	1600		
Reserve Alkalinity	Scale 0-20	ASTM D1121*	8.5	2.2		
Percentage Glycol	%	ASTM D3321*	50	48.3		
Freezing Point	°C	ASTM D3321*	-40	-31		
Carboxylate		7.072002.				
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		17		
Phosphorus	ppm	ASTM D5185(m)		10		
Boron	ppm	ASTM D5185(m)		168		
Molybdenum		ASTM D5185(m)		0		
,	ppm					
CORROSION		method	limit/base		history1	history2
Iron	ppm	ASTM D5185(m)	>15	0		
Aluminum	ppm	ASTM D5185(m)	>10	0		
Copper	ppm	ASTM D5185(m)	>10	3		
Lead	ppm	ASTM D5185(m)	>10	0		
Tin	ppm	ASTM D5185(m)	>10	<1		
Silver	ppm	ASTM D5185(m)	>10	<1		
Zinc	ppm	ASTM D5185(m)		<1		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		1647		
Potassium	ppm	ASTM D5185(m)		186		
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	2		
Magnesium	ppm	ASTM D5185(m)	>40	1		
Hardness	mg/L CaCO3	In-house*	<75	8		
VISUAL		method	limit/base	current	history1	history2
Coolant Color		Visual*	Green	Green		
Coolant Appearance		Visual*	Clear	Cloudy		
Color					no image	no image
Bottom					no image	no image



COOLANT REPORT





CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number

Unique Number : 5655996 Test Package : COOL

: WA0020037 : 02586930

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 Received Diagnosed

: 04 Oct 2023 : 05 Oct 2023 Diagnostician : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Wajax Power Systems 10 Diesel Drive

Toronto, ON **CA M8W 2T8** Contact: Komal Ramotar kramotar@wajax.com T: (416)259-3281

F: (416)251-6191