


COOLANT REPORT

THE STATE GROUP [174787] MTU 324002-1-2-0810 526105114 - GEN:BLUE

Component

HYBRID (HOAT) COOLANT (--- LTR)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. The fluid was not specified, however, a fluid match indicates that this fluid is (GENERIC) HYBRID (HOAT) COOLANT. Please confirm.

All component wear rates are normal.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

The condition of the coolant is acceptable for the time in service.


				Sep 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WA0020278		
Sample Date		Client Info		11 Sep 2023		
Machine Age	yrs	Client Info		0		
Oil Age	yrs	Client Info		5		
Oil Changed	, -	Client Info		Not Changd		
Sample Status				NORMAL		
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		ASTM D1298*		1.066		
pH	Scale 0-14	ASTM D1287*		8.54		
Nitrites	ppm	Alcan Test Kit*		1400		
Reserve Alkalinity	Scale 0-20	ASTM D1121*		2.6		
Percentage Glycol	%	ASTM D3321*		48.9		
Freezing Point	°C	ASTM D3321*		-31		
Carboxylate						
CORROSION INHI	BITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)		8		
Phosphorus	ppm	ASTM D5185(m)		6		
Boron	ppm	ASTM D5185(m)		188		
Molybdenum	ppm	ASTM D5185(m)		0		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>15	3		
Aluminum	ppm	ASTM D5185(m)	>10	0		
Copper	ppm	ASTM D5185(m)	>10	5		
Lead	ppm	ASTM D5185(m)	>10	0		
Tin	ppm	ASTM D5185(m)	>10	3		
Silver	ppm	ASTM D5185(m)	>10	<1		
Zinc	ppm	ASTM D5185(m)		3		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D5185(m)		2042		
Potassium	ppm	ASTM D5185(m)		67		
SCALE POTENTIA	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D5185(m)	>100	2		
Magnesium	ppm	ASTM D5185(m)	>40	<1		
Hardness	mg/L CaCO3	In-house*	<75	6		
VISUAL		method	limit/base	current	history1	history2
Coolant Color		Visual*		Yellow		
Coolant Appearance		Visual*	Clear	Clear		
Color					no image	no image
Bottom				(6)	no image	no image

Contact/Location: David Gilkes - HARTOR



COOLANT REPORT







CALA ISO 17025:2017 Accredited Laboratory

Laboratory Sample No. Lab Number : 02586933 Unique Number : 5655999

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : WA0020278

Tested Test Package : COOL

Diagnosed

Received

: 04 Oct 2023 : 05 Oct 2023

: 05 Oct 2023 - Wes Davis

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

Wajax Power Systems 10 Diesel Drive Toronto, ON **CA M8W 2T8** Contact: David Gilkes dgilkes@wajax.com

> T: (416)259-3281 F: (416)251-6191