




PROBLEM SUMMARY

Sample Rating Trend



VISUAL METAL




Machine Id
HYDROSTATIC TEST STAND

Component
Hydraulic System


Fluid
RADCOLUBE RHP5606 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ **Non-ferrous Metals**



▲ **Particle Trend**



RECOMMENDATION

We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	ABNORMAL	SEVERE
Copper	ppm	ASTM D5185(m)	>20	▲ 23	18	11
Particles >4µm		ASTM D7647	>5000	▲ 5857	▲ 11827	● 81681
Particles >6µm		ASTM D7647	>1300	▲ 1525	▲ 3082	● 20033
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ 20/18/14	▲ 21/19/15	● 24/22/16
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE	NONE
PrtFilter					no image	no image

Customer Id: PARMIL
Sample No.: WC0782055
Lab Number: 02587150
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.

HISTORICAL DIAGNOSIS

12 Jul 2023 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



18 May 2023 Diag: Wes Davis

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



28 Mar 2023 Diag: Kevin Marson

VISUAL METAL



We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Copper ppm levels are noted. Moderate concentration of visible metal present. Cylinder wear is indicated. Particles >4µm are abnormally high. Particles >6µm and oil cleanliness are abnormally high. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



VISUAL METAL



Machine Id HYDROSTATIC TEST STAND

Component
Hydraulic System
Fluid

RADCOLUBE RHP5606 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for visible metal particles in the oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

Copper ppm levels are noted. Light concentration of visible metal present. All other component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0782055	WC0782051	WC0782047
Sample Date	Client Info	04 Oct 2023	12 Jul 2023	18 May 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ATTENTION	ABNORMAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m) >20	8	7	5
Chromium	ppm	ASTM D5185(m) >20	0	0	0
Nickel	ppm	ASTM D5185(m) >20	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	<1	0	0
Aluminum	ppm	ASTM D5185(m) >20	0	<1	0
Lead	ppm	ASTM D5185(m) >20	4	4	3
Copper	ppm	ASTM D5185(m) >20	▲ 23	18	11
Tin	ppm	ASTM D5185(m) >20	0	0	0
Antimony	ppm	ASTM D5185(m)	0	<1	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	<1	<1	<1
Barium	ppm	ASTM D5185(m)	2	1	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	<1	1	<1
Magnesium	ppm	ASTM D5185(m)	4	4	<1
Calcium	ppm	ASTM D5185(m)	4	3	<1
Phosphorus	ppm	ASTM D5185(m)	74	67	41
Zinc	ppm	ASTM D5185(m)	68	55	24
Sulfur	ppm	ASTM D5185(m)	281	255	229
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m) >15	<1	0	0
Sodium	ppm	ASTM D5185(m)	2	1	<1
Potassium	ppm	ASTM D5185(m) >20	1	2	<1

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	▲ 5857	▲ 11827	● 81681
Particles >6µm	ASTM D7647 >1300	▲ 1525	▲ 3082	● 20033
Particles >14µm	ASTM D7647 >160	99	▲ 178	▲ 579
Particles >21µm	ASTM D7647 >40	23	41	▲ 102
Particles >38µm	ASTM D7647 >10	2	2	2
Particles >71µm	ASTM D7647 >3	0	0	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	▲ 20/18/14	▲ 21/19/15	● 24/22/16






FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974* 0.20	0.17	0.06	0.05

Particle Filter (Magn: 100 x)



OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	13.2	15.0	14.4	14.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0782055 **Received** : 05 Oct 2023
Lab Number : 02587150 **Diagnosed** : 06 Oct 2023
Unique Number : 5656216 **Diagnostician** : Kevin Marson
Test Package : IND 2 (Additional Tests: Bottom, BottomAnalysis, FilterPatch, PrtFilter, TAN Man)

PARKER HANNIFIN
 160 CHISHOLM DRIVE
 MILTON, ON
 CA L9T 3G9
 Contact: Walter Wozniak
 walter.wozniak@parker.com
 T: (905)693-3000
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.