




PROBLEM SUMMARY

Sample Rating Trend

ISO




Area
(ZONE3) BRUCE A/4/34710
 Machine Id
4-34710-P2-P OB Ball/Sleeve
 Component
Outboard Bearing
 Fluid
MOBIL DTE 732 (--- GAL)



COMPONENT CONDITION SUMMARY

Particle Trend



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS

Sample Status		SEVERE	SEVERE	SEVERE
Particles >4µm	ASTM D7647 >5000	55042	174829	273306
Particles >6µm	ASTM D7647 >1300	3803	17020	36010
Oil Cleanliness	ISO 4406 (c) >19/17/15	23/19/13	25/21/15	25/22/17

Customer Id: BRUTIV
 Sample No.: WC0815685
 Lab Number: 02587175
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	Resample in 30-45 days to monitor this situation.
Information Required	---	---	?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.
Check Breathers	---	---	?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.
Check Seals	---	---	?	Check seals and/or filters for points of contaminant entry.

HISTORICAL DIAGNOSIS

ISO



23 Mar 2023 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



WATER



20 Apr 2022 Diag: Kevin Marson

Check seals and/or filters for points of contaminant entry. We advise that you check all areas where contaminants can enter the system. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. No other corrective action is recommended at this time. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Wear particle analysis indicates that the ferrous cutting particles are marginal. All other component wear rates are normal. Cutting wear particles are caused by either hard protuberances (mis-aligned components, etc.), or abrasives entering the system and embedding themselves in softer materials (sand, etc.), and gouging out mating surfaces. Water and ppm water contamination levels are severe. Particles >6µm are severely high. Particles >4µm are severely high. Particles >4µm are severely high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. There is a high concentration of water present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



ISO



29 Sep 2021 Diag: Kevin Marson

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. Particles >6µm are severely high. Particles >4µm are severely high. Particles >14µm are abnormally high. Particles >21µm are abnormally high. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
(ZONE3) BRUCE A/4/34710
Machine Id
4-34710-P2-P OB Ball/Sleeve
Component
Outboard Bearing
Fluid
MOBIL DTE 732 (--- GAL)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0815685	WC0801511	WC0660372
Sample Date	Client Info	27 Sep 2023	23 Mar 2023	20 Apr 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		SEVERE	SEVERE	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m) >10	2	4	6
Chromium	ppm	ASTM D5185(m) >5	0	0	0
Nickel	ppm	ASTM D5185(m) >5	<1	<1	<1
Titanium	ppm	ASTM D5185(m) >5	0	0	0
Silver	ppm	ASTM D5185(m)	<1	0	0
Aluminum	ppm	ASTM D5185(m) >5	0	<1	0
Lead	ppm	ASTM D5185(m) >5	<1	<1	0
Copper	ppm	ASTM D5185(m) >5	1	3	<1
Tin	ppm	ASTM D5185(m) >5	0	<1	0
Antimony	ppm	ASTM D5185(m)	0	0	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	0	0






DR-FERROGRAPHY

method	limit/base	current	history1	history2	
Large Particles	DR-Ferr*	8.2	83.7	141.2	
Small Particles	DR-Ferr*	6.5	36.5	63.9	
Total Particles	DR-Ferr*	>---	120.2	205.1	
Large Particles Percentage	%	DR-Ferr*	11.6	39.3	37.7
Severity Index	DR-Ferr*	14	3951	10915	

FERROGRAPHY

method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*	4	5
Ferrous Sliding	Scale 0-10	ASTM D7684*		
Ferrous Cutting	Scale 0-10	ASTM D7684*		1
Ferrous Rolling	Scale 0-10	ASTM D7684*	2	3
Ferrous Break-in	Scale 0-10	ASTM D7684*		
Ferrous Spheres	Scale 0-10	ASTM D7684*		
Ferrous Black Oxides	Scale 0-10	ASTM D7684*		
Ferrous Red Oxides	Scale 0-10	ASTM D7684*		
Ferrous Corrosive	Scale 0-10	ASTM D7684*	1	1
Ferrous Other	Scale 0-10	ASTM D7684*		
Nonferrous Rubbing	Scale 0-10	ASTM D7684*		
Nonferrous Sliding	Scale 0-10	ASTM D7684*		
Nonferrous Cutting	Scale 0-10	ASTM D7684*		
Nonferrous Rolling	Scale 0-10	ASTM D7684*		
Nonferrous Other	Scale 0-10	ASTM D7684*		
Carbonaceous Material	Scale 0-10	ASTM D7684*		
Lubricant Degradation	Scale 0-10	ASTM D7684*		
Sand/Dirt	Scale 0-10	ASTM D7684*	1	1
Fibres	Scale 0-10	ASTM D7684*		
Spheres	Scale 0-10	ASTM D7684*		
Other	Scale 0-10	ASTM D7684*	2	1

OIL ANALYSIS REPORT



Laboratory Sample No.
Lab Number
Unique Number
Test Package

To discuss this sample report, call
 Test denoted (*) outside scope of
 Validity of results and interpretation

ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	<1	<1	<1
Barium	ppm	ASTM D5185(m)	<1	0	0
Molybdenum	ppm	ASTM D5185(m)	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m)	<1	<1	0
Calcium	ppm	ASTM D5185(m)	<1	0	<1
Phosphorus	ppm	ASTM D5185(m)	<1	0	<1
Zinc	ppm	ASTM D5185(m)	<1	<1	<1
Sulfur	ppm	ASTM D5185(m)	13	15	31
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>5	<1	<1	1
Sodium	ppm	ASTM D5185(m)	>5	<1	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	0	0	<1
Water	%	ASTM D6304*	>0.005	0.001	0.00	0.043
ppm Water	ppm	ASTM D6304*	>50	2.0	0.00	435.5

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	55042	174829	273306
Particles >6µm	ASTM D7647	>1300	3803	17020	36010
Particles >14µm	ASTM D7647	>320	60	194	957
Particles >21µm	ASTM D7647	>80	16	49	199
Particles >38µm	ASTM D7647	>20	1	2	13
Particles >71µm	ASTM D7647	>4	0	1	1
Oil Cleanliness	ISO 4406 (c)	>19/17/15	23/19/13	25/21/15	25/22/17

FLUID DEGRADATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.10	0.11	0.08	0.10

VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	NONE	NONE	
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	
Precipitate	scalar	Visual*	NONE	NONE	NONE	
Silt	scalar	Visual*	NONE	NONE	NONE	
Debris	scalar	Visual*	NONE	NONE	VLITE	
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	
Appearance	scalar	Visual*	NORML	NORML	NORML	
Odor	scalar	Visual*	NORML	NORML	NORML	
Emulsified Water	scalar	Visual*	>0.005	NEG	NEG	.2%
Free Water	scalar	Visual*		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D7279(m)	30.0	32.6	32.2	32.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color					
Bottom					
PrtFilter					

