

PROBLEM SUMMARY

Sample Rating Trend

ISO


402 CRANE MAIN HOIST GEARBOX EAST SIDE

Component

Gearbox

SHELL OMALA S4 GX 220 (460 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | |
|--------------------------|--------------|-----------|-----------------|----------------------------|-----------------|--|--|--|
| Sample Status | | | ATTENTION | ABNORMAL | SEVERE | | | |
| Particles >4µm | ASTM D7647 | >20000 | 28450 | <u></u> 53538 | 2 46987 | | | |
| Particles >6µm | ASTM D7647 | >5000 | <u> </u> | <u> </u> | 56043 | | | |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | <u>22/20/15</u> | <u>\$\Delta\$ 23/21/16</u> | 25/23/16 | | | |

Customer Id: INCOCCSMR **Sample No.:** WC0811784 Lab Number: 02587339 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Gloria Gonzalez +1 (289)291-4643 x4643 gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---------------|--------|------|---------|---|
| Change Filter | | | ? | We recommend you service the filters on this component. |

HISTORICAL DIAGNOSIS

11 Oct 2022 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles $>4\mu m$ are abnormally high. Particles $>6\mu m$ and oil cleanliness are abnormally high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



19 Sep 2022 Diag: Kevin Marson

ISO



Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.lron ppm levels are marginal. A sharp increase in the iron level is noted. All other component wear rates are normal. Particles >6 μ m are severely high. Particles >4 μ m and oil cleanliness are severely high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.



19 Apr 2022 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. Please specify the component make and model with your next sample. All component wear rates are normal. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Machine Id

402 CRANE MAIN HOIST GEARBOX EAST SIDE

Component

Gearbox

SHELL OMALA S4 GX 220 (460 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a light amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFOR | MATION | method | limit/base | current | history1 | history2 |
|------------------------------|--------|---------------|-------------|-------------------|-------------------|------------------|
| Sample Number | | Client Info | mine bacc | WC0811784 | WC0698323 | WC0665416 |
| • | | Client Info | | | 11 Oct 2022 | 19 Sep 2022 |
| Sample Date Machine Age | Vro | Client Info | | 18 Sep 2023 0 | 0 | 0 Sep 2022 |
| Oil Age | yrs | Client Info | | 0 | 0 | 0 |
| • | yrs | Client Info | | Not Changd | Not Changd | Not Changd |
| Oil Changed Sample Status | | Cilent inio | | ATTENTION | ABNORMAL | SEVERE |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185(m) | >200 | 3 | 4 | △ 30 |
| Chromium | ppm | ASTM D5185(m) | >15 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185(m) | >15 | <1 | 0 | <1 |
| Titanium | | ASTM D5185(m) | >10 | 0 | 0 | <1 |
| Silver | ppm | , | | <1 | 0 | 0 |
| Aluminum | ppm | ASTM D5185(m) | > 25 | 0 | 0 | <1 |
| | ppm | ASTM D5185(m) | >25 >100 | | | |
| Lead | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185(m) | >200 | <1 | 0 | <1 |
| Tin | ppm | ASTM D5185(m) | >25 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185(m) | >5 | 0 | 0 | <1 |
| Vanadium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Beryllium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185(m) | | 0 | 0 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185(m) | | 21 | 22 | 17 |
| Barium | ppm | ASTM D5185(m) | | <1 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185(m) | | 0 | <1 | 13 |
| Manganese | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Magnesium | ppm | ASTM D5185(m) | | 0 | 0 | <1 |
| Calcium | ppm | ASTM D5185(m) | | 2 | 1 | 20 |
| Phosphorus | ppm | ASTM D5185(m) | | 414 | 458 | 464 |
| Zinc | ppm | ASTM D5185(m) | | 5 | 2 | 9 |
| Sulfur | ppm | ASTM D5185(m) | | 4951 | 5158 | 5600 |
| Lithium | ppm | ASTM D5185(m) | | <1 | <1 | <1 |
| CONTAMINANT | S | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185(m) | >50 | 11 | 11 | 16 |
| Sodium | ppm | ASTM D5185(m) | | 1 | <1 | 3 |
| Potassium | ppm | ASTM D5185(m) | >20 | <1 | <1 | 2 |
| FLUID CLEANLII | NESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | >20000 | 28450 | <u></u> 53538 | 2 46987 |
| Particles >6µm | | ASTM D7647 | >5000 | <u></u> 6011 | △ 10165 | 56043 |
| Particles >14µm | | ASTM D7647 | >640 | 245 | 358 | 512 |
| Particles >21µm | | ASTM D7647 | >160 | 37 | 57 | 65 |
| Particles >38µm | | ASTM D7647 | >40 | 2 | 0 | 1 |
| Particles >71µm | | | >10 | 0 | 0 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >21/19/16 | <u>^</u> 22/20/15 | <u>△</u> 23/21/16 | 2 5/23/16 |
| FLUID DEGRAD | ATION | method | limit/base | current | history1 | history2 |
| | | | 2.2.00 | | 2,2,7 | |

0.83

0.76



OIL ANALYSIS REPORT





CALA ISO 17025:2017 Accredited

Laboratory

Laboratory Sample No. Lab Number **Unique Number**

: WC0811784 : 02587339

: 5656405

: WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9 : 05 Oct 2023 Received Diagnosed : 06 Oct 2023

Diagnostician Test Package : IND 2 (Additional Tests: TAN Man)

: Wes Davis

Vale - Copper Cliff Smelter COPPER CLIFF SMELTER WAREHOUSE, 155 BALSAM ST. COPPER CLIFF, ON CA P0M 1N0

Contact: Andy Kozachanko andrew.kozachanko@vale.com T: (705)682-6687

To discuss this sample report, contact Customer Service at 1-800-268-2131. Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab. Validity of results and interpretation are based on the sample and information as supplied.

F: (705)682-6939