




PROBLEM SUMMARY

Sample Rating Trend


ISO



Machine Id
PH631.010.17 (S/N 3436)
 Component
Starboard Variable Pitch Prop
 Fluid
PETRO CANADA ULTIMA EP 150 (4500 LTR)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ATTENTION	ABNORMAL
Particles >4µm	ASTM D7647	>20000	▲ 60973	▲ 27739	---
Particles >6µm	ASTM D7647	>5000	▲ 7504	1122	---
Oil Cleanliness	ISO 4406 (c)	>21/19/15	▲ 23/20/14	▲ 22/17/12	---

Customer Id: PLACHOPE
 Sample No.: WC0797080
 Lab Number: 02587813
 Test Package: MAR 3



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Kevin Marson +1 (289)291-4644 x4644
Kevin.Marson@wearcheck.com

To change component or sample information:
 Gloria Gonzalez +1 (289)291-4643 x4643
gloria.gonzalez@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Contact Required	---	---	?	Please contact your representative for information regarding the proper sampling kits for your service.
Alert	---	---	?	NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

HISTORICAL DIAGNOSIS

17 Apr 2023 Diag: Kevin Marson

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. All component wear rates are normal. The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed).

view report



23 Mar 2023 Diag: Kevin Marson

VISUAL METAL



We advise that you check for visible metal particles in the oil. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. Light concentration of visible metal present. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service (unconfirmed).

view report



29 Dec 2022 Diag: Kevin Marson

NORMAL



Resample at the next service interval to monitor. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use. this testkit includes Analytical Ferrography which provides a detailed morphological analysis of wear particles present in the fluid. Component wear rates appear to be normal (unconfirmed). There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service (unconfirmed).


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
PH631.010.17 (S/N 3436)
 Component
Starboard Variable Pitch Prop
 Fluid
PETRO CANADA ULTIMA EP 150 (4500 LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition. Please contact your representative for information regarding the proper sampling kits for your service. NOTE: We recommend using Advanced Oil Monitoring (AOM) kits for this system. The AOM test package includes advanced level testing to determine the suitability of turbine and large industrial compressor oils for continued use.

Wear

Component wear rates appear to be normal (unconfirmed). The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system.

Contaminants

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Oil Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service (unconfirmed). The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0797080	WC0797084	WC0671098
Sample Date	Client Info		17 Sep 2023	17 Apr 2023	23 Mar 2023
Machine Age	hrs	Client Info	38502	37986	37889
Oil Age	hrs	Client Info	0	7698	0
Oil Changed	Client Info		Not Chngd	N/A	Changed
Sample Status			ABNORMAL	ATTENTION	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184*		0	0	---
Iron	ppm	ASTM D5185(m) >25	6	5	5
Chromium	ppm	ASTM D5185(m) >10	0	0	0
Nickel	ppm	ASTM D5185(m) >10	<1	<1	<1
Titanium	ppm	ASTM D5185(m)	0	0	0
Silver	ppm	ASTM D5185(m)	<1	0	0
Aluminum	ppm	ASTM D5185(m) >5	<1	0	<1
Lead	ppm	ASTM D5185(m) >5	4	3	4
Copper	ppm	ASTM D5185(m) >55	32	32	32
Tin	ppm	ASTM D5185(m) >5	3	3	3
Antimony	ppm	ASTM D5185(m)	0	<1	0
Vanadium	ppm	ASTM D5185(m)	0	0	0
Beryllium	ppm	ASTM D5185(m)	0	0	0
Cadmium	ppm	ASTM D5185(m)	0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m) 50	26	47	50
Barium	ppm	ASTM D5185(m) 0	<1	0	0
Molybdenum	ppm	ASTM D5185(m) 0	0	0	0
Manganese	ppm	ASTM D5185(m)	0	0	0
Magnesium	ppm	ASTM D5185(m) 0	1	<1	1
Calcium	ppm	ASTM D5185(m) 0	11	9	9
Phosphorus	ppm	ASTM D5185(m) 270	239	261	259
Zinc	ppm	ASTM D5185(m) 0	8	7	6
Sulfur	ppm	ASTM D5185(m) 5300	7341	7592	7739
Lithium	ppm	ASTM D5185(m)	<1	<1	<1

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m) >15	2	2	2
Sodium	ppm	ASTM D5185(m)	11	11	10
Potassium	ppm	ASTM D5185(m) >20	0	<1	<1

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 60973	▲ 27739	---
Particles >6µm	ASTM D7647	>5000	▲ 7504	1122	---
Particles >14µm	ASTM D7647	>320	147	31	---
Particles >21µm	ASTM D7647	>80	16	9	---
Particles >38µm	ASTM D7647	>20	1	1	---
Particles >71µm	ASTM D7647	>4	0	0	---
Oil Cleanliness	ISO 4406 (c)	>21/19/15	▲ 23/20/14	▲ 22/17/12	---



OIL ANALYSIS REPORT



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0797080
Lab Number : 02587813
Unique Number : 5656879
Test Package : MAR 3 (Additional Tests: TAN Man)

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D974*	0.4	0.42	---


VISUAL

method	limit/base	current	history1	history2
White Metal	scalar Visual*	NONE	NONE	▲ VLITE
Yellow Metal	scalar Visual*	NONE	NONE	NONE
Precipitate	scalar Visual*	NONE	NONE	NONE
Silt	scalar Visual*	NONE	NONE	NONE
Debris	scalar Visual*	NONE	NONE	VLITE
Sand/Dirt	scalar Visual*	NONE	NONE	NONE
Appearance	scalar Visual*	NORML	NORML	NORML
Odor	scalar Visual*	NORML	NORML	NORML
Emulsified Water	scalar Visual*	>0.05	NEG	NEG
Free Water	scalar Visual*		NEG	NEG

FLUID PROPERTIES

method	limit/base	current	history1	history2
Visc @ 40°C cSt	ASTM D7279(m)	150.0	146	148

SAMPLE IMAGES




CANSHIP UGLAND LTD.
 PLACENTIA HOPE, P.O. BOX 8274, STN. A
 ST. JOHN'S, NL
 CA A1B 3N4
 Contact: Brian Bishop
 bbishop@canship.com
 T: (709)782-7341
 F: (709)782-0225


FERROGRAPHY REPORT

Machine Id
PH631.010.17 (S/N 3436)
 Component
Starboard Variable Pitch Prop
 Fluid
PETRO CANADA ULTIMA EP 150 (4500 LTR)


Magn: 200x Illum: BC



Magn: 50x Illum: RW



Magn: 100x Illum: RW




DR-FERROGRAPHY		method	limit/base	current	history1	history2
Large Particles		DR-Ferr*		8.1	3.3	---
Small Particles		DR-Ferr*		7.4	1.4	---
Total Particles		DR-Ferr*	>---	15.5	4.7	---
Large Particles Percentage	%	DR-Ferr*		4.5	40.4	---
Severity Index		DR-Ferr*		6	6	---

FERROGRAPHY		method	limit/base	current	history1	history2
Ferrous Rubbing	Scale 0-10	ASTM D7684*		3	4	
Ferrous Sliding	Scale 0-10	ASTM D7684*				
Ferrous Cutting	Scale 0-10	ASTM D7684*				
Ferrous Rolling	Scale 0-10	ASTM D7684*		1	2	
Ferrous Break-in	Scale 0-10	ASTM D7684*				
Ferrous Spheres	Scale 0-10	ASTM D7684*				
Ferrous Black Oxides	Scale 0-10	ASTM D7684*				
Ferrous Red Oxides	Scale 0-10	ASTM D7684*				
Ferrous Corrosive	Scale 0-10	ASTM D7684*		1	1	
Ferrous Other	Scale 0-10	ASTM D7684*				
Nonferrous Rubbing	Scale 0-10	ASTM D7684*				
Nonferrous Sliding	Scale 0-10	ASTM D7684*				
Nonferrous Cutting	Scale 0-10	ASTM D7684*				
Nonferrous Rolling	Scale 0-10	ASTM D7684*				
Nonferrous Other	Scale 0-10	ASTM D7684*				
Carbonaceous Material	Scale 0-10	ASTM D7684*				
Lubricant Degradation	Scale 0-10	ASTM D7684*				
Sand/Dirt	Scale 0-10	ASTM D7684*		1	1	
Fibres	Scale 0-10	ASTM D7684*				
Spheres	Scale 0-10	ASTM D7684*				
Other	Scale 0-10	ASTM D7684*		1	2	

WEAR

Component wear rates appear to be normal (unconfirmed). The direct-reading & analytical ferrographic results are normal indicating no abnormal wear in the system.



This page left intentionally blank