


OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
[6100196787]
Machine Id
JD PE6068C275523

Component
Diesel Engine
Fluid
DIESEL ENGINE OIL SAE 15W40 (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
Metal levels are typical for a new component breaking in.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WA0020264	WA0012470	WA0011513
Sample Date	Client Info			04 Oct 2023	02 Oct 2018	19 Oct 2017
Machine Age	hrs	Client Info		240	53	43
Oil Age	hrs	Client Info		96	10	43
Oil Changed	Client Info			Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>5		<1.0	<1.0	0.0
Glycol	WC Method			NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185(m)	>100	5	3	13
Chromium	ppm	ASTM D5185(m)	>20	0	0	<1
Nickel	ppm	ASTM D5185(m)	>4	<1	0	0
Titanium	ppm	ASTM D5185(m)		0	0	0
Silver	ppm	ASTM D5185(m)	>3	<1	0	0
Aluminum	ppm	ASTM D5185(m)	>20	1	1	5
Lead	ppm	ASTM D5185(m)	>40	0	<1	2
Copper	ppm	ASTM D5185(m)	>330	<1	1	11
Tin	ppm	ASTM D5185(m)	>15	0	0	2
Antimony	ppm	ASTM D5185(m)		0	0	<1
Vanadium	ppm	ASTM D5185(m)		0	0	<1
Beryllium	ppm	ASTM D5185(m)		0	0	0
Cadmium	ppm	ASTM D5185(m)		0	0	0


ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185(m)	250	6	22	269
Barium	ppm	ASTM D5185(m)	10	<1	0	2
Molybdenum	ppm	ASTM D5185(m)	100	56	74	259
Manganese	ppm	ASTM D5185(m)		0	<1	3
Magnesium	ppm	ASTM D5185(m)	450	913	899	880
Calcium	ppm	ASTM D5185(m)	3000	1117	1027	1434
Phosphorus	ppm	ASTM D5185(m)	1150	1000	1008	919
Zinc	ppm	ASTM D5185(m)	1350	1161	1149	1075
Sulfur	ppm	ASTM D5185(m)	4250	2639	2697	2738
Lithium	ppm	ASTM D5185(m)		<1	0	<1

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185(m)	>25	3	4	8
Sodium	ppm	ASTM D5185(m)	>158	1	2	3
Potassium	ppm	ASTM D5185(m)	>20	0	<1	2

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	ASTM D7844*	>3	0	0	0
Nitration	Abs/cm	ASTM D7624*	>20	4.8	5.0	7.5
Sulfation	Abs/.1mm	ASTM D7415*	>30	17.9	18.9	25.0

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	ASTM D7414*	>25	12.3	13.7	16.1









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D7279(m)	14.4	14.5	14.4

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WA0020264 **Received** : 12 Oct 2023
Lab Number : 02588506 **Diagnosed** : 12 Oct 2023
Unique Number : 5657572 **Diagnostician** : Wes Davis
Test Package : MOB 1

Wajax Power Systems
 485 VENTURE DR
 MONCTON, NB
 CA E1H 2P4
 Contact: Doug Balsler
 dbalsler@wajax.com
 T: (506)855-5371
 F: (506)870-4448

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.