



# PROBLEM SUMMARY

Sample Rating Trend


VISCOSITY

Area

**5**  
Machine Id  
**5-3-230-D Pump Station for Atox Roller Lube**


Component  
**Reservoir Bearing Lube**

Fluid  
**MOBIL SHC 639 (1000 LTR)**



## COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



## RECOMMENDATION

Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	NORMAL
Visc @ 40°C	cSt	ASTM D7279(m)	923	▲ 696	▲ 680	731

Customer Id: STMBOW  
Sample No.: WC0851473  
Lab Number: 02588749  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

### 02 Oct 2023 Diag: Kevin Marson

#### VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. Viscosity of sample indicates oil is within ISO 680 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 25 Sep 2023 Diag: Wes Davis

#### NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 18 Sep 2023 Diag: Bill Quesnel

#### VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. Viscosity of sample indicates oil is within ISO 680 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report





# OIL ANALYSIS REPORT

Sample Rating Trend

VISCOSITY

Area

5

Machine Id


## 5-3-230-D Pump Station for Atox Roller Lube

Component

Reservoir Bearing Lube

Fluid

MOBIL SHC 639 (1000 LTR)



### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

#### Fluid Condition

Viscosity of sample indicates oil is within ISO 680 range, advise investigate. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0851473</b>	WC0851472	WC0842673
Sample Date	Client Info		<b>10 Oct 2023</b>	02 Oct 2023	25 Sep 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>120	<b>&lt;1</b>	2	<1
Chromium	ppm	ASTM D5185(m)	>5	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Aluminum	ppm	ASTM D5185(m)	>4	<b>0</b>	0	<1
Lead	ppm	ASTM D5185(m)	>30	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185(m)	>17	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185(m)	>10	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)	0.2	<b>1</b>	2	<1
Barium	ppm	ASTM D5185(m)	0.0	<b>0</b>	<1	<1
Molybdenum	ppm	ASTM D5185(m)	0.0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)	0.0	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)	0.6	<b>0</b>	0	0
Calcium	ppm	ASTM D5185(m)	0.0	<b>&lt;1</b>	<1	<1
Phosphorus	ppm	ASTM D5185(m)	691	<b>388</b>	386	403
Zinc	ppm	ASTM D5185(m)	2.0	<b>1</b>	<1	<1
Sulfur	ppm	ASTM D5185(m)	18	<b>255</b>	352	52
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1

### CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>25	<b>19</b>	20	22
Sodium	ppm	ASTM D5185(m)		<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0


### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>19365</b>	22104	26775
Particles >6µm	ASTM D7647	>320000	<b>2320</b>	2698	4948
Particles >14µm	ASTM D7647	>160000	<b>53</b>	77	140
Particles >21µm	ASTM D7647	>40000	<b>10</b>	22	23
Particles >38µm	ASTM D7647	>10000	<b>1</b>	5	2
Particles >71µm	ASTM D7647	>2500	<b>0</b>	3	1
Oil Cleanliness	ISO 4406 (c)	>25/24	<b>18/13</b>	19/13	19/14


### FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974*	0.32	<b>0.46</b>	0.47	0.52


### Particle Trend




### Particle Count



### Acid Number




### Particle Trend





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	NONE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.2	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	923 ▲ 696	680	731

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0851473 **Received** : 12 Oct 2023  
**Lab Number** : 02588749 **Diagnosed** : 13 Oct 2023  
**Unique Number** : 5657815 **Diagnostician** : Kevin Marson  
**Test Package** : IND 2 ( Additional Tests: TAN Man )

**ST. MARYS CEMENT CO.**  
 400 BOWMANVILLE AVENUE  
 BOWMANVILLE, ON  
 CA L1C 7B5  
 Contact: Lou Traiforos  
 lou.traiforos@vcimentos.com  
 T: (905)440-5874  
 F: (905)623-4695

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.