




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**[4250]**  
 Machine Id  
**10-009-CD**  
 Component  
**New (Unused) Oil**  
 Fluid  
**PETRO CANADA LUMINOL LS B-4 (--- GAL)**



## DIAGNOSIS

### Recommendation

This is a baseline read-out on the submitted sample.

### Wear

{not applicable}

### Contamination

{not applicable}

### Fluid Condition

Pour Point = -60°C.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PP0000786</b>	---	---
Sample Date	Client Info		<b>11 Oct 2023</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>N/A</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>5	<b>0</b>	---	---
Chromium	ppm	ASTM D5185(m)	>5	<b>0</b>	---	---
Nickel	ppm	ASTM D5185(m)	>5	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185(m)		<b>0</b>	---	---
Silver	ppm	ASTM D5185(m)	>5	<b>&lt;1</b>	---	---
Aluminum	ppm	ASTM D5185(m)	>5	<b>0</b>	---	---
Lead	ppm	ASTM D5185(m)	>5	<b>0</b>	---	---
Copper	ppm	ASTM D5185(m)	>5	<b>&lt;1</b>	---	---
Tin	ppm	ASTM D5185(m)	>5	<b>0</b>	---	---
Antimony	ppm	ASTM D5185(m)		<b>0</b>	---	---
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	---	---
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	---	---
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<b>&lt;1</b>	---	---
Barium	ppm	ASTM D5185(m)		<b>&lt;1</b>	---	---
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	---	---
Manganese	ppm	ASTM D5185(m)		<b>0</b>	---	---
Magnesium	ppm	ASTM D5185(m)		<b>0</b>	---	---
Calcium	ppm	ASTM D5185(m)		<b>0</b>	---	---
Phosphorus	ppm	ASTM D5185(m)		<b>0</b>	---	---
Zinc	ppm	ASTM D5185(m)		<b>&lt;1</b>	---	---
Sulfur	ppm	ASTM D5185(m)		<b>&lt;1</b>	---	---
Lithium	ppm	ASTM D5185(m)		<b>&lt;1</b>	---	---

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<b>&lt;1</b>	---	---
Sodium	ppm	ASTM D5185(m)	>5	<b>0</b>	---	---
Potassium	ppm	ASTM D5185(m)	>20	<b>0</b>	---	---

## VISUAL

	method	limit/base	current	history1	history2	
White Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Yellow Metal	scalar	Visual*	NONE	<b>NONE</b>	---	---
Precipitate	scalar	Visual*	NONE	<b>NONE</b>	---	---
Silt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Debris	scalar	Visual*	NONE	<b>NONE</b>	---	---
Sand/Dirt	scalar	Visual*	NONE	<b>NONE</b>	---	---
Appearance	scalar	Visual*	NORML	<b>NORML</b>	---	---
Odor	scalar	Visual*	NORML	<b>NORML</b>	---	---






# OIL ANALYSIS REPORT

FLUID PROPERTIES	method	limit/base	current	history1	history2
Pour Point	°C	ASTM D97*	<b>-60</b>	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color			<i>no image</i>	<i>no image</i>	<i>no image</i>
Bottom			<i>no image</i>	<i>no image</i>	<i>no image</i>

## GRAPHS



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : PP0000786 **Received** : 12 Oct 2023  
**Lab Number** : **02588768** **Diagnosed** : 13 Oct 2023  
**Unique Number** : 5657834 **Diagnostician** : Kevin Marson  
**Test Package** : TEST ( Additional Tests: ICP, PourPt, Visual )

To discuss this sample report, contact Customer Service at 1-800-268-2131.  
 Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.  
 Validity of results and interpretation are based on the sample and information as supplied.

**Oleo Energies**  
 5800 Thorold Stone Road  
 Niagara Falls, ON  
 CA L2J 1A2  
 Contact: Mark Michalkoff  
 mmichalkoff@oleoenergies.com  
 T: (905)358-5133  
 F: