



OIL ANALYSIS REPORT


Sample Rating Trend

COMBUSTION



Machine Id
PIONEER GEN 4 TRANSFORMER (S/N G14062-5)

Component
Transformer Oil
Fluid
NOT GIVEN (1935 LTR)



DIAGNOSIS

Recommendation
Recommend early resample to monitor.

Wear
{not applicable}

Contamination
Ethane >=65 (0.0065%): Low energy arcing in a confined space. All other gas values normal.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0850743	WC0752817	WC0630486
Sample Date	Client Info	04 Oct 2023	14 Oct 2022	21 Oct 2021
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	MARGINAL	MARGINAL

DISSOLVED GAS ANALYSIS (DGA)

method	limit/base	current	history1	history2	
DGA - H2	ppm	ASTM D3612(e)*	5	5	6
DGA - O2	ppm	ASTM D3612(e)*	147	236	326
DGA - N2	ppm	ASTM D3612(e)*	64612	60435	82957
DGA - CO	ppm	ASTM D3612(e)*	206	181	248
DGA - CO2	ppm	ASTM D3612(e)*	1591	1125	1277
DGA - Methane	ppm	ASTM D3612(e)*	68	51	60
DGA - Acetylene	ppm	ASTM D3612(e)*	0	0	0
DGA - Ethylene	ppm	ASTM D3612(e)*	22	12	13
DGA - Ethane	ppm	ASTM D3612(e)*	▲ 125	▲ 88	▲ 93
DGA - Total Gas Content	%	ASTM D3612(e)*	66776	62133	84980
DGA - Total Combustible Gas	ppm	ASTM D3612(e)*	426	337	420

VISUAL

method	limit/base	current	history1	history2		
White Metal	scalar	Visual*	NONE	NONE	NONE	---
Yellow Metal	scalar	Visual*	NONE	NONE	NONE	---
Precipitate	scalar	Visual*	NONE	NONE	NONE	---
Silt	scalar	Visual*	NONE	NONE	NONE	---
Debris	scalar	Visual*	NONE	NONE	NONE	---
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE	---
Appearance	scalar	Visual*	NORML	NORML	NORML	---
Odor	scalar	Visual*	NORML	NORML	NORML	---




SAMPLE IMAGES

method	limit/base	current	history1	history2
Color				no image
Bottom				no image



OIL ANALYSIS REPORT

GRAPHS



Laboratory : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9
Sample No. : WC0850743
Lab Number : 02588788
Unique Number : 5657854
Test Package : TEST (Additional Tests: DGA)

BRODER ELECTRIC
 14 GRENFELL CRESCENT, SUITE 100
 NEPEAN, ON
 CA K2G 0G2
 Contact: Carly Joudoin
 carly@broderelectric.ca
 T: (613)224-1176
 F:

To discuss this sample report, contact Customer Service at 1-800-268-2131.
 Test denoted (*) outside scope of accreditation, (m) method modified, (e) tested at external lab.
 Validity of results and interpretation are based on the sample and information as supplied.