




# PROBLEM SUMMARY

Area  
**OPK/CL05**  
 Machine Id  
**101811 Calander**  
 Component  
**Hydraulic System**  
 Fluid  
**ESSO TERESSO ISO 32 (80 LTR)**

Sample Rating Trend




**VISUAL METAL**



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	SEVERE	ABNORMAL
Particles >4µm	ASTM D7647	>5000	▲ <b>16077</b>	▲ 38724	▲ 26936	
Particles >6µm	ASTM D7647	>1300	▲ <b>5160</b>	● 14330	▲ 8915	
Particles >14µm	ASTM D7647	>160	▲ <b>486</b>	● 1524	▲ 941	
Particles >21µm	ASTM D7647	>40	▲ <b>139</b>	● 443	▲ 278	
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ <b>21/20/16</b>	● 22/21/18	▲ 22/20/17	
White Metal	scalar	Visual*	NONE	▲ <b>VLITE</b>	NONE	NONE
PrtFilter					no image	no image

Customer Id: MITWAT  
 Sample No.: WC0790683  
 Lab Number: 02588900  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Kevin Marson +1 (289)291-4644 x4644  
[Kevin.Marson@wearcheck.com](mailto:Kevin.Marson@wearcheck.com)

To change component or sample information:  
 Gloria Gonzalez +1 (289)291-4643 x4643  
[gloria.gonzalez@wearcheck.com](mailto:gloria.gonzalez@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check For Visual Metal	---	---	?	We advise that you check for visible metal particles in the oil.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

### 21 Mar 2023 Diag: Wes Davis

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. All component wear rates are normal. Particles >14µm are severely high. Particles >21µm are severely high. Particles >6µm are severely high. Oil Cleanliness are severely high. Particles >4µm are abnormally high. Particles >38µm are notably high. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



### 06 Apr 2022 Diag: Wes Davis

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Particles >14µm are abnormally high. Particles >21µm are abnormally high. Particles >4µm are abnormally high. Particles >38µm are abnormally high. Particles >6µm are abnormally high. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 23 Mar 2022 Diag: Kevin Marson

VISCOSITY



Due to this condition we recommend the following action... We advise an early resample to confirm this situation. NOTE: The current sample results do not match this units historical trend, indicating the sample may not be from this component/unit. All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. This plus the additive levels indicates that this is not the same brand, or type of oil as reported. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

## Sample Rating Trend



## VISUAL METAL



Area  
**OPK/CL05**  
 Machine Id  
**101811 Calander**  
 Component  
**Hydraulic System**  
 Fluid  
**ESSO TERESSO ISO 32 (80 LTR)**

### DIAGNOSIS

#### Recommendation

We advise that you check for visible metal particles in the oil. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

#### Wear

Light concentration of visible metal present.

#### Contamination

There is a moderate amount of particulates (2 to 100 microns in size) present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0790683</b>	WC0763703	WC0651600
Sample Date	Client Info		<b>03 Oct 2023</b>	21 Mar 2023	06 Apr 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	SEVERE	ABNORMAL

### WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185(m)	>20	<1	<1	0
Chromium	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185(m)	>20	<1	0	<1
Titanium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Silver	ppm	ASTM D5185(m)		<1	0	0
Aluminum	ppm	ASTM D5185(m)	>20	<1	1	<1
Lead	ppm	ASTM D5185(m)	>20	<b>0</b>	<1	0
Copper	ppm	ASTM D5185(m)	>20	<1	0	<1
Tin	ppm	ASTM D5185(m)	>20	<b>0</b>	0	0
Antimony	ppm	ASTM D5185(m)		<b>0</b>	0	0
Vanadium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Beryllium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185(m)		<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185(m)		<1	0	<1
Barium	ppm	ASTM D5185(m)		<1	0	0
Molybdenum	ppm	ASTM D5185(m)		<b>0</b>	0	0
Manganese	ppm	ASTM D5185(m)		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Calcium	ppm	ASTM D5185(m)		<b>2</b>	0	2
Phosphorus	ppm	ASTM D5185(m)		<b>2</b>	2	2
Zinc	ppm	ASTM D5185(m)		<b>2</b>	2	2
Sulfur	ppm	ASTM D5185(m)		<b>1729</b>	1669	1647
Lithium	ppm	ASTM D5185(m)		<1	<1	<1

### CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185(m)	>15	<1	<1	<1
Sodium	ppm	ASTM D5185(m)		<b>0</b>	0	0
Potassium	ppm	ASTM D5185(m)	>20	<1	0	0


### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ <b>16077</b>	▲ 38724	▲ 26936
Particles >6µm	ASTM D7647	>1300	▲ <b>5160</b>	■ 14330	▲ 8915
Particles >14µm	ASTM D7647	>160	▲ <b>486</b>	■ 1524	▲ 941
Particles >21µm	ASTM D7647	>40	▲ <b>139</b>	■ 443	▲ 278
Particles >38µm	ASTM D7647	>10	<b>10</b>	▲ 16	▲ 32
Particles >71µm	ASTM D7647	>3	<b>1</b>	1	3
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ <b>21/20/16</b>	■ 22/21/18	▲ 22/20/17

### FLUID DEGRADATION





	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974*	<b>0.13</b>	0.13	0.12

Particle Filter (Magn: 100 x)





# OIL ANALYSIS REPORT



ISO 17025:2017  
Accredited  
Laboratory

**Laboratory** : WearCheck - C8-1175 Appleby Line, Burlington, ON L7L 5H9  
**Sample No.** : WC0790683  
**Lab Number** : 02588900  
**Unique Number** : 5657966  
**Test Package** : IND 2 (Additional Tests: Bottom, BottomAnalysis, FilterPatch, PrtFilter, TAN Man)

**Received** : 13 Oct 2023  
**Diagnosed** : 16 Oct 2023  
**Diagnostician** : Kevin Marson

To discuss this sample report, contact Customer Service at 1-800-268-2131.

Test denoted (\*) outside scope of accreditation, (m) method modified, (e) tested at external lab.

Validity of results and interpretation are based on the sample and information as supplied.

**MICHELIN TIRE**  
 866 RANDOLPH RD  
 WATERVILLE, NS  
 CA B0P 1V0

Contact: Alan Davies  
 alan.davies@michelin.com


T: (902)534-3590

F: x:

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	Visual*	NONE	▲ VLITE	NONE
Yellow Metal	scalar	Visual*	NONE	NONE	NONE
Precipitate	scalar	Visual*	NONE	NONE	NONE
Silt	scalar	Visual*	NONE	NONE	NONE
Debris	scalar	Visual*	NONE	NONE	NONE
Sand/Dirt	scalar	Visual*	NONE	NONE	NONE
Appearance	scalar	Visual*	NORML	NORML	NORML
Odor	scalar	Visual*	NORML	NORML	NORML
Emulsified Water	scalar	Visual*	>0.05	NEG	NEG
Free Water	scalar	Visual*		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D7279(m)	32	31.9	31.7 32.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS

